

SVRATOUCH, Czech Republic

WMO: 116830

Lat: 49.7350N

Lon: 16.0342E

Elev: 2429

StdP: 13.45

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.4	12.3	2.2	6.7	11.3	7.2	8.7	14.5	43.6	20.8	40.1	24.4	12.4	180	0.715

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.8	81.4	65.2	77.9	64.0	74.9	62.5	66.9	77.6	65.3	75.3	63.8	72.8	10.0	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.3	95.2	70.9	61.7	90.0	69.2	60.3	85.4	67.7	32.9	77.8	31.5	75.6	30.3	72.8	74.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 35.9	30.9	26.8	3.7	85.9	5.5	3.7	-0.2	88.6	-3.4	90.7	-6.5	92.8	-10.5	95.5		
(5)			3.3	70.0	5.4	1.8	-0.5	71.3	-3.7	72.3	-6.7	73.3	-10.6	74.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.9	26.5	28.8	35.1	45.0	53.0	59.0	62.8	62.7	54.0	45.4	36.5	28.6		
	DBStd	14.97	7.81	8.44	8.01	8.62	7.18	7.07	6.85	6.60	6.89	7.50	7.34	7.38		
	HDD50	3332	728	594	463	193	52	9	1	2	36	183	407	664		
	HDD65	7487	1193	1014	926	599	375	203	127	123	334	608	856	1129		
	CDD50	1462	0	0	2	45	146	279	397	396	156	40	1	0		
	CDD65	142	0	0	0	0	3	24	58	52	5	0	0	0		
	CDH74	850	0	0	0	0	19	139	357	316	19	0	0	0		
	CDH80	157	0	0	0	0	1	18	72	65	1	0	0	0		
	WSAvg	12.7	14.7	14.2	13.7	12.5	12.0	10.3	10.2	10.1	11.4	13.7	15.4	14.5		
	PrecAvg	26.8	1.7	1.4	2.0	1.6	2.8	3.0	3.6	3.0	2.4	1.7	1.8	1.7		
(15) Precipitation	PrecMax	33.0	3.5	2.9	5.9	3.5	4.8	5.5	10.3	7.6	5.6	3.9	3.8	3.0		
	PrecMin	20.7	0.4	0.4	0.6	0.1	0.5	0.6	1.2	0.8	0.6	0.2	0.0	0.7		
	PrecStd	3.5	0.8	0.8	1.1	0.7	1.1	1.2	1.9	1.7	1.5	0.9	0.8	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.7	50.0	58.4	70.0	76.5	82.6	86.1	85.8	76.6	65.7	54.6	46.6		
		MCWB	43.0	42.3	47.7	55.5	60.7	66.8	66.4	65.5	62.2	57.3	50.7	43.7		
	2%	DB	43.2	45.4	53.8	65.5	71.9	78.4	81.6	81.1	71.7	61.7	51.6	43.4		
		MCWB	40.7	41.2	45.6	52.8	59.2	65.0	65.3	64.8	60.2	55.0	48.9	41.7		
	5%	DB	39.7	42.2	49.6	61.4	68.1	74.5	77.8	77.3	67.8	58.2	48.9	40.5		
		MCWB	38.1	38.8	43.1	50.7	57.4	62.5	64.1	63.7	58.3	53.4	46.6	39.1		
	10%	DB	36.9	39.3	46.1	57.8	64.6	70.9	74.5	73.9	64.2	55.5	46.2	38.0		
		MCWB	35.6	36.9	41.4	49.0	55.7	60.9	62.9	62.1	56.9	52.3	44.7	37.0		
	0.4%	WB	44.2	44.6	49.1	56.5	63.2	69.1	69.2	68.4	63.9	58.6	51.6	44.7		
		MCDB	45.8	47.5	56.3	67.4	73.5	79.4	79.2	79.4	73.0	62.9	53.0	45.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	41.1	41.9	46.4	54.2	60.4	66.2	67.0	66.2	61.4	56.1	49.6	42.0		
		MCDB	42.5	44.4	51.6	63.6	68.9	75.6	77.7	77.7	68.7	59.8	51.5	43.3		
	5%	WB	38.2	39.6	44.3	51.8	58.5	63.9	65.3	64.6	59.6	54.3	47.0	39.4		
		MCDB	39.6	41.7	48.5	59.3	66.1	72.4	75.5	74.7	65.8	57.4	48.4	40.3		
	10%	WB	35.7	37.1	42.1	49.7	56.6	61.7	63.8	63.1	57.9	52.5	44.9	37.2		
		MCDB	37.0	39.1	45.4	56.7	63.4	69.3	72.7	72.0	63.2	55.4	46.0	38.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.2	8.4	10.6	13.6	14.2	14.5	14.8	15.0	12.2	10.0	7.2	6.9		
		MCDBR	9.7	11.2	15.7	17.5	18.4	18.8	19.4	19.4	17.0	13.6	10.1	9.0		
		MCWBR	8.0	8.0	9.8	9.3	9.7	9.9	9.0	8.6	8.5	8.2	7.4	7.6		
		MCDBR	8.8	10.1	14.1	16.4	17.0	17.7	18.0	17.4	15.2	12.5	9.0	8.7		
	5% WB	MCWBR	7.8	8.0	9.6	9.4	9.6	9.8	9.0	8.6	8.5	8.0	7.3	7.9		
(40) Clear-Sky Solar Irradiance	taub		0.287	0.309	0.347	0.388	0.389	0.389	0.402	0.397	0.367	0.343	0.318	0.285		
	taud		2.364	2.345	2.306	2.248	2.278	2.302	2.269	2.299	2.358	2.406	2.418	2.406		
	Ebn at Noon		242	264	272	271	276	276	270	265	262	248	227	226		
	Edh at Noon		21	27	34	40	40	40	40	37	32	25	20	17		
(44) All-Sky Solar Radiation	RadAvg		275	533	867	1332	1592	1714	1632	1457	1033	600	291	208		
	RadStd		48	73	141	167	188	147	175	139	144	88	36	22		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (66 neighbors)		+0.88	N/A	N/A	N/A	+0.67	+0.61	N/A	-277	+121	+45

Nomenclature: See separate page