

NAMEST NAD OSLAVOU, Czech Republic

WMO: 116920

Lat: 49.1708N

Lon: 16.1206E

Elev: 480

StdP: 95.70

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -12.0	(c) -9.7	(d) -15.6	(e) 1.0	(f) -10.8	(g) -12.6	(h) 1.3	(i) -8.3	(j) 13.3	(k) 3.3	(l) 11.9	(m) 2.2	(n) 2.8	(o) 340	(p) 0.564

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.5	29.4	19.4	27.5	18.6	25.8	18.0	20.5	26.6	19.6	25.6	18.8	24.3	3.7	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.5	14.1	22.9	17.6	13.3	22.0	16.7	12.6	21.1	61.1	26.6	57.9	25.6	55.1	24.5	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
10.4	9.1	7.9	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-14.0	32.2	2.1	1.6	-15.6	33.4	-16.8	34.3	-18.0	35.2	-19.5	36.4
			-14.4	22.9	2.1	1.8	-16.0	24.2	-17.2	25.2	-18.4	26.2	-19.9	27.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.8	-1.9	0.0	3.8	9.1	13.5	17.1	18.9	18.9	13.9	8.7	3.8	-0.9
	DBStd	8.36	4.31	4.39	4.18	4.18	3.72	3.68	3.48	3.41	3.53	3.76	4.03	4.17
	HDD10.0	1520	368	279	193	64	11	1	0	0	7	71	188	339
	HDD18.3	3624	626	512	449	276	154	67	37	34	138	298	435	597
	CDD10.0	1081	0	0	2	39	121	213	274	275	123	31	3	0
	CDD18.3	143	0	0	0	0	5	29	53	51	5	0	0	0
	CDH23.3	1069	0	0	0	1	32	200	414	391	32	0	0	0
	CDH26.7	252	0	0	0	0	2	37	108	103	2	0	0	0
Wind	WSAvg	3.6	3.8	3.9	4.0	3.7	3.5	3.3	3.5	3.1	3.3	3.4	3.6	3.6
Precipitation	PrecAvg	515	24	21	33	33	59	67	73	62	48	34	33	27
	PrecMax	771	48	59	88	72	125	144	197	136	116	69	64	44
	PrecMin	392	3	2	7	2	16	14	12	22	7	4	3	7
	PrecStd	87	12	14	21	18	22	30	38	31	30	17	14	11
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.3	12.1	16.7	22.5	26.2	30.2	31.7	32.0	26.5	20.1	14.8	9.2
		MCWB	7.8	7.6	9.8	14.0	17.0	19.8	19.9	20.0	17.5	14.6	12.0	7.8
	2%	DB	7.6	9.6	14.5	20.2	23.9	27.5	29.5	29.4	23.9	17.6	12.5	7.2
		MCWB	5.9	6.8	8.8	12.8	16.4	19.4	19.6	18.9	16.6	13.8	10.6	6.0
	5%	DB	5.6	7.8	12.2	18.2	22.1	25.6	27.6	27.3	21.7	15.8	10.7	5.7
		MCWB	4.4	5.4	7.6	11.7	15.5	18.2	18.6	18.3	15.8	12.9	9.4	4.6
	10%	DB	3.7	5.8	10.1	16.1	20.2	23.8	25.7	25.3	19.8	14.1	9.1	4.3
		MCWB	2.8	4.1	6.7	10.5	14.3	17.3	18.0	17.6	15.0	12.1	8.1	3.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.3	8.6	10.8	14.9	18.5	21.9	21.9	21.2	18.7	15.8	12.2	8.0
		MCDB	10.1	11.2	15.1	21.2	24.1	27.1	28.9	27.7	23.6	18.3	14.2	9.0
	2%	WB	6.2	7.1	9.4	13.5	17.2	20.2	20.5	20.0	17.4	14.4	10.9	6.2
		MCDB	7.4	9.2	13.3	19.2	22.5	25.6	26.8	26.7	22.2	16.6	12.1	7.1
	5%	WB	4.4	5.7	8.3	12.2	16.1	19.1	19.6	19.2	16.5	13.4	9.5	4.8
		MCDB	5.5	7.5	11.5	17.0	20.9	24.2	25.6	25.4	20.5	15.3	10.5	5.5
	10%	WB	2.8	4.2	7.0	11.0	15.0	17.9	18.7	18.4	15.6	12.4	8.2	3.7
		MCDB	3.6	5.6	9.5	15.4	19.3	22.6	24.2	24.1	19.1	14.0	9.0	4.3
Mean Daily Temperature Range	5% DB	MDBR	4.3	5.5	7.1	8.8	8.8	9.2	9.5	9.6	7.9	6.2	4.4	4.0
		MCDBR	6.2	7.9	10.7	11.3	11.1	11.5	12.3	12.2	10.8	8.5	6.3	5.6
		MCWBR	5.0	5.5	6.2	5.8	5.5	5.2	4.7	4.7	5.1	5.3	4.5	4.8
	5% WB	MCDBR	6.0	7.4	9.5	10.7	10.4	10.4	11.0	10.9	9.5	7.6	5.7	5.4
		MCWBR	5.0	5.5	6.2	5.8	5.7	5.2	4.8	4.7	5.1	5.2	4.3	4.7
Clear-Sky Solar Irradiance	taub	0.300	0.322	0.361	0.405	0.405	0.406	0.416	0.413	0.384	0.357	0.333	0.299	
	taud	2.361	2.343	2.290	2.212	2.248	2.276	2.250	2.275	2.327	2.376	2.391	2.403	
	Ebn at Noon	753	822	844	840	855	855	839	823	809	768	703	705	
	Edh at Noon	67	87	109	130	131	129	130	121	104	84	66	57	
All-Sky Solar Radiation	RadAvg	0.90	1.74	2.83	4.29	5.07	5.50	5.26	4.70	3.34	1.97	0.97	0.70	
	RadStd	0.15	0.23	0.44	0.51	0.59	0.46	0.54	0.45	0.45	0.27	0.11	0.07	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.59	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+75	+43
(47) Regional (77 neighbors)		+0.52	N/A	N/A	N/A	+0.38	+0.32	-122	-157	+69	+27

Nomenclature: See separate page