

KUCCHAROVICE, Czech Republic

WMO: 116980

Lat: 48.8811N

Lon: 16.0853E

Elev: 1111

StdP: 14.12

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.0	15.6	4.1	7.1	12.8	9.3	9.2	18.0	29.5	38.4	27.2	37.1	7.4	10	0.567

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.3	88.1	67.7	84.6	66.4	81.5	65.1	69.7	83.2	68.1	81.0	66.6	78.2	9.3	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.3	97.5	74.4	63.8	92.2	72.8	62.3	87.5	71.5	34.4	82.5	33.0	80.9	31.8	78.5	77.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.7	21.5	18.7	6.4	93.4	5.7	3.5	2.3	95.9	-1.1	98.0	-4.3	100.0	-8.4	102.5
			5.6	72.9	5.6	2.0	1.6	74.3	-1.7	75.5	-4.8	76.6	-8.9	78.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	49.5	30.1	33.4	40.4	50.1	57.9	64.3	68.3	67.7	58.9	49.4	40.4	31.9	(6)
(7)		DBStd	15.20	8.12	8.27	7.55	7.63	6.48	6.54	5.94	5.96	6.24	6.81	7.17	7.53	(7)
(8)		HDD50	2453	617	467	306	92	10	0	0	5	98	297	561		(8)
(9)		HDD65	6026	1082	886	761	449	234	92	35	40	198	485	738	1026	(9)
(10)		CDD50	2264	0	1	9	94	255	430	566	548	273	79	9	0	(10)
(11)		CDD65	361	0	0	0	1	14	71	136	123	16	0	0	0	(11)
(12)		CDH74	3324	0	0	0	15	131	652	1296	1101	125	4	0	0	(12)
(13)		CDH80	988	0	0	0	0	17	166	438	350	17	0	0	0	(13)
(14)	Wind	WSAvg	8.6	9.2	9.3	9.7	9.2	8.8	7.9	8.2	7.6	8.1	8.2	8.8	8.6	(14)
(15)	Precipitation	PrecAvg	19.4	0.9	0.7	1.2	1.3	2.2	2.6	2.7	2.4	2.0	1.3	1.2	1.0	(15)
(16)		PrecMax	28.6	2.0	2.2	3.3	3.0	4.3	5.2	8.1	5.4	4.9	2.9	2.5	1.7	(16)
(17)		PrecMin	14.6	0.1	0.1	0.2	0.0	0.6	0.8	0.4	0.7	0.4	0.2	0.1	0.3	(17)
(18)		PrecStd	3.3	0.5	0.5	0.7	0.7	0.8	1.1	1.5	1.2	1.2	0.7	0.6	0.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.3	56.2	65.4	76.1	82.4	89.5	92.5	92.6	82.3	71.7	61.1	51.0	(19)
(20)			MCWB	47.6	47.4	51.3	58.2	63.5	68.9	68.4	68.3	64.5	60.3	54.4	46.9	(20)
(21)		2%	DB	47.8	51.4	60.6	71.2	77.5	84.7	88.5	87.6	77.7	66.1	56.4	47.3	(21)
(22)			MCWB	43.3	45.4	49.2	56.3	62.4	67.4	67.7	67.0	62.8	57.4	51.6	44.0	(22)
(23)		5%	DB	44.0	47.7	56.0	67.3	74.1	81.2	85.1	83.8	73.7	62.6	52.9	44.1	(23)
(24)			MCWB	40.7	42.9	46.8	53.9	60.9	65.8	66.3	66.0	61.0	55.7	49.4	41.2	(24)
(25)		10%	DB	40.6	44.2	52.1	63.5	70.7	77.7	81.4	80.3	70.1	59.2	49.9	41.4	(25)
(26)			MCWB	37.9	40.1	44.9	51.9	58.5	63.9	65.1	64.6	59.7	54.2	47.3	39.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.3	48.5	53.1	59.3	66.9	71.9	71.8	70.9	66.2	61.2	55.2	47.5	(27)
(28)			MCDWB	52.8	54.6	62.3	73.0	78.5	84.6	85.7	85.7	77.5	67.4	60.5	50.2	(28)
(29)		2%	WB	43.9	45.6	50.1	57.0	64.3	69.6	69.5	68.9	64.3	58.5	52.3	44.3	(29)
(30)			MCDWB	47.1	50.6	58.2	69.5	75.1	81.4	83.8	82.7	75.0	63.7	55.7	46.9	(30)
(31)		5%	WB	41.0	43.1	47.9	54.8	61.9	67.3	68.0	67.3	62.4	56.7	49.8	41.6	(31)
(32)			MCDWB	43.7	47.4	54.8	65.3	71.6	77.9	81.4	80.2	70.7	61.4	52.6	43.6	(32)
(33)		10%	WB	38.0	40.4	45.5	52.9	59.8	65.2	66.4	65.8	60.7	54.8	47.6	39.5	(33)
(34)			MCDWB	40.4	43.8	51.2	62.2	68.7	75.2	78.3	77.2	68.4	58.7	49.7	41.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.5	11.1	14.3	18.1	18.1	19.4	20.3	19.6	16.1	12.6	8.8	7.7	(35)
(36)			MCDBR	12.2	15.6	21.6	24.1	23.4	24.7	26.2	25.1	22.1	17.1	12.9	11.6	(36)
(37)			MCWBR	9.4	11.0	12.2	11.9	11.2	10.4	9.2	9.2	9.8	9.8	8.9	9.2	(37)
(38)		5% WB	MCDBR	11.9	15.1	19.7	22.0	21.7	22.3	23.5	22.2	19.5	15.2	11.7	11.0	(38)
(39)			MCWBR	9.4	11.0	12.1	11.4	11.3	10.4	9.2	9.1	9.5	9.5	8.6	9.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.306	0.328	0.367	0.411	0.411	0.414	0.423	0.420	0.391	0.363	0.338	0.305	(40)	
(41)		taud	2.372	2.349	2.287	2.200	2.237	2.263	2.241	2.265	2.315	2.367	2.389	2.407	(41)	
(42)		Ebn at Noon	238	259	266	265	270	269	265	259	255	242	222	223	(42)	
(43)		Edh at Noon	22	28	35	42	42	41	42	39	34	27	21	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	294	560	910	1376	1618	1761	1687	1507	1073	639	319	229	(44)	
(45)		RadStd	45	74	132	158	186	146	170	146	141	83	34	25	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.97	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+77
(47)	Regional (83 neighbors)	+0.97	N/A	N/A	N/A	+0.72	+0.59	-221	-292	+137	+59

Nomenclature: See separate page