

PRADED, Czech Republic

WMO: 117350

Lat: 50.0829N

Lon: 17.2299E

Elev: 1492

StdP: 84.64

Time Zone: 1.00 (EUC)

Period: 86-97

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-18.1	-15.7	-22.7	0.6	-13.2	-20.1	0.8	-12.5	25.0	-5.6	22.1	-4.1	9.2	100	0.988

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.4	19.2	13.3	17.6	12.6	16.0	12.0	14.4	17.4	13.6	16.3	12.7	15.1	4.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.3	11.4	15.3	12.4	10.8	14.5	11.6	10.2	13.7	45.4	17.9	42.9	16.3	40.4	15.1	18.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.2	17.9	15.9	DB	-20.1	21.6	4.6	1.2	-23.5	22.5	-26.2	23.2	-28.8	23.8	-32.1	24.7	(4)
(5)			WB	-20.5	16.3	4.5	1.0	-23.7	17.1	-26.3	17.7	-28.8	18.3	-32.1	19.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	1.6	-5.8	-6.1	-4.4	-0.2	5.4	8.0	10.4	10.5	5.9	2.6	-2.7	-5.5	
	DBStd	7.47	4.57	5.08	4.62	4.71	4.05	3.72	3.63	3.93	3.54	4.50	3.94	4.31	
	HDD10.0	3231	489	451	445	305	149	82	41	44	131	231	382	481	
	HDD18.3	6122	748	684	703	555	400	309	247	244	373	488	632	739	
	CDD10.0	150	0	0	0	0	7	23	52	58	7	2	0	0	
	CDD18.3	1	0	0	0	0	0	0	1	1	0	0	0	0	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	7.7	9.1	8.7	8.6	7.3	6.7	6.4	6.1	6.2	7.6	8.4	8.3	9.0	
Precipitation	PrecAvg	879	60	53	64	55	83	101	119	86	79	59	60	60	
	PrecMax	1214	128	112	151	90	216	183	506	199	180	164	99	114	
	PrecMin	595	25	12	23	6	34	37	32	23	18	8	0	17	
	PrecStd	125	28	25	29	22	38	36	90	41	45	36	23	26	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.2	6.3	7.0	12.6	16.5	20.0	21.8	21.9	15.9	14.7	6.8	5.5	
		MCWB	-0.1	1.4	3.6	6.9	11.0	14.8	13.8	13.8	11.9	7.6	3.0	-0.5	
	2%	DB	2.2	4.2	4.8	10.4	14.1	17.2	19.1	19.3	13.5	11.7	5.0	3.2	
		MCWB	-0.4	0.1	1.9	5.6	9.4	13.1	13.0	13.4	11.1	7.0	3.5	0.5	
	5%	DB	0.9	2.1	3.2	8.5	12.5	15.3	17.4	17.7	12.1	9.7	3.9	1.7	
		MCWB	-0.4	-0.6	1.7	5.0	8.2	11.8	12.3	12.8	10.5	7.2	2.7	-0.2	
	10%	DB	-0.2	0.3	1.7	6.5	11.1	13.7	15.7	16.1	11.1	8.4	2.6	0.3	
		MCWB	-1.2	-0.8	0.7	3.8	7.9	10.9	11.9	12.0	10.0	6.7	1.6	-0.8	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.6	2.6	4.8	8.1	12.0	15.2	15.7	15.3	13.2	10.1	5.1	3.1
			MCDB	2.1	4.9	5.7	10.2	14.9	17.9	18.5	19.0	14.4	11.6	5.5	3.4
2%		WB	0.7	1.2	3.2	6.4	10.8	13.8	14.2	14.3	12.0	8.9	4.2	1.6	
		MCDB	1.3	2.4	3.9	9.4	13.1	16.4	17.0	17.8	12.7	9.9	4.6	2.0	
5%		WB	-0.1	0.2	1.9	5.2	9.6	12.6	13.3	13.5	11.0	8.0	3.2	0.3	
		MCDB	0.7	1.0	2.6	8.0	11.4	14.7	16.0	16.5	11.9	9.1	3.6	0.8	
10%		WB	-1.0	-0.8	0.6	4.1	8.3	11.3	12.4	12.6	10.0	7.1	1.7	-0.9	
		MCDB	-0.2	0.4	1.5	6.3	10.1	13.1	15.0	15.3	11.0	8.2	2.1	0.0	
Mean Daily Temperature Range		5% DB	MDBR	4.2	4.3	4.2	4.7	5.3	5.1	5.6	5.4	4.3	4.2	3.9	4.0
			MCDBR	4.6	6.1	6.1	6.4	7.0	6.6	7.1	7.0	5.7	5.9	5.3	4.7
	MCWBR		3.8	4.4	4.9	3.8	4.2	4.3	4.5	4.1	4.2	4.0	4.4	3.8	
	5% WB	MCDBR	4.3	4.7	5.5	6.0	6.0	6.3	6.2	6.4	5.3	4.7	4.7	4.3	
		MCWBR	4.1	4.1	5.1	4.1	4.3	4.6	4.6	4.4	4.6	4.0	4.3	4.0	
Clear-Sky Solar Irradiance	taub	0.253	0.273	0.303	0.339	0.339	0.339	0.339	0.350	0.345	0.321	0.301	0.282	0.253	
	taud	2.409	2.414	2.410	2.366	2.386	2.400	2.364	2.392	2.453	2.496	2.501	2.458		
	Ebn at Noon	814	883	910	905	918	917	900	889	878	837	773	766		
	Edh at Noon	60	78	94	110	113	113	115	107	90	72	56	50		
All-Sky Solar Radiation	RadAvg	0.84	1.59	2.66	4.15	5.01	5.33	5.07	4.55	3.22	1.87	0.92	0.63		
	RadStd	0.15	0.23	0.44	0.52	0.60	0.50	0.57	0.42	0.47	0.28	0.12	0.07		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (44 neighbors)	+0.50	N/A	N/A	+0.76	+0.36	+0.31	N/A	-152	+65	+27

Nomenclature: See separate page