

PREROV, Czech Republic

WMO: 117480

Lat: 49.426N

Lon: 17.405E

Elev: 676

StdP: 14.34

Time Zone: 1.00 (EUC)

Period: 96-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 5.0	(c) 10.4	(d) -0.1	(e) 5.6	(f) 6.0	(g) 5.5	(h) 7.5	(i) 12.2	(j) 21.8	(k) 30.5	(l) 19.5	(m) 31.4	(n) 3.7	(o) 60	(p) 0.521

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 19.7	(c) 86.3	(d) 69.5	(e) 83.1	(f) 67.7	(g) 80.2	(h) 66.3	(i) 71.0	(j) 82.9	(k) 69.4	(l) 80.4	(m) 67.7	(n) 77.2	(o) 7.0	(p) 170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.0	101.8	76.0	65.5	96.6	74.2	64.1	91.9	72.8	35.3	82.9	33.8	80.7	32.5	77.4	75.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 19.6	(b) 16.9	(c) 14.6	(e) -0.6	(f) 91.6	(g) 6.9	(h) 2.5	(i) -5.6	(j) 93.4	(k) -9.6	(l) 94.9	(m) -13.5	(n) 96.3	(o) -18.5	(p) 98.1		
(a) 19.6	(b) 16.9	(c) 14.6	(e) -1.0	(f) 74.2	(g) 6.9	(h) 1.0	(i) -6.0	(j) 74.9	(k) -10.1	(l) 75.4	(m) -14.0	(n) 76.0	(o) -19.0	(p) 76.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	48.2	28.4	31.7	38.8	49.0	57.3	63.0	66.4	66.0	57.2	48.5	40.0	30.4	(6)
(7)		DBStd	15.34	9.68	8.92	7.59	7.26	6.31	6.18	5.77	5.28	5.79	7.25	7.90	8.93	(7)
(8)		HDD50	2691	671	512	351	102	12	0	0	0	7	118	310	608	(8)
(9)		HDD65	6396	1136	932	811	482	248	109	52	52	239	513	749	1073	(9)
(10)		CDD50	2015	0	0	4	71	239	391	509	496	224	70	11	0	(10)
(11)		CDD65	247	0	0	0	1	10	50	96	83	6	1	0	0	(11)
(12)		CDH74	2627	0	0	0	23	168	503	1004	831	96	2	0	0	(12)
(13)		CDH80	687	0	0	0	2	20	117	324	214	10	0	0	0	(13)
(14)	Wind	WSAvg	5.8	5.9	6.8	7.2	6.8	5.7	4.9	5.1	4.9	5.2	5.4	5.7	5.9	(14)
(15)	Precipitation	PrecAvg	23.3	1.1	1.0	1.4	1.5	2.6	3.1	3.1	2.6	2.3	1.6	1.6	1.4	(15)
(16)		PrecMax	32.8	2.0	2.4	3.1	3.1	7.9	5.6	9.7	5.1	5.5	4.1	3.8	2.7	(16)
(17)		PrecMin	16.8	0.2	0.1	0.2	0.2	0.9	0.7	0.2	0.9	0.5	0.1	0.0	0.5	(17)
(18)		PrecStd	3.3	0.5	0.6	0.8	0.8	1.3	1.3	1.9	1.1	1.3	0.9	0.8	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.0	54.9	64.9	77.4	82.6	87.4	91.3	90.7	81.5	72.1	63.0	52.9	(19)
(20)			MCWB	48.2	48.0	51.2	59.4	64.4	71.0	70.0	70.5	64.7	62.5	55.5	49.5	(20)
(21)		2%	DB	47.8	50.2	60.1	71.7	78.7	83.7	87.2	85.1	76.6	67.2	58.6	47.2	(21)
(22)			MCWB	44.6	45.6	49.7	56.5	63.7	69.0	69.7	68.7	63.3	59.0	53.0	44.6	(22)
(23)		5%	DB	43.6	47.1	55.8	67.1	75.0	80.0	83.7	81.8	73.2	63.7	54.9	44.0	(23)
(24)			MCWB	40.9	43.4	47.1	54.2	61.9	66.8	68.3	67.0	61.6	57.3	50.5	41.8	(24)
(25)		10%	DB	40.2	43.9	51.6	63.4	71.2	76.4	79.8	78.8	69.6	60.0	51.8	41.5	(25)
(26)			MCWB	38.2	40.7	45.2	52.1	60.0	65.3	66.7	65.9	60.0	55.4	48.8	39.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.7	48.6	52.9	60.6	67.9	73.0	72.8	72.5	67.1	63.2	55.9	49.8	(27)
(28)			MCD B	51.6	53.4	61.9	74.0	79.2	84.3	86.2	84.9	77.2	69.6	61.7	53.1	(28)
(29)		2%	WB	44.8	46.0	50.3	57.7	65.0	70.4	71.1	70.2	64.5	60.3	53.4	45.0	(29)
(30)			MCD B	47.4	49.4	58.1	69.6	75.1	80.7	83.7	82.1	73.4	65.6	57.7	46.8	(30)
(31)		5%	WB	41.0	43.7	48.0	55.3	62.9	68.2	69.6	68.5	62.9	57.8	51.1	42.1	(31)
(32)			MCD B	43.5	46.9	54.6	65.3	72.8	77.6	81.3	78.8	71.2	62.3	54.4	43.7	(32)
(33)		10%	WB	38.3	41.0	45.7	53.2	61.0	66.2	67.7	66.9	61.1	55.7	48.9	39.9	(33)
(34)			MCD B	40.2	43.6	50.8	61.7	69.7	74.5	77.1	76.1	68.4	59.7	51.5	41.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.4	11.8	16.1	20.3	20.1	19.2	19.7	20.7	18.3	15.0	10.8	8.9	(35)
(36)			MCDBR	11.1	15.8	25.4	27.2	27.1	25.6	26.7	26.6	25.7	20.2	15.6	10.5	(36)
(37)			MCWBR	8.8	11.7	15.7	14.5	14.1	12.8	11.3	11.8	13.2	12.8	10.8	8.3	(37)
(38)		5% WB	MCD BR	10.9	15.0	22.6	24.8	23.5	23.3	23.8	23.5	22.4	17.7	13.8	9.8	(38)
(39)			MCWBR	8.9	11.5	14.7	13.7	12.9	12.3	11.4	11.2	12.3	11.7	10.0	7.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.314	0.339	0.379	0.428	0.426	0.426	0.439	0.433	0.403	0.375	0.350	0.313	(40)	
(41)		taud	2.305	2.286	2.240	2.155	2.204	2.241	2.211	2.240	2.291	2.340	2.351	2.357	(41)	
(42)		Ebn at Noon	229	252	260	259	265	265	259	255	250	235	213	213	(42)	
(43)		Edh at Noon	23	29	36	44	43	42	43	40	34	28	22	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	274	526	881	1351	1607	1732	1655	1484	1049	606	295	209	(44)	
(45)		RadStd	46	69	149	155	194	152	173	138	148	90	33	20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (62 neighbors)		+0.99	N/A	N/A	+1.48	+0.77	+0.67	-230	-297	+133	+54

Nomenclature: See separate page