

PREROV, Czech Republic

WMO: 117480

Lat: 49.426N

Lon: 17.405E

Elev: 206

StdP: 98.87

Time Zone: 1.00 (EUC)

Period: 96-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -15.0	(c) -12.0	(d) -17.9	(e) 0.8	(f) -14.4	(g) -14.7	(h) 1.1	(i) -11.0	(j) 9.7	(k) -0.8	(l) 8.7	(m) -0.3	(n) 1.6	(o) 60	(p) 0.521

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 10.9	(c) 30.2	(d) 20.8	(e) 28.4	(f) 19.9	(g) 26.8	(h) 19.0	(i) 21.7	(j) 28.3	(k) 20.8	(l) 26.9	(m) 19.9	(n) 25.1	(o) 3.1	(p) 170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.4	14.5	24.5	18.6	13.8	23.4	17.8	13.1	22.7	64.1	28.3	60.8	27.1	57.6	25.2	24.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.8	7.5	6.5	-18.1	33.1	3.8	1.4	-20.9	34.1	-23.1	34.9	-25.3	35.7	-28.1	36.7
			-18.4	23.4	3.8	0.5	-21.1	23.8	-23.4	24.1	-25.5	24.4	-28.3	24.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.0	-2.0	-0.2	3.8	9.4	14.1	17.2	19.1	18.9	14.0	9.1	4.5	-0.9
	DBStd	8.52	5.38	4.96	4.22	4.04	3.51	3.43	3.20	2.94	3.21	4.03	4.39	4.96
	HDD10.0	1495	373	284	195	57	7	0	0	0	4	66	172	338
	HDD18.3	3553	631	518	451	268	138	61	29	29	133	285	416	596
	CDD10.0	1119	0	0	2	39	133	217	283	276	124	39	6	0
	CDD18.3	137	0	0	0	1	6	28	53	46	3	1	0	0
	CDH23.3	1459	0	0	0	13	93	279	558	462	53	1	0	0
	CDH26.7	382	0	0	0	1	11	65	180	119	6	0	0	0
Wind	WSAvg	2.6	2.7	3.0	3.2	3.0	2.6	2.2	2.3	2.2	2.3	2.4	2.5	2.6
Precipitation	PrecAvg	592	28	26	36	38	67	78	78	66	59	40	41	35
	PrecMax	833	52	62	80	79	200	142	247	129	140	105	97	68
	PrecMin	426	5	3	6	4	22	17	6	24	13	2	1	12
	PrecStd	84	12	15	21	20	34	32	47	28	33	24	21	15
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	12.7	18.3	25.2	28.1	30.8	33.0	32.6	27.5	22.3	17.2	11.6
		MCWB	9.0	8.9	10.7	15.2	18.0	21.6	21.1	21.4	18.2	16.9	13.0	9.7
	2%	DB	8.8	10.1	15.6	22.0	25.9	28.7	30.7	29.5	24.8	19.5	14.8	8.4
		MCWB	7.0	7.6	9.8	13.6	17.6	20.6	20.9	20.4	17.4	15.0	11.7	7.0
	5%	DB	6.5	8.4	13.2	19.5	23.9	26.7	28.7	27.7	22.9	17.6	12.7	6.7
		MCWB	4.9	6.3	8.4	12.4	16.6	19.3	20.2	19.5	16.5	14.0	10.3	5.4
	10%	DB	4.6	6.6	10.9	17.4	21.8	24.6	26.6	26.0	20.9	15.5	11.0	5.3
		MCWB	3.4	4.8	7.3	11.2	15.6	18.5	19.3	18.9	15.5	13.0	9.3	4.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.3	9.2	11.6	15.9	19.9	22.8	22.7	22.5	19.5	17.3	13.3	9.9
		MCDB	10.9	11.9	16.6	23.4	26.2	29.1	30.1	29.4	25.1	20.9	16.5	11.7
	2%	WB	7.1	7.8	10.1	14.3	18.3	21.3	21.7	21.2	18.1	15.7	11.9	7.2
		MCDB	8.6	9.7	14.5	20.9	24.0	27.1	28.7	27.8	23.0	18.7	14.3	8.2
	5%	WB	5.0	6.5	8.9	12.9	17.2	20.1	20.9	20.3	17.1	14.3	10.6	5.6
		MCDB	6.4	8.3	12.6	18.5	22.7	25.4	27.4	26.0	21.8	16.9	12.4	6.5
	10%	WB	3.5	5.0	7.6	11.8	16.1	19.0	19.9	19.4	16.2	13.2	9.4	4.4
		MCDB	4.5	6.5	10.5	16.5	20.9	23.6	25.1	24.5	20.2	15.4	10.8	5.2
Mean Daily Temperature Range	5% DB	MDBR	5.2	6.6	8.9	11.3	11.2	10.7	10.9	11.5	10.2	8.3	6.0	5.0
		MCDBR	6.2	8.8	14.1	15.1	15.1	14.2	14.8	14.8	14.3	11.2	8.7	5.8
		MCWBR	4.9	6.5	8.7	8.1	7.8	7.1	6.3	6.6	7.4	7.1	6.0	4.6
	5% WB	MCDBR	6.1	8.3	12.6	13.8	13.1	12.9	13.2	13.1	12.5	9.8	7.7	5.4
		MCWBR	5.0	6.4	8.2	7.6	7.2	6.9	6.3	6.2	6.8	6.5	5.5	4.4
Clear-Sky Solar Irradiance	taub	0.314	0.339	0.379	0.428	0.426	0.426	0.439	0.433	0.403	0.375	0.350	0.313	
	taud	2.305	2.286	2.240	2.155	2.204	2.241	2.211	2.240	2.291	2.340	2.351	2.357	
	Ebn at Noon	722	793	820	815	834	836	817	803	787	742	672	672	
	Edh at Noon	71	92	114	138	137	133	135	126	108	87	69	60	
All-Sky Solar Radiation	RadAvg	0.86	1.66	2.78	4.26	5.07	5.46	5.22	4.68	3.31	1.91	0.93	0.66	
	RadStd	0.14	0.22	0.47	0.49	0.61	0.48	0.55	0.43	0.47	0.28	0.10	0.06	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (62 neighbors)		+0.55	N/A	N/A	+0.82	+0.43	+0.37	-128	-165	+74	+30

Nomenclature: See separate page