

CERVENA, Czech Republic

WMO: 117660

Lat: 49.7772N

Lon: 17.5419E

Elev: 2471

StdP: 13.43

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.6	10.4	1.3	6.4	8.5	5.9	8.1	12.7	25.4	26.5	23.4	26.3	11.1	30	0.620

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.1	80.4	64.4	77.0	63.0	74.0	61.7	66.1	76.2	64.5	74.3	63.0	72.0	8.8	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.5	92.8	70.2	60.9	87.7	68.3	59.4	82.9	66.7	32.2	76.4	30.9	74.4	29.8	72.2	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.9	19.6	17.7	DB	2.4	84.9	6.4	2.6	-2.2	86.8	-5.9	88.3	-9.5	89.8	-14.2	91.7	(4)
			WB	1.8	69.4	6.4	2.4	-2.7	71.2	-6.5	72.6	-10.1	73.9	-14.7	75.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.3	25.2	27.8	34.3	44.7	52.9	58.9	62.7	62.4	53.6	44.7	36.1	27.3
	DBStd	15.37	7.89	8.70	8.23	8.65	7.39	6.96	6.68	6.54	7.00	7.86	7.99	7.58
	HDD50	3512	768	621	489	201	55	8	1	2	42	203	419	703
	HDD65	7687	1233	1041	952	609	379	206	127	129	346	630	867	1168
	CDD50	1431	0	0	1	41	145	275	393	386	150	38	2	0
	CDD65	134	0	0	0	0	4	23	55	48	4	0	0	0
	CDH74	664	0	0	0	0	14	112	298	232	8	0	0	0
	CDH80	102	0	0	0	0	0	11	51	40	0	0	0	0
Wind	WSAvg	9.1	10.9	10.2	9.5	8.7	8.2	7.5	7.5	7.2	8.0	9.4	10.5	11.3
Precipitation	PrecAvg	26.6	1.4	1.3	1.7	1.8	2.9	3.3	3.7	2.8	2.5	1.9	1.8	1.5
	PrecMax	38.1	2.8	3.4	4.0	3.7	7.7	5.3	13.1	5.4	5.8	4.3	3.7	3.3
	PrecMin	17.5	0.4	0.3	0.5	0.2	1.1	0.7	0.5	1.0	0.5	0.2	0.0	0.4
	PrecStd	3.9	0.7	0.7	0.9	0.8	1.3	1.2	2.5	1.1	1.5	1.1	0.8	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.9	47.7	57.9	70.4	75.8	81.7	85.0	84.4	74.6	65.4	55.7	46.1
		MCWB	41.5	41.5	46.1	54.6	60.2	65.6	64.0	64.9	61.3	56.0	49.9	43.9
	2%	DB	40.7	43.7	53.0	65.2	71.8	77.4	80.9	79.6	70.1	61.3	52.2	42.5
		MCWB	39.2	39.9	44.0	52.0	58.8	63.8	64.5	63.8	59.0	54.3	48.5	41.1
	5%	DB	37.6	41.2	48.7	60.9	68.1	73.7	77.3	76.1	67.0	58.2	49.5	39.2
		MCWB	36.5	38.5	42.1	49.7	56.7	61.9	63.0	62.9	57.4	52.9	46.4	38.3
	10%	DB	35.2	38.5	45.3	57.2	64.5	70.4	73.9	73.0	63.8	55.4	46.6	36.8
		MCWB	34.5	36.3	40.4	47.9	55.1	60.4	61.5	61.6	56.1	51.9	44.5	36.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.7	43.6	47.6	55.6	62.6	68.2	68.0	67.9	63.5	57.5	51.4	44.4
		MCDB	43.4	45.9	54.1	67.3	72.9	77.6	79.1	77.3	71.5	62.5	54.3	45.7
	2%	WB	39.5	41.0	45.2	53.0	59.9	65.4	66.0	65.5	60.6	55.6	49.3	41.3
		MCDB	40.2	42.9	50.6	63.0	68.8	74.1	76.3	76.0	67.0	59.1	51.8	42.4
	5%	WB	36.7	38.9	43.1	50.8	57.9	63.4	64.4	64.0	58.7	53.9	46.7	38.5
		MCDB	37.5	40.6	47.6	59.0	66.3	71.9	74.6	73.6	64.4	57.2	48.8	39.1
	10%	WB	34.6	36.6	41.0	48.8	55.8	61.3	62.8	62.4	57.1	52.0	44.7	36.3
		MCDB	35.2	38.2	44.6	55.8	63.2	69.0	71.8	71.1	62.6	55.3	46.3	36.9
Mean Daily Temperature Range	5% DB	MDBR	6.9	8.2	10.5	13.3	13.8	13.9	14.1	13.9	11.3	9.2	7.2	6.5
		MCDBR	8.4	10.8	14.7	16.8	17.2	17.4	17.9	17.5	14.9	12.4	9.7	8.2
		MCWBR	7.4	8.0	8.8	8.9	8.9	9.0	8.0	7.7	7.8	7.0	6.7	7.1
	5% WB	MCDBR	7.6	9.6	13.4	15.9	16.2	16.6	17.0	16.2	13.3	11.1	8.8	7.7
		MCWBR	7.0	7.9	8.9	8.7	9.0	9.4	8.5	7.9	7.9	6.7	6.8	7.0
Clear-Sky Solar Irradiance	taub	0.288	0.310	0.346	0.390	0.387	0.388	0.400	0.393	0.366	0.342	0.319	0.286	
	taud	2.350	2.340	2.314	2.244	2.282	2.306	2.274	2.304	2.362	2.410	2.418	2.404	
	Ebn at Noon	241	263	272	271	276	276	270	266	262	248	227	226	
	Edh at Noon	21	27	33	40	40	39	40	37	32	25	20	17	
All-Sky Solar Radiation	RadAvg	270	515	861	1330	1594	1705	1627	1461	1032	599	292	205	
	RadStd	47	71	145	160	193	155	177	135	149	90	35	21	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.88	N/A	N/A	N/A	N/A	N/A	-320	-347	N/A	+34
Regional (52 neighbors)		+0.94	N/A	N/A	+1.39	+0.72	+0.65	-218	-279	+122	+49

Nomenclature: See separate page