

CERVENA, Czech Republic

WMO: 117660

Lat: 49.7772N

Lon: 17.5419E

Elev: 753

StdP: 92.60

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.7	-12.0	-17.0	0.9	-13.1	-14.5	1.2	-10.7	11.3	-3.1	10.4	-3.1	4.9	30	0.620

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.8	26.9	18.0	25.0	17.2	23.4	16.5	18.9	24.5	18.1	23.5	17.2	22.2	3.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.0	13.3	21.2	16.1	12.5	20.1	15.2	11.8	19.3	57.0	24.7	54.1	23.6	51.4	22.3	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min		Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.8	8.8	7.9	DB	-16.4	29.4	3.6	1.5	-19.0	30.4	-21.1	31.3	-23.1	32.1	-25.7	33.2
			WB	-16.7	20.8	3.5	1.3	-19.3	21.8	-21.4	22.5	-23.4	23.3	-25.9	24.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.8	-3.8	-2.3	1.3	7.1	11.6	14.9	17.0	16.9	12.0	7.1	2.3	-2.6
	DBStd	8.54	4.38	4.83	4.57	4.81	4.11	3.87	3.71	3.64	3.89	4.37	4.44	4.21
	HDD10.0	1951	427	345	272	112	31	4	1	1	23	113	233	391
	HDD18.3	4271	685	578	529	338	211	114	71	72	192	350	482	649
	CDD10.0	795	0	0	1	23	81	153	218	214	83	21	1	0
	CDD18.3	74	0	0	0	0	2	13	31	27	2	0	0	0
	CDH23.3	369	0	0	0	0	8	62	166	129	4	0	0	0
	CDH26.7	57	0	0	0	0	0	6	28	22	0	0	0	0
Wind	WSAvg	4.1	4.9	4.6	4.3	3.9	3.6	3.4	3.3	3.2	3.6	4.2	4.7	5.1
Precipitation	PrecAvg	676	36	34	43	45	74	84	94	71	63	47	45	38
	PrecMax	967	72	86	101	93	196	135	333	138	148	110	93	83
	PrecMin	444	10	7	12	6	27	18	12	25	13	6	1	11
	PrecStd	99	17	18	23	21	34	30	63	29	37	29	21	19
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.6	8.7	14.4	21.3	24.4	27.6	29.4	29.1	23.7	18.6	13.2	7.8
		MCWB	5.3	5.3	7.8	12.6	15.7	18.7	17.8	18.3	16.3	13.3	9.9	6.6
	2%	DB	4.8	6.5	11.6	18.5	22.1	25.2	27.2	26.5	21.1	16.3	11.2	5.8
		MCWB	4.0	4.4	6.6	11.1	14.9	17.7	18.0	17.7	15.0	12.4	9.2	5.0
	5%	DB	3.1	5.1	9.3	16.0	20.1	23.2	25.2	24.5	19.4	14.5	9.7	4.0
		MCWB	2.5	3.6	5.6	9.8	13.7	16.6	17.2	17.2	14.1	11.6	8.0	3.5
	10%	DB	1.8	3.6	7.4	14.0	18.0	21.3	23.3	22.8	17.7	13.0	8.1	2.7
		MCWB	1.4	2.4	4.7	8.8	12.8	15.8	16.4	16.4	13.4	11.1	7.0	2.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.9	6.4	8.7	13.1	17.0	20.1	20.0	20.0	17.5	14.2	10.8	6.9
		MCDB	6.3	7.7	12.3	19.6	22.7	25.3	26.1	25.1	21.9	17.0	12.4	7.6
	2%	WB	4.1	5.0	7.3	11.7	15.5	18.5	18.9	18.6	15.9	13.1	9.6	5.2
		MCDB	4.5	6.0	10.3	17.2	20.5	23.4	24.6	24.5	19.4	15.0	11.0	5.8
	5%	WB	2.6	3.8	6.2	10.5	14.4	17.4	18.0	17.8	14.9	12.2	8.2	3.6
		MCDB	3.1	4.8	8.7	15.0	19.0	22.2	23.7	23.1	18.0	14.0	9.3	4.0
	10%	WB	1.4	2.6	5.0	9.3	13.2	16.3	17.1	16.9	14.0	11.1	7.1	2.4
		MCDB	1.8	3.4	7.0	13.2	17.3	20.6	22.1	21.7	17.0	12.9	8.0	2.7
Mean Daily Temperature Range	5% DB	MDBR	3.9	4.5	5.8	7.4	7.6	7.7	7.8	7.7	6.3	5.1	4.0	3.6
		MCDBR	4.7	6.0	8.2	9.4	9.5	9.6	10.0	9.7	8.3	6.9	5.4	4.5
		MCWBR	4.1	4.4	4.9	4.9	4.9	5.0	4.5	4.3	4.3	3.9	3.7	3.9
	5% WB	MCDBR	4.2	5.3	7.4	8.8	9.0	9.2	9.4	9.0	7.4	6.2	4.9	4.3
		MCWBR	3.9	4.4	4.9	4.9	5.0	5.2	4.7	4.4	4.4	3.7	3.8	3.9
Clear-Sky Solar Irradiance	taub	0.288	0.310	0.346	0.390	0.387	0.388	0.400	0.393	0.366	0.342	0.319	0.286	
	taud	2.350	2.340	2.314	2.244	2.282	2.306	2.274	2.304	2.362	2.410	2.418	2.404	
	Ebn at Noon	759	830	858	853	870	871	852	840	826	783	715	712	
	Edh at Noon	66	86	105	126	126	124	126	117	100	80	63	55	
All-Sky Solar Radiation	RadAvg	0.85	1.62	2.71	4.19	5.03	5.38	5.13	4.61	3.25	1.89	0.92	0.65	
	RadStd	0.15	0.23	0.46	0.51	0.61	0.49	0.56	0.42	0.47	0.28	0.11	0.07	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.49	N/A	N/A	N/A	N/A	N/A	-178	-193	N/A	+19
(47) Regional (52 neighbors)		+0.52	N/A	N/A	+0.77	+0.40	+0.36	-121	-155	+68	+27

Nomenclature: See separate page