

OSTRAVA MOSNOV, Czech Republic

WMO: 117820

Lat: 49.6919N

Lon: 18.1128E

Elev: 845

StdP: 14.25

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.8	11.3	1.0	6.0	6.8	6.4	7.9	12.1	27.0	34.4	24.8	32.6	5.5	20	0.557

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.9	87.4	68.6	83.8	67.4	80.7	65.9	70.2	82.9	68.8	80.8	67.2	78.1	9.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.3	99.9	74.4	64.7	94.5	73.0	63.3	89.8	71.8	34.7	83.1	33.4	81.1	32.1	78.4	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.6	20.0	17.9	DB	-0.5	92.2	7.1	3.2	-5.6	94.5	-9.7	96.3	-13.7	98.1	-18.8	100.4	(4)
			WB	-1.0	73.5	7.0	1.6	-6.1	74.6	-10.2	75.6	-14.2	76.5	-19.3	77.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.6	29.4	32.3	39.0	48.7	56.8	63.3	66.8	66.1	57.6	49.2	40.8	32.0
	DBStd	15.09	9.40	9.20	7.94	7.58	6.38	6.16	5.63	5.67	6.02	7.28	8.04	8.68
	HDD50	2570	639	495	348	110	14	0	0	0	8	106	291	559
	HDD65	6254	1104	914	807	490	262	104	46	54	232	491	727	1023
	CDD50	2057	0	0	6	72	225	400	522	501	236	80	14	1
	CDD65	266	0	0	0	1	9	54	103	89	9	1	0	0
	CDH74	2872	0	0	0	26	161	585	1066	912	119	3	0	0
	CDH80	828	0	0	0	2	19	159	353	275	20	0	0	0
Wind	WSAvg	7.8	10.0	9.2	8.7	7.4	6.8	6.5	6.5	6.0	6.6	7.6	8.7	10.2
Precipitation	PrecAvg	31.4	1.6	1.6	1.9	2.2	3.6	3.8	4.4	3.1	3.1	2.2	2.1	1.7
	PrecMax	43.4	3.2	3.5	4.3	4.5	12.2	7.4	17.8	6.4	8.0	4.8	4.0	4.2
	PrecMin	20.7	0.5	0.4	0.7	0.4	1.3	1.1	0.9	0.6	0.8	0.2	0.0	0.6
	PrecStd	5.0	0.6	0.7	1.0	1.1	2.1	1.4	3.3	1.5	1.7	1.3	0.9	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.7	55.2	65.5	77.7	82.3	89.4	91.8	92.2	82.9	73.0	64.3	56.2
		MCWB	46.6	47.2	51.4	59.2	64.9	69.6	69.0	69.2	65.4	61.5	54.7	49.1
	2%	DB	47.5	51.2	60.1	72.2	78.6	84.7	87.7	86.5	77.2	68.7	60.0	49.2
		MCWB	43.7	44.9	48.7	56.9	63.3	68.3	68.8	68.1	63.2	58.6	52.3	44.9
	5%	DB	44.2	48.2	55.8	67.3	74.8	80.6	84.0	82.6	73.7	64.9	56.5	45.6
		MCWB	40.7	43.5	46.9	54.2	61.2	66.3	67.7	67.4	61.8	57.0	50.4	42.5
	10%	DB	41.2	44.6	51.5	63.3	70.7	76.8	80.3	79.1	69.8	60.7	52.5	42.6
		MCWB	38.6	40.9	44.8	52.0	59.4	64.4	66.0	65.6	60.0	55.0	48.2	40.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.3	48.2	52.5	60.4	67.1	72.5	72.7	71.8	67.2	62.5	55.3	49.3
		MCDB	50.7	53.9	62.8	74.6	79.5	85.1	86.2	84.1	79.4	70.3	62.8	55.0
	2%	WB	44.0	45.8	49.9	57.8	64.5	69.7	70.2	69.7	64.7	59.7	53.1	45.3
		MCDB	47.1	50.2	58.0	70.2	75.2	81.5	82.9	82.8	73.5	66.5	59.1	48.7
	5%	WB	41.1	43.6	47.7	55.3	62.5	67.5	68.7	68.2	62.8	57.6	50.9	42.6
		MCDB	43.7	47.7	54.4	65.8	72.5	77.9	80.7	80.5	71.4	63.7	55.5	45.2
	10%	WB	38.7	41.1	45.4	53.0	60.3	65.5	67.2	66.6	61.0	55.5	48.6	40.3
		MCDB	40.9	44.3	50.8	61.4	69.0	74.7	77.8	76.7	68.3	60.3	52.3	42.4
Mean Daily Temperature Range	5% DB	MDBR	9.2	11.5	15.0	19.2	19.6	19.2	19.9	20.5	17.5	14.8	10.8	8.8
		MCDBR	11.1	15.7	23.6	27.5	27.4	26.2	27.6	26.7	25.0	21.4	17.2	12.2
		MCWBR	8.7	11.0	14.3	14.7	13.8	12.1	11.3	11.3	12.6	13.0	11.1	9.1
	5% WB	MCDBR	10.6	14.2	20.7	25.2	24.4	23.2	24.1	24.0	21.6	19.3	15.1	11.6
		MCWBR	8.6	10.4	13.2	14.0	13.1	11.7	10.8	10.8	11.6	12.3	10.3	9.1
Clear-Sky Solar Irradiance	taub	0.313	0.339	0.381	0.434	0.430	0.430	0.444	0.436	0.405	0.374	0.346	0.310	
	taud	2.286	2.263	2.222	2.137	2.193	2.230	2.200	2.231	2.284	2.342	2.354	2.350	
	Ebn at Noon	227	250	259	257	264	264	258	253	248	235	213	213	
	Edh at Noon	23	30	37	44	44	43	43	40	34	27	22	19	
All-Sky Solar Radiation	RadAvg	275	513	861	1298	1554	1662	1599	1443	1019	607	303	213	
	RadStd	48	76	142	157	196	164	185	134	152	89	41	24	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.35	N/A	N/A	+2.05	+1.24	+1.19	-281	-409	+194	+88
(47)	Regional (47 neighbors)	+0.97	N/A	N/A	+1.44	+0.76	+0.65	-223	-293	+135	+56

Nomenclature: See separate page