

LYSA HORA, Czech Republic

WMO: 117870

Lat: 49.5461N

Lon: 18.4475E

Elev: 4353

StdP: 12.53

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.0	6.8	-9.1	3.9	13.2	-2.4	5.7	12.7	50.5	23.6	46.1	23.4	18.0	20	0.856

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.5	73.8	61.1	70.6	59.7	67.6	58.1	62.6	70.7	60.9	68.6	59.2	66.2	8.1	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.6	89.5	66.1	57.8	84.1	64.4	56.2	79.2	62.6	30.5	70.8	29.2	68.7	27.9	66.2	69.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
42.5	37.0	32.3	DB	-2.6	79.4	5.9	2.5	-6.8	81.2	-10.2	82.7	-13.5	84.1	-17.8	85.9	(4)
			WB	-3.3	66.6	5.7	1.7	-7.3	67.8	-10.7	68.8	-13.8	69.8	-17.9	71.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	39.3	22.4	23.1	28.0	38.6	47.1	53.1	56.6	56.5	47.9	40.2	31.8	24.8
	DBStd	14.81	8.08	8.43	8.27	9.03	8.15	7.63	7.10	6.99	7.39	8.54	8.24	8.07
	HDD50	4666	857	752	681	354	155	54	20	20	126	319	546	782
	HDD65	9425	1322	1172	1146	793	556	364	274	274	513	768	996	1247
	CDD50	747	0	0	0	11	65	145	224	223	64	15	0	0
	CDD65	30	0	0	0	0	0	5	13	12	0	0	0	0
	CDH74	84	0	0	0	0	2	15	37	29	1	0	0	0
	CDH80	3	0	0	0	0	0	0	2	1	0	0	0	0
Wind	WSAvg	15.3	18.3	17.7	16.1	14.3	13.1	12.3	12.3	12.0	13.6	16.5	19.0	18.3
Precipitation	PrecAvg	36.5	2.0	2.0	2.4	2.5	4.1	4.3	5.0	3.6	3.6	2.5	2.4	2.1
	PrecMax	51.7	4.5	4.3	5.2	5.2	15.1	8.5	17.8	7.5	8.6	5.8	4.2	5.4
	PrecMin	25.9	0.6	0.6	0.7	0.4	1.4	1.4	1.3	0.8	1.0	0.3	0.0	0.6
	PrecStd	5.8	0.9	0.9	1.1	1.1	2.5	1.6	3.5	1.8	2.0	1.5	1.0	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.7	44.2	50.6	63.8	70.4	76.2	78.5	77.8	68.4	61.7	51.7	43.2
		MCWB	34.1	36.6	40.2	51.1	56.1	61.9	62.0	62.3	57.0	51.9	41.0	35.6
	2%	DB	38.4	39.3	45.2	58.1	65.5	71.8	73.8	73.0	63.7	57.4	47.9	39.9
		MCWB	35.1	33.4	38.2	47.4	54.7	60.2	61.2	61.0	55.7	49.9	43.2	35.4
	5%	DB	35.7	36.2	41.7	53.6	62.1	67.6	70.2	69.6	60.6	53.7	45.1	37.4
		MCWB	33.7	33.8	36.6	45.3	52.9	58.4	59.8	59.7	53.8	48.8	42.0	34.4
	10%	DB	33.1	33.9	38.9	50.0	58.6	64.0	67.1	66.6	57.6	51.0	42.5	35.1
		MCWB	31.6	32.1	35.8	42.8	51.0	56.6	58.2	58.2	52.1	47.3	40.1	33.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.2	38.4	42.0	51.8	58.9	64.3	64.7	64.6	59.2	54.0	46.8	39.9
		MCDB	39.5	40.5	47.4	60.9	67.9	72.5	73.3	73.3	65.2	58.4	48.9	40.7
	2%	WB	36.1	36.0	39.6	48.5	55.8	61.8	62.4	62.2	56.7	51.7	44.8	37.5
		MCDB	37.1	37.5	42.9	56.3	62.9	69.1	70.3	70.7	61.8	54.4	46.4	38.3
	5%	WB	34.1	34.2	37.8	46.0	53.8	59.4	60.7	60.4	54.8	49.8	42.7	35.4
		MCDB	35.4	35.6	40.7	52.0	60.2	65.7	68.5	68.0	59.0	53.0	44.1	36.4
	10%	WB	31.7	32.2	35.9	43.8	51.8	57.3	59.1	58.7	53.0	47.7	40.6	33.3
		MCDB	32.9	33.5	38.7	48.9	57.7	63.3	66.3	65.5	57.0	50.6	41.9	34.3
Mean Daily Temperature Range	5% DB	MDBR	7.5	8.2	9.2	11.3	12.7	12.6	12.5	12.1	10.0	8.8	7.1	7.5
		MCDBR	9.0	10.6	12.6	14.8	16.7	16.9	16.3	15.8	13.8	12.2	8.8	9.1
		MCWBR	7.0	7.9	8.1	8.7	9.8	9.9	9.1	9.0	8.8	7.9	6.6	7.1
	5% WB	MCDBR	8.2	9.1	10.9	13.8	15.3	15.6	15.2	14.9	12.5	11.2	7.9	8.1
		MCWBR	7.2	7.9	7.9	8.3	9.7	9.9	9.2	9.2	8.5	7.9	6.8	7.1
Clear-Sky Solar Irradiance	taub	0.261	0.281	0.313	0.353	0.352	0.354	0.363	0.357	0.335	0.312	0.291	0.261	
	taud	2.380	2.379	2.385	2.351	2.375	2.386	2.356	2.383	2.438	2.495	2.495	2.447	
	Ebn at Noon	256	277	285	283	287	287	282	279	274	263	243	242	
	Edh at Noon	20	26	31	36	36	36	37	34	29	23	18	16	
All-Sky Solar Radiation	RadAvg	281	514	860	1274	1520	1628	1577	1430	1007	613	311	221	
	RadStd	49	79	143	154	199	169	188	135	155	90	45	26	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (46 neighbors)	+0.95	N/A	N/A	+1.42	+0.74	+0.65	-223	-293	+131	+54

Nomenclature: See separate page