

LYSA HORA, Czech Republic

WMO: 117870

Lat: 49.5461N

Lon: 18.4475E

Elev: 1327

StdP: 86.37

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.1	-14.0	-22.9	0.6	-10.4	-19.1	0.8	-10.7	22.6	-4.7	20.6	-4.8	8.0	20	0.856

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.9	23.2	16.1	21.4	15.4	19.8	14.5	17.0	21.5	16.0	20.3	15.1	19.0	3.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.3	12.8	18.9	14.4	12.0	18.0	13.5	11.3	17.0	53.1	21.6	50.0	20.4	47.1	19.0	20.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.0	16.6	14.5	-19.2	26.3	3.3	1.4	-21.6	27.3	-23.5	28.1	-25.3	28.9	-27.6	30.0		
(5)			-19.6	19.2	3.1	1.0	-21.9	19.9	-23.7	20.5	-25.5	21.0	-27.7	21.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.0	-5.4	-4.9	-2.2	3.6	8.4	11.7	13.6	13.6	8.8	4.6	-0.1	-4.0		
	DBStd	8.23	4.49	4.68	4.59	5.02	4.53	4.24	3.94	3.88	4.11	4.75	4.58	4.48		
	HDD10.0	2592	476	418	378	197	86	30	11	11	70	177	303	434		
	HDD18.3	5236	734	651	637	441	309	202	152	152	285	427	553	693		
	CDD10.0	415	0	0	0	6	36	81	124	124	36	8	0	0		
	CDD18.3	17	0	0	0	0	0	3	7	7	0	0	0	0		
	CDH23.3	47	0	0	0	0	1	8	21	16	1	0	0	0		
	CDH26.7	2	0	0	0	0	0	0	1	1	0	0	0	0		
(14) Wind	WSAvg	6.8	8.2	7.9	7.2	6.4	5.9	5.5	5.5	5.4	6.1	7.4	8.5	8.2		
(15) Precipitation	PrecAvg	928	52	50	60	63	103	110	128	92	91	63	62	54		
	PrecMax	1314	115	108	133	132	384	216	453	191	218	147	107	138		
	PrecMin	659	16	14	17	9	35	35	34	20	26	7	1	15		
	PrecStd	148	23	23	29	29	64	41	88	46	51	37	26	26		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.9	6.8	10.4	17.7	21.3	24.6	25.8	25.4	20.2	16.5	10.9	6.2		
		MCWB	1.2	2.5	4.6	10.6	13.4	16.6	16.7	16.8	13.9	11.0	5.0	2.0		
	2%	DB	3.6	4.0	7.3	14.5	18.6	22.1	23.2	22.8	17.6	14.1	8.8	4.4		
		MCWB	1.7	0.8	3.5	8.5	12.6	15.6	16.2	16.1	13.2	9.9	6.2	1.9		
	5%	DB	2.1	2.3	5.4	12.0	16.7	19.8	21.2	20.9	15.9	12.1	7.3	3.0		
		MCWB	0.9	1.0	2.6	7.4	11.6	14.7	15.4	15.4	12.1	9.3	5.5	1.3		
	10%	DB	0.6	1.0	3.9	10.0	14.8	17.8	19.5	19.2	14.2	10.5	5.8	1.7		
		MCWB	-0.2	0.1	2.1	6.0	10.6	13.6	14.5	14.6	11.2	8.5	4.5	0.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.5	3.5	5.6	11.0	14.9	18.0	18.2	18.1	15.1	12.2	8.2	4.4		
		MCDB	4.2	4.7	8.5	16.1	19.9	22.5	22.9	22.9	18.4	14.7	9.4	4.8		
	2%	WB	2.3	2.2	4.2	9.2	13.2	16.6	16.9	16.8	13.7	10.9	7.1	3.0		
		MCDB	2.8	3.0	6.1	13.5	17.2	20.6	21.3	21.5	16.6	12.4	8.0	3.5		
	5%	WB	1.1	1.2	3.2	7.8	12.1	15.2	16.0	15.8	12.7	9.9	5.9	1.9		
		MCDB	1.9	2.0	4.8	11.1	15.7	18.7	20.3	20.0	15.0	11.7	6.7	2.4		
	10%	WB	-0.1	0.1	2.2	6.5	11.0	14.0	15.0	14.9	11.7	8.7	4.8	0.7		
		MCDB	0.5	0.8	3.7	9.4	14.3	17.4	19.0	18.6	13.9	10.4	5.5	1.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.2	4.5	5.1	6.3	7.0	7.0	6.9	6.7	5.6	4.9	4.0	4.1		
		MCDBR	5.0	5.9	7.0	8.2	9.3	9.4	9.1	8.8	7.7	6.8	4.9	5.1		
	5% WB	MCWBR	3.9	4.4	4.5	4.8	5.5	5.5	5.1	5.0	4.9	4.4	3.6	4.0		
		MCWBR	4.5	5.1	6.0	7.7	8.5	8.7	8.4	8.3	7.0	6.2	4.4	4.5		
(40) Clear-Sky Solar Irradiance	taub	taub	0.261	0.281	0.313	0.353	0.352	0.354	0.363	0.357	0.335	0.312	0.291	0.261		
		taud	2.380	2.379	2.385	2.351	2.375	2.386	2.356	2.383	2.438	2.495	2.495	2.447		
	Edn at Noon	Edn at Noon	807	874	899	893	906	904	889	878	865	828	767	762		
		Edh at Noon	63	82	98	113	115	115	117	108	92	73	58	52		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.89	1.62	2.71	4.02	4.79	5.13	4.97	4.51	3.17	1.93	0.98	0.70		
	RadStd	RadStd	0.15	0.25	0.45	0.49	0.63	0.53	0.59	0.43	0.49	0.28	0.14	0.08		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (46 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.53	N/A	N/A	+0.79	+0.41	+0.36	-124	-163	+73	+30

Nomenclature: See separate page