

BRATISLAVA-LETISKO, Slovakia

WMO: 118160

Lat: 48.1703N

Lon: 17.2075E

Elev: 440

StdP: 14.46

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.8	18.3	5.8	7.5	16.3	10.8	9.7	21.8	29.6	43.0	26.0	40.6	6.3	50	0.527

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.2	90.8	69.4	87.5	68.2	84.3	67.0	71.3	85.5	69.8	83.6	68.4	81.3	8.5	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.6	99.4	77.0	64.9	93.8	75.4	63.8	90.1	74.4	35.3	85.6	34.0	83.5	32.9	81.7	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	23.6	20.6	18.1	DB	8.0	95.1	5.9	3.1	3.8	97.4	0.3	99.2	-2.9	100.9	-7.2	103.2
(5)				WB	7.1	74.1	5.7	1.6	3.1	75.2	-0.3	76.2	-3.5	77.1	-7.6	78.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.1	32.0	35.7	43.2	53.0	60.9	67.8	71.3	70.5	61.6	52.0	42.6	33.8
	DBStd	15.46	7.95	8.06	7.28	7.09	6.18	6.11	5.59	5.76	5.97	7.01	7.25	7.49
	HDD50	2048	560	403	230	51	2	0	0	0	1	62	237	502
	HDD65	5283	1024	820	675	363	156	40	12	16	135	405	671	966
	CDD50	2821	1	3	19	140	340	534	660	636	349	122	16	1
	CDD65	584	0	0	0	2	29	124	207	187	34	1	0	0
	CDH74	5416	0	0	0	42	308	1146	1944	1702	265	9	0	0
	CDH80	1844	0	0	0	4	51	362	748	632	47	0	0	0
Wind	WSAvg	8.1	8.4	8.6	9.1	8.7	8.2	7.8	8.0	7.0	7.4	7.1	8.2	8.1
Precipitation	PrecAvg	22.8	1.6	1.5	1.5	1.5	2.2	2.6	2.2	2.3	1.8	1.6	2.1	1.9
	PrecMax	33.7	4.2	4.6	3.5	3.7	6.2	6.5	5.6	7.8	5.8	5.3	5.2	5.4
	PrecMin	15.4	0.1	0.1	0.4	0.2	0.2	0.5	0.5	0.3	0.4	0.1	0.5	0.4
	PrecStd	3.8	1.0	1.0	0.7	0.9	1.3	1.4	1.3	1.4	1.2	1.1	1.2	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.7	59.3	68.1	78.8	84.7	91.7	94.8	95.4	85.1	74.6	65.1	54.9
		MCWB	47.6	48.5	52.4	61.0	65.5	70.3	70.3	69.0	66.2	61.9	56.2	48.5
	2%	DB	50.2	55.0	63.4	73.7	80.7	87.9	90.8	90.8	80.5	70.2	60.1	49.6
		MCWB	44.1	47.1	50.8	57.9	64.6	68.9	69.4	69.2	64.8	60.4	53.5	44.9
	5%	DB	46.2	50.9	59.0	70.0	77.4	84.2	87.6	86.5	76.9	66.5	55.7	45.9
		MCWB	41.7	44.8	48.7	56.1	62.6	67.4	68.2	67.9	63.2	58.2	50.8	42.6
	10%	DB	42.8	47.1	55.2	66.2	73.8	80.7	84.3	82.8	73.3	62.8	52.5	43.2
		MCWB	39.6	42.4	46.8	53.9	60.7	65.9	67.1	66.5	61.6	56.3	48.6	40.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.6	50.2	54.1	61.7	68.2	73.5	73.1	72.9	67.9	63.2	57.2	49.2
		MCDB	54.5	57.6	64.5	75.8	81.4	87.3	88.2	87.7	80.1	71.6	63.6	54.4
	2%	WB	45.0	47.6	51.9	59.1	65.8	70.7	71.1	70.9	66.2	61.1	54.2	45.4
		MCDB	49.3	53.7	61.2	71.8	78.0	83.6	86.0	84.9	77.1	68.7	59.3	48.5
	5%	WB	42.2	45.1	49.7	56.9	63.8	68.7	69.8	69.3	64.6	59.1	51.5	42.9
		MCDB	45.3	49.9	57.6	67.6	74.8	81.2	84.0	83.1	73.9	65.3	55.6	45.4
	10%	WB	39.6	42.7	47.5	55.0	61.9	67.0	68.4	67.8	62.8	56.9	49.2	40.5
		MCDB	42.6	46.8	54.1	64.6	71.9	78.5	81.3	80.6	71.2	61.9	52.0	42.7
Mean Daily Temperature Range	5% DB	MDBR	9.4	12.0	15.4	18.6	18.5	18.8	19.2	19.5	17.1	15.1	10.4	8.5
		MCDBR	13.3	17.7	22.8	25.1	24.6	24.5	25.9	25.6	23.5	19.9	15.4	12.8
		MCWBR	9.5	11.7	13.0	12.7	11.6	9.7	9.3	9.1	10.4	11.3	10.1	9.6
	5% WB	MCDBR	12.7	16.5	21.0	23.2	22.5	22.1	23.1	23.2	20.6	18.8	14.8	11.8
		MCWBR	9.6	11.5	12.7	12.2	11.2	9.4	9.1	9.3	9.9	11.1	10.1	9.4
Clear-Sky Solar Irradiance	taub	0.324	0.347	0.384	0.428	0.424	0.426	0.435	0.435	0.410	0.380	0.356	0.323	
	taud	2.361	2.336	2.258	2.159	2.215	2.247	2.223	2.238	2.278	2.335	2.356	2.383	
	Ebn at Noon	233	254	261	260	266	266	261	255	250	237	217	218	
	Edh at Noon	23	29	36	44	43	42	43	40	35	29	23	20	
All-Sky Solar Radiation	RadAvg	310	568	943	1426	1682	1834	1768	1577	1127	683	352	242	
	RadStd	36	76	124	141	179	136	162	151	137	79	34	28	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.85	N/A	N/A	N/A	+0.94	+0.81	-185	-216	+158	N/A
(47)	Regional (81 neighbors)	+1.04	N/A	N/A	+1.51	+0.85	+0.74	-225	-308	+164	+77

Nomenclature: See separate page