

BRATISLAVA-LETISKO, Slovakia

WMO: 118160

Lat: 48.1703N

Lon: 17.2075E

Elev: 134

StdP: 99.73

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.1	-7.6	-14.5	1.1	-8.7	-11.8	1.4	-5.6	13.2	6.1	11.6	4.8	2.8	50	0.527

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	32.7	20.8	30.9	20.1	29.1	19.4	21.8	29.7	21.0	28.7	20.2	27.4	3.8	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.2	14.2	25.0	18.3	13.4	24.1	17.7	12.9	23.6	64.3	29.8	61.3	28.6	58.6	27.6	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.5	9.2	8.1	DB	-13.3	35.1	3.3	1.7	-15.7	36.3	-17.6	37.3	-19.4	38.3	-21.8	39.5	(4)
(5)			WB	-13.8	23.4	3.2	0.9	-16.1	24.0	-17.9	24.5	-19.7	25.0	-22.0	25.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.2	0.0	2.1	6.2	11.6	16.1	19.9	21.8	21.4	16.5	11.1	5.9	1.0	(6)	
	DBStd	8.59	4.41	4.48	4.05	3.94	3.44	3.39	3.11	3.20	3.32	3.90	4.03	4.16	(7)	
	HDD10.0	1138	311	224	128	28	1	0	0	0	1	34	132	279	(8)	
	HDD18.3	2935	569	456	375	202	87	22	7	9	75	225	373	537	(9)	
	CDD10.0	1567	1	2	11	78	189	297	367	353	194	68	9	1	(10)	
	CDD18.3	324	0	0	0	1	16	69	115	104	19	1	0	0	(11)	
	CDH23.3	3009	0	0	0	23	171	637	1080	946	147	5	0	0	(12)	
	CDH26.7	1024	0	0	0	2	28	201	416	351	26	0	0	0	(13)	
(14) Wind	WSAvg	3.6	3.7	3.8	4.1	3.9	3.7	3.5	3.6	3.1	3.3	3.2	3.7	3.6	(14)	
(15) Precipitation	PrecAvg	578	40	38	38	37	55	66	57	58	46	40	53	49	(15)	
	PrecMax	857	107	118	90	95	158	166	143	197	148	134	131	138	(16)	
	PrecMin	392	3	2	11	6	5	12	12	8	10	2	12	9	(17)	
	PrecStd	96	26	25	19	23	34	36	33	35	31	29	30	26	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	15.2	20.0	26.0	29.3	33.2	34.9	35.2	29.5	23.7	18.4	12.7	(19)	
		MCWB	8.7	9.2	11.4	16.1	18.6	21.3	21.3	20.5	19.0	16.6	13.4	9.2	(20)	
	2%	DB	10.1	12.8	17.4	23.2	27.1	31.0	32.7	32.6	26.9	21.2	15.6	9.8	(21)	
		MCWB	6.7	8.4	10.4	14.4	18.1	20.5	20.8	20.6	18.2	15.8	12.0	7.2	(22)	
	5%	DB	7.9	10.5	15.0	21.1	25.2	29.0	30.9	30.3	25.0	19.2	13.2	7.7	(23)	
		MCWB	5.4	7.1	9.3	13.4	17.0	19.7	20.1	19.9	17.3	14.6	10.4	5.9	(24)	
	10%	DB	6.0	8.4	12.9	19.0	23.2	27.1	29.0	28.2	22.9	17.1	11.4	6.2	(25)	
		MCWB	4.2	5.8	8.2	12.2	16.0	18.8	19.5	19.1	16.5	13.5	9.2	4.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	10.1	12.3	16.5	20.1	23.1	22.8	22.7	20.0	17.4	14.0	9.5	(27)	
		MCDB	12.5	14.2	18.1	24.4	27.4	30.7	31.2	31.0	26.7	22.0	17.6	12.4	(28)	
	2%	WB	7.2	8.7	11.0	15.0	18.8	21.5	21.7	21.6	19.0	16.2	12.4	7.5	(29)	
		MCDB	9.6	12.1	16.2	22.1	25.6	28.7	30.0	29.4	25.1	20.4	15.2	9.1	(30)	
	5%	WB	5.6	7.3	9.9	13.9	17.7	20.4	21.0	20.7	18.1	15.1	10.8	6.0	(31)	
		MCDB	7.4	9.9	14.2	19.8	23.8	27.3	28.9	28.4	23.3	18.5	13.1	7.4	(32)	
	10%	WB	4.2	5.9	8.6	12.8	16.6	19.5	20.2	19.9	17.1	13.9	9.5	4.7	(33)	
		MCDB	5.9	8.2	12.3	18.1	22.2	25.8	27.4	27.0	21.8	16.6	11.1	6.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.2	6.7	8.5	10.3	10.3	10.4	10.6	10.8	9.5	8.4	5.8	4.7	(35)	
		MCDBR	7.4	9.9	12.7	14.0	13.7	13.6	14.4	14.2	13.1	11.1	8.6	7.1	(36)	
	5% WB	MCWBR	5.3	6.5	7.2	7.1	6.5	5.4	5.2	5.0	5.8	6.3	5.6	5.3	(37)	
		MCWBR	7.1	9.2	11.7	12.9	12.5	12.3	12.8	12.9	11.4	10.4	8.2	6.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.324	0.347	0.384	0.428	0.424	0.426	0.435	0.435	0.410	0.380	0.356	0.323	(40)	
		taud	2.361	2.336	2.258	2.159	2.215	2.247	2.223	2.238	2.278	2.335	2.356	2.383	(41)	
	Ebn at Noon		736	800	824	821	840	839	824	805	788	748	685	687	(42)	
		Edh at Noon	71	90	114	139	136	133	134	127	111	90	72	62	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.98	1.79	2.97	4.49	5.30	5.78	5.57	4.97	3.55	2.15	1.11	0.76	(44)	
	RadStd		0.12	0.24	0.39	0.45	0.56	0.43	0.51	0.48	0.43	0.25	0.11	0.09	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.47	N/A	N/A	N/A	+0.52	+0.45	-103	-120	+88	N/A	(46)
(47)	Regional (81 neighbors)	+0.58	N/A	N/A	+0.84	+0.47	+0.41	-125	-171	+91	+43	(47)

Nomenclature: See separate page