

JASLOVSKE BOHUNICE, Slovakia

WMO: 118190

Lat: 48.4861N

Lon: 17.6641E

Elev: 584

StdP: 14.39

Time Zone: 1.00 (EUC)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.1	16.8	3.9	6.9	14.3	9.5	9.1	20.7	25.6	32.8	23.3	32.7	10.9	310	0.526

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.8	91.9	69.6	88.5	68.2	85.3	67.1	71.4	86.4	70.0	84.4	68.5	82.0	6.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.7	100.4	77.0	65.3	95.4	75.3	63.8	90.7	74.0	35.5	86.3	34.3	84.0	33.0	82.1	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
22.2	19.3	17.2	DB	8.0	95.8	4.3	2.5	4.9	97.6	2.4	99.1	0.0	100.5	-3.2	102.3
			WB	7.2	73.8	4.3	1.5	4.1	74.9	1.5	75.7	-0.9	76.6	-4.1	77.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.5	31.2	34.4	42.9	52.5	59.2	66.7	70.3	69.6	61.3	51.3	43.2	33.8
	DBStd	15.27	7.92	7.58	7.42	7.35	6.62	6.02	6.12	6.68	6.28	6.67	7.02	6.93
	HDD50	2111	582	436	237	57	9	0	0	0	1	66	220	503
	HDD65	5458	1047	856	685	377	200	52	22	27	146	424	654	968
	CDD50	2644	0	1	17	133	294	501	628	606	341	107	16	0
	CDD65	516	0	0	0	4	20	103	185	169	35	0	0	0
	CDH74	5823	0	0	0	73	228	1163	2096	1919	336	8	0	0
	CDH80	2161	0	0	0	11	25	374	846	831	74	0	0	0
Wind	WSAvg	7.7	7.8	8.6	9.0	8.9	8.0	6.9	7.0	6.5	7.2	7.2	7.6	7.4
Precipitation	PrecAvg	22.8	1.2	1.1	1.4	1.7	2.3	2.6	2.6	2.1	2.3	1.8	2.0	1.8
	PrecMax	34.7	2.2	2.2	3.1	3.7	6.9	5.0	5.4	4.5	5.9	4.8	4.1	3.8
	PrecMin	14.4	0.2	0.0	0.1	0.0	0.7	0.5	0.4	0.2	0.5	0.2	0.9	0.4
	PrecStd	4.0	0.6	0.6	0.9	1.0	1.5	1.2	1.3	1.2	1.5	1.2	0.8	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.8	54.8	68.4	81.1	83.1	91.0	95.1	96.7	86.4	74.6	63.4	52.2
		MCWB	47.5	46.3	52.3	61.0	64.5	70.6	70.0	67.6	65.8	61.0	54.6	47.5
	2%	DB	47.3	51.0	64.1	75.3	79.3	88.0	91.4	93.0	81.9	70.4	58.6	48.0
		MCWB	44.3	45.2	50.6	58.9	63.6	68.9	69.5	69.1	64.6	59.4	53.1	44.6
	5%	DB	43.9	47.8	59.5	71.1	76.4	84.4	88.0	89.0	78.0	66.3	55.6	45.4
		MCWB	40.9	43.3	48.7	56.4	61.9	67.8	67.6	68.5	63.0	57.8	51.2	42.4
	10%	DB	41.3	44.8	55.5	66.8	73.1	81.0	85.1	84.5	73.6	62.5	52.8	42.8
		MCWB	39.1	41.5	47.0	54.6	60.2	66.4	66.8	67.2	61.3	55.9	48.9	40.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.9	48.5	53.7	62.1	67.6	73.6	72.4	72.6	67.8	62.3	56.0	48.1
		MCDB	50.0	54.3	64.5	76.2	78.9	87.1	87.8	87.2	81.8	70.9	60.7	51.6
	2%	WB	44.5	45.6	51.8	59.8	65.2	71.3	71.0	71.0	65.8	60.4	53.7	45.1
		MCDB	46.8	49.8	61.9	73.4	76.9	84.0	86.8	86.4	78.0	68.7	58.5	47.7
	5%	WB	41.6	43.8	49.9	57.6	63.2	69.2	69.7	69.7	64.3	58.7	51.5	42.7
		MCDB	43.6	47.6	58.1	68.3	73.4	81.3	84.2	85.1	74.7	65.3	54.9	45.1
	10%	WB	39.2	41.8	47.6	55.6	61.4	67.4	68.3	68.0	62.7	56.7	49.5	40.7
		MCDB	41.1	44.6	54.9	65.5	70.4	78.8	81.4	82.5	71.9	61.7	52.5	42.8
Mean Daily Temperature Range	5% DB	MDBR	9.5	11.7	17.7	20.5	19.9	21.6	22.8	22.2	19.1	15.7	10.6	8.4
		MCDBR	10.3	16.9	25.7	27.5	25.3	26.8	28.1	28.4	25.2	21.8	14.5	11.7
		MCWBR	7.8	12.1	14.5	13.3	12.1	11.2	9.8	9.9	10.6	12.5	10.0	9.2
	5% WB	MCDBR	10.2	15.4	22.4	24.6	22.3	24.6	24.0	25.6	22.2	20.8	13.3	11.3
	MCWBR	8.2	11.3	13.1	12.5	11.3	10.9	9.0	9.8	10.1	12.2	9.5	9.2	
Clear-Sky Solar Irradiance	taub		0.322	0.345	0.383	0.428	0.425	0.426	0.436	0.435	0.408	0.379	0.356	0.320
	taud		2.340	2.316	2.251	2.150	2.203	2.241	2.213	2.232	2.274	2.328	2.339	2.367
	Ebn at Noon		232	253	261	260	266	266	261	255	250	237	215	216
	Edh at Noon		23	29	36	44	44	43	43	41	35	29	23	20
All-Sky Solar Radiation	RadAvg		297	553	925	1410	1662	1815	1738	1556	1112	662	336	234
	RadStd		40	75	131	143	184	142	171	149	141	82	35	25

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (79 neighbors)	+1.03	N/A	N/A	N/A	+0.83	+0.74	-229	-310	+151	+65

Nomenclature: See separate page