

PIESTANY, Slovakia

WMO: 118260

Lat: 48.617N

Lon: 17.833E

Elev: 538

StdP: 14.41

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.1	15.3	3.6	6.8	12.3	8.8	8.8	17.1	25.5	34.4	22.9	33.9	5.2	20	0.534

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.6	89.9	69.3	86.4	68.3	83.7	67.1	71.1	85.0	69.7	83.2	68.3	81.0	8.2	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.4	99.3	76.5	64.9	94.1	74.7	63.9	90.8	73.7	35.2	85.2	34.0	83.2	32.8	81.2	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.9	19.3	17.1	3.5	94.4	5.2	3.2	-0.3	96.7	-3.4	98.6	-6.3	100.5	-10.1	102.8		
(5)			2.9	73.8	5.1	1.8	-0.8	75.2	-3.8	76.2	-6.6	77.3	-10.4	78.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.5	30.2	33.8	41.2	51.3	59.4	65.6	69.1	68.8	60.2	50.8	42.0	32.6		
	DBStd	15.46	8.26	7.82	7.27	7.60	6.55	6.32	6.06	6.09	6.43	7.40	7.77	7.83		
	HDD50	2314	613	455	283	73	7	0	0	0	3	82	258	540		
	HDD65	5732	1078	874	737	412	197	69	28	31	171	441	689	1005		
	CDD50	2501	0	1	11	114	297	468	594	582	308	107	19	0		
	CDD65	445	0	0	0	2	22	87	157	148	27	2	0	0		
	CDH74	4743	0	0	0	35	265	942	1731	1526	238	6	0	0		
	CDH80	1568	0	0	0	3	37	271	657	561	39	0	0	0		
	WSAvg	7.2	6.8	7.5	8.3	8.3	7.8	7.0	6.7	6.4	6.8	6.8	7.2	6.5		
	PrecAvg	24.7	1.4	1.4	1.5	1.8	2.5	2.9	3.0	2.3	2.3	1.9	1.9	1.7		
(15) Precipitation	PrecMax	35.7	2.5	3.5	3.6	4.4	6.9	6.3	8.3	4.6	7.8	5.2	4.4	3.9		
	PrecMin	16.3	0.2	0.1	0.2	0.1	0.8	0.8	0.2	0.4	0.3	0.2	0.1	0.5		
	PrecStd	3.5	0.7	0.8	1.0	1.0	1.3	1.3	1.7	1.3	1.6	1.2	0.9	0.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.0	56.2	66.7	78.3	84.2	90.8	94.6	95.0	84.5	73.7	63.8	53.5		
		MCWB	46.7	47.7	52.0	60.4	65.6	70.3	70.1	69.2	66.1	61.8	55.4	48.8		
	2%	DB	48.0	51.8	62.4	73.6	80.2	86.4	90.2	89.9	80.2	69.8	59.3	48.6		
		MCWB	44.2	46.0	50.4	57.7	64.5	69.2	69.1	69.3	64.7	60.2	53.4	45.0		
	5%	DB	44.4	48.6	57.7	69.9	76.9	83.0	86.7	86.1	76.6	66.4	56.0	45.2		
		MCWB	41.3	43.7	48.1	55.8	62.7	67.3	68.1	68.2	63.1	58.3	50.8	42.5		
	10%	DB	41.3	45.5	53.8	66.1	73.4	79.6	83.7	82.4	72.8	62.8	53.5	42.8		
		MCWB	38.9	41.7	46.2	53.8	60.7	65.9	67.0	66.5	61.4	56.1	49.1	40.5		
	0.4%	WB	47.3	49.2	54.0	61.6	67.7	73.0	72.8	72.8	68.3	63.3	56.5	49.2		
		MCDB	51.3	54.9	62.6	75.7	80.7	86.7	87.6	87.1	80.8	71.2	62.6	53.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	44.3	46.5	51.5	58.9	65.4	70.7	70.8	70.8	66.3	61.0	53.9	45.5		
		MCDB	47.3	51.0	60.4	71.4	77.6	83.2	85.3	84.9	76.7	68.2	59.0	48.2		
	5%	WB	41.3	44.0	49.2	56.6	63.6	68.7	69.5	69.3	64.4	59.0	51.5	42.7		
		MCDB	43.7	47.8	56.6	67.8	74.8	80.3	83.1	83.2	73.4	65.2	55.6	44.7		
	10%	WB	39.0	41.9	46.9	54.7	61.8	67.0	68.2	67.7	62.5	56.9	49.5	40.5		
		MCDB	41.1	45.2	53.1	64.4	71.4	77.7	80.9	80.3	70.9	62.0	52.9	42.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.4	13.3	17.2	20.5	20.4	20.9	21.6	21.4	18.6	15.8	11.0	9.3		
		MCDBR	12.2	17.9	24.3	26.3	25.9	25.8	27.4	27.2	24.2	20.2	14.1	11.0		
		MCWBR	9.3	12.6	14.5	13.4	12.4	11.1	9.8	9.7	10.9	11.7	9.4	8.8		
	5% WB	MCDBR	11.7	16.2	21.2	24.0	23.4	22.8	24.2	24.1	21.2	18.2	13.2	10.3		
		MCWBR	9.1	11.9	13.5	12.7	11.8	10.5	9.8	9.5	10.4	11.1	9.1	8.4		
(40) Clear-Sky Solar Irradiance	taub		0.321	0.345	0.384	0.431	0.428	0.428	0.439	0.437	0.409	0.380	0.357	0.320		
	taud		2.328	2.301	2.242	2.146	2.197	2.237	2.209	2.228	2.272	2.325	2.334	2.361		
	Ebn at Noon		231	252	260	259	265	265	260	254	249	236	214	215		
	Edh at Noon		23	29	36	44	44	43	43	41	35	29	23	20		
(44) All-Sky Solar Radiation	RadAvg		295	549	920	1391	1646	1794	1719	1541	1100	656	332	232		
	RadStd		42	78	138	145	187	146	171	148	145	82	37	24		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.95	N/A	N/A	N/A	+0.72	N/A	-223	-311	+198	+99
(47)	Regional (77 neighbors)	+1.03	N/A	N/A	+1.44	+0.85	+0.76	-229	-310	+151	+65

Nomenclature: See separate page