

PIESTANY, Slovakia

WMO: 118260

Lat: 48.617N

Lon: 17.833E

Elev: 164

StdP: 99.37

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.2	-9.3	-15.8	1.0	-11.0	-12.9	1.3	-8.3	11.4	1.3	10.2	1.1	2.3	20	0.534

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	32.2	20.7	30.2	20.1	28.7	19.5	21.7	29.4	21.0	28.5	20.2	27.2	3.7	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	14.2	24.7	18.3	13.4	23.7	17.7	13.0	23.2	64.1	29.6	61.2	28.4	58.5	27.3	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.6	7.6	-15.8	34.7	2.9	1.8	-17.9	36.0	-19.7	37.0	-21.3	38.0	-23.4	39.3		
(5)			-16.1	23.2	2.9	1.0	-18.2	24.0	-19.9	24.6	-21.5	25.2	-23.5	25.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.3	-1.0	1.0	5.1	10.7	15.2	18.7	20.6	20.4	15.7	10.5	5.6	0.3		
	DBStd	8.59	4.59	4.35	4.04	4.22	3.64	3.51	3.37	3.38	3.57	4.11	4.32	4.35		
	HDD10.0	1286	341	253	157	41	4	0	0	0	2	46	143	300		
	HDD18.3	3184	599	486	409	229	109	38	16	17	95	245	383	558		
	CDD10.0	1389	0	1	6	63	165	260	330	323	171	59	11	0		
	CDD18.3	247	0	0	0	1	12	48	87	82	15	1	0	0		
	CDH23.3	2635	0	0	0	19	147	523	962	848	132	3	0	0		
	CDH26.7	871	0	0	0	2	21	151	365	312	22	0	0	0		
	WSAvg	3.2	3.0	3.4	3.7	3.7	3.5	3.1	3.0	2.8	3.0	3.1	3.2	2.9		
	PrecAvg	627	36	36	39	45	63	74	77	59	59	49	48	43		
(15) Precipitation	PrecMax	907	64	89	92	112	174	160	210	118	199	133	112	100		
	PrecMin	414	5	3	5	2	20	21	5	9	7	5	2	12		
	PrecStd	90	18	21	25	26	33	34	43	34	40	30	24	22		
	PrecStd	90	18	21	25	26	33	34	43	34	40	30	24	22		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.1	13.4	19.3	25.7	29.0	32.7	34.8	35.0	29.2	23.2	17.7	11.9		
		MCWB	8.2	8.7	11.1	15.8	18.7	21.3	21.2	20.7	18.9	16.6	13.0	9.3		
	2%	DB	8.9	11.0	16.9	23.1	26.8	30.2	32.3	32.2	26.8	21.0	15.2	9.2		
		MCWB	6.8	7.8	10.2	14.3	18.1	20.6	20.6	20.7	18.1	15.7	11.9	7.2		
	5%	DB	6.9	9.2	14.3	21.0	25.0	28.3	30.4	30.0	24.8	19.1	13.3	7.3		
		MCWB	5.2	6.5	9.0	13.2	17.0	19.6	20.1	20.1	17.3	14.6	10.4	5.8		
	10%	DB	5.2	7.5	12.1	18.9	23.0	26.5	28.7	28.0	22.7	17.1	12.0	6.0		
		MCWB	3.8	5.4	7.9	12.1	16.0	18.8	19.5	19.2	16.3	13.4	9.5	4.7		
	0.4%	WB	8.5	9.6	12.2	16.4	19.8	22.8	22.7	22.7	20.2	17.4	13.6	9.5		
		MCDB	10.7	12.7	17.0	24.3	27.1	30.4	30.9	30.6	27.1	21.8	17.0	11.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	6.8	8.0	10.9	14.9	18.6	21.5	21.6	21.5	19.1	16.1	12.2	7.5		
		MCDB	8.5	10.5	15.8	21.9	25.4	28.4	29.6	29.4	24.8	20.1	15.0	9.0		
	5%	WB	5.2	6.7	9.6	13.7	17.6	20.4	20.9	20.7	18.0	15.0	10.8	5.9		
		MCDB	6.5	8.8	13.7	19.9	23.8	26.8	28.4	28.5	23.0	18.4	13.1	7.1		
	10%	WB	3.9	5.5	8.3	12.6	16.5	19.5	20.1	19.8	16.9	13.8	9.7	4.7		
		MCDB	5.1	7.3	11.7	18.0	21.9	25.4	27.2	26.8	21.6	16.7	11.6	5.7		
	5% DB	MDBR	5.8	7.4	9.5	11.4	11.3	11.6	12.0	11.9	10.3	8.8	6.1	5.2		
		MCDBR	6.8	9.9	13.5	14.6	14.4	14.4	15.2	15.1	13.4	11.2	7.8	6.1		
		MCWBR	5.1	7.0	8.0	7.4	6.9	6.2	5.5	5.4	6.1	6.5	5.2	4.9		
		MCWBR	6.5	9.0	11.8	13.3	13.0	12.7	13.4	13.4	11.8	10.1	7.4	5.7		
(35) Mean Daily Temperature Range	5% WB	MCWBR	5.0	6.6	7.5	7.1	6.5	5.8	5.4	5.3	5.8	6.1	5.1	4.7		
		MCWBR	5.0	6.6	7.5	7.1	6.5	5.8	5.4	5.3	5.8	6.1	5.1	4.7		
	Clear-Sky Solar Irradiance	taub	0.321	0.345	0.384	0.431	0.428	0.428	0.439	0.437	0.409	0.380	0.357	0.320		
		taud	2.328	2.301	2.242	2.146	2.197	2.237	2.209	2.228	2.272	2.325	2.334	2.361		
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	728	795	820	816	835	836	819	802	785	743	675	679		
		Edh at Noon	72	92	115	140	138	134	136	128	111	90	72	62		
(44) All-Sky Solar Radiation	RadStd	RadAvg	0.93	1.73	2.90	4.39	5.19	5.66	5.42	4.86	3.47	2.07	1.05	0.73		
		RadStd	0.13	0.24	0.43	0.46	0.59	0.46	0.54	0.47	0.46	0.26	0.12	0.08		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.53	N/A	N/A	N/A	+0.40	N/A	-124	-173	+110	+55
(47) Regional (77 neighbors)		+0.57	N/A	N/A	+0.80	+0.47	+0.42	-127	-172	+84	+36

Nomenclature: See separate page