

ZILINA HRICOV, Slovakia

WMO: 118410

Lat: 49.233N

Lon: 18.614E

Elev: 1020

StdP: 14.16

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.4	11.3	1.0	6.0	8.6	5.7	7.6	13.3	16.2	34.6	14.5	34.2	3.2	100	0.506

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.1	87.4	68.7	84.0	67.2	80.7	65.5	70.2	83.5	68.5	80.5	67.0	77.7	6.5	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.0	99.5	75.3	64.4	94.1	73.1	62.9	89.0	71.4	34.8	83.9	33.3	81.2	32.0	77.7	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.0	13.0	11.3	-0.1	91.8	6.4	2.6	-4.7	93.7	-8.4	95.2	-12.0	96.7	-16.6	98.6		
(5)			-0.7	73.4	6.3	1.8	-5.2	74.7	-8.9	75.8	-12.4	76.8	-17.0	78.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.2	28.1	31.5	38.4	48.9	57.0	63.2	66.4	65.9	57.5	48.9	40.3	30.7	
	DBStd	15.19	8.20	7.74	7.21	7.45	6.39	6.13	5.83	5.74	6.04	7.05	7.64	7.87	
	HDD50	2692	679	519	360	105	14	0	0	0	7	108	302	598	
	HDD65	6402	1144	939	823	483	258	106	54	59	234	498	741	1063	
	CDD50	2018	0	0	2	72	230	395	509	492	232	75	11	0	
	CDD65	253	0	0	0	0	9	50	99	86	9	0	0	0	
	CDH74	2873	0	0	0	26	177	603	1048	899	117	3	0	0	
	CDH80	836	0	0	0	2	22	162	351	284	15	0	0	0	
Wind	WSAvg	4.0	3.6	3.7	4.7	4.7	4.7	4.4	4.2	3.7	3.7	3.4	3.6	3.6	
Precipitation	PrecAvg	31.1	2.0	1.9	2.0	2.1	3.1	3.4	4.0	3.0	2.8	2.4	2.4	2.1	
	PrecMax	41.7	5.3	4.1	5.2	4.4	8.1	5.5	7.8	7.2	6.0	5.5	4.7	5.2	
	PrecMin	21.9	0.5	0.4	0.4	0.2	1.2	1.2	1.1	0.6	0.8	0.2	0.2	0.7	
	PrecStd	4.1	1.1	0.9	1.2	1.0	1.5	1.1	1.7	1.7	1.5	1.5	1.1	1.0	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.4	53.7	65.0	77.4	82.6	88.2	91.8	91.7	82.4	73.1	64.3	53.6	
		MCWB	44.7	45.8	50.5	58.0	63.3	69.4	69.0	69.3	65.2	61.1	54.3	47.3	
	2%	DB	44.6	48.4	60.1	72.5	78.8	84.7	87.7	86.6	77.3	68.1	59.0	47.6	
		MCWB	42.0	42.5	48.0	55.8	61.8	67.8	68.7	68.5	63.3	58.4	52.3	44.0	
	5%	DB	41.0	44.6	55.1	68.0	75.2	80.9	84.0	82.7	73.6	64.3	55.3	43.1	
		MCWB	39.1	40.4	45.8	53.5	60.8	65.8	67.1	67.0	61.5	56.5	49.6	41.1	
	10%	DB	37.8	41.2	50.1	63.9	71.3	77.0	80.3	79.0	69.8	59.9	51.4	40.2	
		MCWB	36.1	38.3	43.5	51.4	58.8	64.0	65.7	65.2	60.0	54.4	47.6	38.7	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.6	46.6	51.3	59.4	66.0	71.7	72.4	72.5	67.3	62.2	55.6	48.2
			MCDB	48.4	51.7	61.9	73.8	77.5	85.3	86.1	84.6	78.6	69.8	62.5	52.0
2%		WB	42.2	43.3	49.1	56.8	63.7	69.1	70.3	69.9	64.9	59.5	52.9	43.7	
		MCDB	44.0	47.1	57.8	69.2	75.4	81.5	83.6	83.2	74.5	66.3	58.3	46.4	
5%		WB	39.2	40.8	46.5	54.7	61.8	67.2	68.6	68.1	62.8	57.3	50.3	41.2	
		MCDB	40.7	43.6	53.4	65.4	72.5	78.1	80.4	80.4	71.0	63.0	54.6	42.9	
10%		WB	36.4	38.4	44.1	52.7	59.9	65.3	66.9	66.4	60.9	55.1	47.9	38.7	
		MCDB	37.6	40.8	49.4	61.9	69.2	74.9	76.9	77.0	68.2	59.6	50.8	40.0	
Mean Daily Temperature Range	5% DB	MDBR	10.3	13.6	16.6	20.9	20.6	20.7	21.1	21.7	18.5	16.4	11.5	8.9	
		MCDBR	10.9	19.3	26.2	29.4	28.3	27.7	28.3	27.9	25.5	22.8	17.8	11.4	
		MCWBR	8.7	13.2	15.1	14.5	13.5	12.5	11.6	11.7	12.7	13.5	11.4	8.6	
	5% WB	MCDBR	10.1	16.6	22.6	26.5	25.2	24.6	25.0	25.7	22.3	20.8	16.1	10.5	
		MCWBR	8.3	11.9	13.8	13.5	12.8	11.8	11.2	11.4	11.8	12.8	10.7	8.2	
Clear-Sky Solar Irradiance	taub	0.307	0.332	0.376	0.428	0.426	0.428	0.439	0.433	0.403	0.372	0.343	0.306		
	taud	2.303	2.262	2.226	2.161	2.212	2.245	2.218	2.245	2.298	2.361	2.369	2.367		
	Ebn at Noon	233	254	261	259	265	265	259	255	250	238	218	218		
	Edh at Noon	23	30	37	43	43	42	43	40	34	27	22	19		
All-Sky Solar Radiation	RadAvg	289	525	879	1295	1545	1663	1610	1458	1030	629	320	227		
	RadStd	49	82	147	151	198	166	182	141	155	87	46	26		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.94	N/A	N/A	N/A	+0.97	+0.86	-290	-394	+166	+81
(47)	Regional (54 neighbors)	+0.95	N/A	N/A	+1.46	+0.77	+0.68	-225	-293	+139	+58

Nomenclature: See separate page