

MOCHOVCE, Slovakia

WMO: 118560

Lat: 48.2889N

Lon: 18.4550E

Elev: 856

StdP: 14.25

Time Zone: 1.00 (EUC)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.8	16.7	5.6	7.6	18.6	10.4	9.6	21.2	34.2	31.8	29.5	33.7	4.8	110	0.516

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.2	91.8	69.8	88.2	68.7	85.0	67.3	71.8	87.0	70.4	84.9	68.8	82.1	8.1	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.1	102.9	77.9	65.5	97.3	75.8	64.1	92.5	74.2	36.0	87.2	34.8	84.8	33.5	82.2	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.1	23.2	19.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	7.8	74.6	6.1	1.7	3.4	75.8	-0.2	76.7	-3.6	77.7	-8.1	78.9	(4)
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.0	31.0	35.4	43.5	53.5	60.1	67.6	70.7	70.5	61.9	51.6	43.5	33.3	
	DBStd	15.56	7.68	7.60	7.57	7.46	6.70	6.27	6.31	6.82	6.76	6.96	7.09	6.93	
	HDD50	2074	588	409	222	49	7	0	0	0	1	67	213	518	
	HDD65	5351	1053	829	667	348	179	44	22	23	140	417	646	983	
	CDD50	2789	0	0	21	155	319	528	641	635	358	115	17	0	
	CDD65	592	0	0	0	5	26	122	198	193	47	1	0	0	
	CDH74	5858	0	0	0	75	278	1153	1981	1985	378	8	0	0	
	CDH80	2130	0	0	0	9	36	369	769	859	88	0	0	0	
Wind	WSAvg	7.6	8.3	8.4	8.1	8.0	7.0	6.2	6.2	6.1	6.7	8.0	10.3	8.4	
Precipitation	PrecAvg	26.1	1.5	1.5	1.6	2.0	2.7	2.7	2.8	2.4	2.2	2.0	2.4	2.2	
	PrecMax	40.9	3.0	3.3	4.3	4.3	7.3	6.1	5.9	5.5	6.2	4.7	4.9	6.0	
	PrecMin	16.7	0.1	0.0	0.2	0.1	1.1	0.5	0.4	0.1	0.3	0.2	1.2	0.4	
	PrecStd	4.8	0.8	0.8	1.1	1.1	1.5	1.4	1.4	1.6	1.4	1.3	1.1	1.3	
	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.0	56.4	68.4	80.8	84.0	91.4	94.9	96.9	86.5	74.6	61.7	50.1
MCWB			45.6	46.3	52.1	62.0	63.4	69.9	71.5	69.5	66.2	60.4	54.0	46.5	
2%		DB	46.4	51.0	64.4	75.7	80.3	87.8	91.4	93.1	82.6	70.6	58.1	46.8	
		MCWB	43.9	44.2	51.0	58.9	63.7	69.1	69.6	70.1	65.0	59.2	52.0	44.0	
5%		DB	43.3	47.7	59.7	71.4	77.2	84.3	87.4	89.0	78.5	66.4	55.4	44.7	
		MCWB	40.9	43.2	48.3	56.1	62.2	68.2	68.1	69.0	63.7	57.4	50.4	42.4	
10%		DB	40.5	45.4	55.7	67.5	73.8	80.9	84.3	84.8	74.2	62.3	52.8	42.3	
		MCWB	38.6	41.9	46.2	54.6	59.8	66.6	66.8	67.6	61.5	55.6	49.3	40.3	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures		0.4%	WB	46.9	48.7	54.0	62.8	67.0	74.1	72.7	73.0	68.1	62.1	55.4	47.3
			MCDB	48.6	54.1	64.4	77.7	80.0	86.6	88.3	88.8	81.6	70.2	59.5	49.8
	2%	WB	44.0	45.6	51.4	59.8	65.0	71.7	71.3	71.5	66.4	60.3	53.1	44.8	
		MCDB	45.8	48.8	61.8	73.8	77.0	84.7	86.6	88.1	79.1	68.3	56.7	46.5	
	5%	WB	41.3	44.0	49.6	57.5	63.1	69.3	70.1	70.1	64.7	58.6	51.4	42.7	
		MCDB	42.9	47.2	58.1	68.9	74.4	80.9	84.6	85.6	75.6	64.9	54.3	44.5	
	10%	WB	38.9	42.2	47.3	55.5	61.2	67.4	68.4	68.6	63.0	56.5	49.5	40.6	
		MCDB	40.4	45.3	54.5	65.9	71.4	78.8	80.7	82.7	72.5	61.4	52.3	42.0	
	Mean Daily Temperature Range	5% DB	MDBR	9.5	12.0	16.8	19.5	20.2	19.8	21.2	21.7	18.6	15.2	10.4	8.2
			MCDBR	10.2	15.3	23.9	25.7	24.9	24.2	25.9	27.0	23.6	20.3	14.4	10.1
MCWBR			7.7	10.3	13.0	12.3	10.9	10.1	9.5	9.5	9.6	10.6	9.1	8.2	
5% WB		MCDBR	9.6	14.1	20.9	23.3	22.3	21.6	23.3	24.5	20.9	18.6	11.9	9.7	
		MCWBR	7.5	10.0	11.8	11.7	10.5	9.9	9.1	9.6	9.0	10.2	8.3	8.1	
Clear-Sky Solar Irradiance	taub	0.317	0.339	0.376	0.422	0.418	0.418	0.430	0.428	0.401	0.373	0.350	0.316		
	taud	2.356	2.327	2.270	2.171	2.225	2.260	2.227	2.247	2.291	2.347	2.362	2.387		
	Ebn at Noon	236	256	264	262	268	268	263	257	252	240	219	220		
	Edh at Noon	22	29	36	43	43	42	43	40	35	28	23	19		
All-Sky Solar Radiation	RadAvg	309	560	942	1386	1660	1807	1743	1567	1116	685	351	241		
	RadStd	45	89	153	143	190	151	159	154	150	80	44	25		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (67 neighbors)		+1.06	N/A	N/A	+1.53	+0.90	+0.79	-227	-313	+160	+74	

Nomenclature: See separate page