

HURBANOVO, SlovakiaWMO: **118580**Lat: **47.867N**Lon: **18.200E**Elev: **407**StdP: **14.48**Time Zone: **1.00 (EUC)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.9	17.4	6.6	7.8	16.8	11.0	9.8	20.0	21.1	36.8	19.0	36.7	4.3	320	0.484

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.7	91.9	70.1	88.7	68.9	85.6	67.7	72.2	86.9	70.7	84.9	69.2	82.5	6.7	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.5	102.5	77.9	66.0	97.3	76.2	64.6	92.5	74.5	36.1	87.2	34.7	85.3	33.5	82.6	80.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	18.7	16.4	14.3	7.2	96.2	6.6	3.1	2.5	98.4	-1.4	100.3	-5.1	102.0	-9.9	104.3	
(5)				6.8	74.7	6.5	2.1	2.1	76.2	-1.7	77.4	-5.3	78.6	-10.1	80.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.4	31.9	35.7	43.5	53.6	61.6	67.9	71.3	70.6	61.8	52.5	43.2	33.8	
	DBStd	15.59	8.01	8.01	7.39	7.31	6.54	6.42	6.02	6.03	6.33	7.41	7.66	7.64	
	HDD50	2023	560	401	225	46	2	0	0	0	1	59	227	502	
	HDD65	5218	1025	820	667	345	145	41	14	18	135	389	653	966	
	CDD50	2895	0	2	23	155	362	537	660	638	355	138	24	1	
	CDD65	616	0	0	0	4	40	129	210	191	39	3	0	0	
	CDH74	6579	0	0	0	74	476	1387	2272	1980	368	22	0	0	
	CDH80	2409	0	0	0	9	100	482	932	806	80	0	0	0	
Wind	WSAvg	6.4	6.6	6.9	7.7	7.3	6.6	6.1	5.9	5.3	5.8	5.9	6.7	6.5	
Precipitation	PrecAvg	22.8	1.4	1.2	1.3	1.4	2.5	2.3	2.8	2.2	2.2	1.9	1.9	1.6	
	PrecMax	38.3	3.0	4.6	4.4	3.4	8.1	5.1	6.4	4.6	5.8	4.4	4.4	4.8	
	PrecMin	13.7	0.1	0.0	0.0	0.0	0.4	0.2	0.5	0.0	0.2	0.1	0.1	0.2	
	PrecStd	5.0	0.7	1.0	1.0	0.9	1.7	1.2	1.5	1.3	1.5	1.1	1.0	1.1	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.1	59.8	69.2	80.6	86.5	92.8	95.8	97.0	86.4	76.9	65.6	54.5	
		MCWB	47.6	49.3	53.1	61.6	65.2	71.1	70.6	70.4	66.4	62.9	56.9	49.3	
	2%	DB	49.2	54.9	64.5	75.7	82.9	89.1	91.9	92.2	82.1	72.4	60.7	49.4	
		MCWB	44.8	47.3	51.5	58.0	64.5	69.7	70.0	70.0	65.1	60.9	54.0	45.8	
	5%	DB	45.6	50.8	60.0	71.7	79.4	85.7	88.7	88.1	78.4	68.5	57.2	46.1	
		MCWB	42.0	44.9	49.5	56.3	63.1	68.3	68.8	68.8	63.4	59.0	51.7	43.3	
	10%	DB	42.5	47.3	56.0	67.9	75.8	82.2	85.4	84.2	74.4	64.4	54.0	43.7	
		MCWB	39.6	43.0	47.3	54.3	61.5	66.6	67.9	67.2	61.9	57.0	49.8	41.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.2	50.4	55.1	62.3	68.1	73.8	73.6	74.4	68.9	64.4	57.6	49.5
			MCDB	53.0	57.8	65.5	77.2	81.4	88.7	88.7	88.5	81.9	73.8	63.9	53.6
2%		WB	45.2	47.8	52.6	59.7	66.0	71.5	71.9	72.0	66.8	62.1	54.7	46.3	
		MCDB	48.7	53.8	61.8	73.1	78.9	85.4	86.7	86.8	78.5	70.6	59.9	48.8	
5%		WB	42.3	45.5	50.4	57.4	64.3	69.5	70.5	70.3	65.2	60.0	52.4	43.8	
		MCDB	45.2	50.0	58.2	68.8	76.8	82.3	84.8	84.8	75.4	67.0	56.6	45.9	
10%		WB	39.7	43.3	48.3	55.5	62.6	67.8	69.1	68.6	63.3	57.8	50.2	41.5	
		MCDB	42.2	47.3	55.2	66.2	73.8	79.7	82.3	81.6	71.9	63.3	53.6	43.4	
Mean Daily Temperature Range	5% DB	MDBR	10.3	13.6	17.3	20.2	20.5	20.9	21.7	22.0	19.4	17.2	11.7	9.4	
		MCDBR	13.5	18.8	24.2	26.6	26.4	25.5	26.8	27.6	25.3	22.1	16.4	11.8	
		MCWBR	9.6	12.4	13.7	12.2	11.0	9.8	9.1	9.7	10.8	11.6	10.3	9.0	
	5% WB	MCDBR	13.0	17.1	21.7	24.0	23.5	23.2	23.8	24.7	21.7	20.3	14.7	11.3	
		MCWBR	9.6	11.7	12.9	11.6	10.6	9.9	9.0	9.7	9.9	11.1	9.7	8.9	
Clear-Sky Solar Irradiance	taub	0.327	0.350	0.387	0.432	0.426	0.427	0.437	0.438	0.412	0.382	0.358	0.326		
	taud	2.363	2.326	2.251	2.145	2.210	2.244	2.214	2.229	2.268	2.330	2.353	2.380		
	Ebn at Noon	233	253	261	259	266	266	261	255	250	238	218	218		
	Edh at Noon	23	29	36	45	43	43	43	41	36	29	23	20		
All-Sky Solar Radiation	RadAvg	321	576	963	1423	1704	1853	1801	1612	1144	715	372	247		
	RadStd	40	85	141	141	183	143	147	157	141	79	39	29		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		+0.72	N/A	N/A	N/A	N/A	N/A	-277	N/A	N/A	N/A
Regional (70 neighbors)		+1.08	N/A	N/A	+1.62	+0.95	+0.85	-229	-324	+182	+94