

HURBANOVO, Slovakia

WMO: 118580

Lat: 47.867N

Lon: 18.200E

Elev: 124

StdP: 99.84

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.6	-8.1	-14.1	1.1	-8.5	-11.6	1.4	-6.7	9.4	2.7	8.5	2.6	1.9	320	0.484

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	33.3	21.2	31.5	20.5	29.8	19.8	22.3	30.5	21.5	29.4	20.7	28.0	3.0	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.7	14.6	25.5	18.9	13.9	24.6	18.1	13.2	23.6	66.0	30.7	62.9	29.6	60.0	28.1	26.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.3	6.4	DB	-13.8	35.7	3.7	1.7	-16.4	36.9	-18.6	37.9	-20.6	38.9	-23.3	40.2	(4)
(5)			WB	-14.0	23.7	3.6	1.2	-16.6	24.6	-18.7	25.2	-20.7	25.9	-23.4	26.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.3	0.0	2.1	6.4	12.0	16.4	20.0	21.8	21.4	16.6	11.4	6.2	1.0	(6)
(7)		DBStd	8.66	4.45	4.45	4.10	4.06	3.63	3.56	3.35	3.35	3.52	4.12	4.25	4.24	(7)
(8)		HDD10.0	1124	311	223	125	26	1	0	0	0	1	33	126	279	(8)
(9)		HDD18.3	2899	569	456	371	192	81	23	8	10	75	216	363	537	(9)
(10)		CDD10.0	1608	0	1	13	86	201	298	367	354	197	77	13	1	(10)
(11)		CDD18.3	342	0	0	0	2	22	72	117	106	22	2	0	0	(11)
(12)		CDH23.3	3655	0	0	0	41	264	771	1262	1100	204	12	0	0	(12)
(13)		CDH26.7	1338	0	0	0	5	56	268	518	448	44	0	0	0	(13)
(14)	Wind	WSAvg	2.9	2.9	3.1	3.4	3.3	3.0	2.7	2.6	2.4	2.6	3.0	2.9	(14)	
(15)	Precipitation	PrecAvg	578	36	31	34	36	64	59	70	56	55	47	49	41	(15)
(16)		PrecMax	973	76	118	112	87	205	130	163	117	148	111	112	123	(16)
(17)		PrecMin	347	2	0	1	0	10	6	13	0	6	3	3	4	(17)
(18)		PrecStd	128	19	25	25	22	43	31	39	33	37	28	25	27	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.3	15.5	20.7	27.0	30.3	33.8	35.4	36.1	30.2	24.9	18.7	12.5	(19)
(20)			MCWB	8.7	9.6	11.7	16.4	18.4	21.7	21.4	21.3	19.1	17.2	13.8	9.6	(20)
(21)		2%	DB	9.6	12.7	18.0	24.3	28.3	31.7	33.3	33.4	27.8	22.4	15.9	9.7	(21)
(22)			MCWB	7.1	8.5	10.8	14.4	18.1	21.0	21.1	21.1	18.4	16.1	12.2	7.7	(22)
(23)		5%	DB	7.5	10.5	15.5	22.0	26.4	29.8	31.5	31.2	25.8	20.3	14.0	7.8	(23)
(24)			MCWB	5.6	7.2	9.7	13.5	17.3	20.2	20.4	20.5	17.5	15.0	10.9	6.3	(24)
(25)		10%	DB	5.8	8.5	13.3	19.9	24.4	27.9	29.7	29.0	23.6	18.0	12.2	6.5	(25)
(26)			MCWB	4.2	6.1	8.5	12.4	16.4	19.2	19.9	19.5	16.6	13.9	9.9	5.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.0	10.2	12.8	16.8	20.0	23.2	23.1	23.6	20.5	18.0	14.2	9.7	(27)
(28)			MCD B	11.6	14.3	18.6	25.1	27.5	31.5	31.5	31.4	27.7	23.2	17.7	12.0	(28)
(29)		2%	WB	7.3	8.8	11.5	15.4	18.9	21.9	22.2	22.2	19.4	16.7	12.6	8.0	(29)
(30)			MCD B	9.3	12.1	16.5	22.8	26.1	29.7	30.4	30.4	25.8	21.4	15.5	9.3	(30)
(31)		5%	WB	5.7	7.5	10.2	14.1	17.9	20.8	21.4	21.3	18.4	15.5	11.3	6.5	(31)
(32)			MCD B	7.3	10.0	14.6	20.5	24.9	27.9	29.3	29.4	24.1	19.5	13.7	7.7	(32)
(33)		10%	WB	4.3	6.3	9.0	13.0	17.0	19.9	20.6	20.3	17.4	14.3	10.1	5.3	(33)
(34)			MCD B	5.7	8.5	12.9	19.0	23.2	26.5	28.0	27.5	22.2	17.4	12.0	6.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.7	7.5	9.6	11.2	11.4	11.6	12.1	12.2	10.8	9.5	6.5	5.2	(35)
(36)			MCD BR	7.5	10.4	13.4	14.8	14.7	14.2	14.9	15.3	14.1	12.3	9.1	6.6	(36)
(37)			MCWBR	5.4	6.9	7.6	6.8	6.1	5.5	5.1	5.4	6.0	6.4	5.7	5.0	(37)
(38)		5% WB	MCD BR	7.2	9.5	12.1	13.3	13.1	12.9	13.2	13.7	12.1	11.3	8.2	6.3	(38)
(39)			MCWBR	5.3	6.5	7.2	6.4	5.9	5.5	5.0	5.4	5.5	6.2	5.4	4.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.327	0.350	0.387	0.432	0.426	0.427	0.437	0.438	0.412	0.382	0.358	0.326	(40)	
(41)		taud	2.363	2.326	2.251	2.145	2.210	2.244	2.214	2.229	2.268	2.330	2.353	2.380	(41)	
(42)		Ebn at Noon	736	799	822	818	839	839	823	804	787	749	687	688	(42)	
(43)		Edh at Noon	71	92	115	141	137	134	136	128	113	91	73	63	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.01	1.82	3.04	4.49	5.37	5.84	5.68	5.08	3.61	2.25	1.17	0.78	(44)	
(45)		RadStd	0.13	0.27	0.45	0.44	0.58	0.45	0.46	0.49	0.45	0.25	0.12	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.40	N/A	N/A	N/A	N/A	N/A	-154	N/A	N/A	N/A
(47) Regional (70 neighbors)		+0.60	N/A	N/A	+0.90	+0.53	+0.47	-127	-180	+101	+52

Nomenclature: See separate page