

PRIEVIDZA, Slovakia

WMO: 118670

Lat: 48.767N

Lon: 18.600E

Elev: 856

StdP: 14.25

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.9	12.8	1.0	6.0	10.8	6.0	7.7	16.4	18.6	33.2	16.1	34.6	2.2	20	0.494

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.3	89.8	69.2	86.3	67.8	83.3	66.4	71.1	85.5	69.4	83.0	67.8	80.4	6.8	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.4	100.2	76.9	64.7	94.5	74.6	63.3	89.8	73.2	35.4	85.4	33.9	83.3	32.6	80.6	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.4	14.2	12.4	DB	0.3	93.9	7.2	3.3	-4.8	96.2	-9.0	98.1	-13.0	100.0	-18.2	102.4	(4)
(5)			WB	-0.1	74.1	7.0	2.1	-5.1	75.6	-9.2	76.8	-13.1	77.9	-18.2	79.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	50.0	29.6	33.1	40.7	51.4	59.1	65.0	68.2	67.8	59.2	50.6	42.0	32.1	(6)
(7)		DBStd	15.39	8.23	7.89	7.34	7.59	6.46	6.41	6.23	6.07	6.51	7.37	7.88	7.97	(7)
(8)		HDD50	2386	633	472	296	72	8	0	0	0	5	85	259	556	(8)
(9)		HDD65	5860	1098	892	753	409	202	78	39	39	195	446	689	1020	(9)
(10)		CDD50	2385	0	0	8	114	289	451	564	553	281	104	20	1	(10)
(11)		CDD65	387	0	0	0	2	19	79	138	127	21	1	0	0	(11)
(12)		CDH74	4460	0	0	0	52	281	901	1547	1420	248	11	0	0	(12)
(13)		CDH80	1470	0	0	0	5	42	271	587	518	47	0	0	0	(13)
(14)	Wind	WSAvg	5.2	4.7	5.1	5.8	6.1	5.9	5.4	5.2	4.7	4.9	4.6	5.0	4.5	(14)
(15)	Precipitation	PrecAvg	30.2	2.1	1.9	2.0	2.0	2.8	3.2	3.7	2.9	2.6	2.4	2.5	2.2	(15)
(16)		PrecMax	39.7	5.4	4.8	5.5	4.7	6.6	5.8	7.2	8.0	5.9	6.0	5.4	5.3	(16)
(17)		PrecMin	21.1	0.4	0.2	0.4	0.1	1.1	1.1	0.6	0.5	0.5	0.2	0.3	0.7	(17)
(18)		PrecStd	4.3	1.2	1.1	1.3	1.0	1.4	1.2	1.5	1.9	1.5	1.5	1.2	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.9	55.7	67.7	79.2	84.3	90.5	94.4	94.7	85.2	75.5	64.2	53.3	(19)
(20)			MCWB	45.1	46.8	51.5	59.4	64.3	70.5	70.3	70.0	65.9	61.6	54.7	47.2	(20)
(21)		2%	DB	46.4	50.9	62.6	74.8	80.3	86.6	89.9	89.8	80.3	70.6	59.4	48.3	(21)
(22)			MCWB	43.3	44.4	48.9	57.0	63.4	69.0	69.0	69.1	63.7	59.2	52.2	44.6	(22)
(23)		5%	DB	43.1	47.4	57.5	70.1	77.1	83.1	86.3	85.7	76.6	66.8	56.7	44.9	(23)
(24)			MCWB	40.6	42.5	47.1	54.5	61.7	67.0	67.7	67.6	62.4	57.7	50.9	42.3	(24)
(25)		10%	DB	40.6	44.3	53.3	66.2	73.6	79.4	82.8	82.2	72.5	62.9	53.7	42.4	(25)
(26)			MCWB	38.2	40.3	45.1	52.8	59.9	65.3	66.6	65.9	60.5	56.1	49.2	40.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.7	48.2	53.0	61.1	67.3	73.1	72.8	73.0	68.0	63.2	55.8	48.2	(27)
(28)			MCD B	48.8	53.7	63.6	75.9	81.0	86.6	88.5	88.0	81.1	72.2	61.5	51.3	(28)
(29)		2%	WB	43.6	45.5	50.4	58.4	64.9	70.3	70.9	70.8	65.6	60.7	53.5	45.1	(29)
(30)			MCD B	45.7	49.9	59.6	71.4	76.7	83.5	85.5	85.6	76.9	68.1	58.8	47.8	(30)
(31)		5%	WB	40.7	42.9	48.3	56.1	63.1	68.3	69.3	68.8	63.7	58.7	51.6	42.6	(31)
(32)			MCD B	42.7	46.6	55.7	67.2	74.1	80.3	82.6	82.8	73.2	65.3	55.9	44.7	(32)
(33)		10%	WB	38.2	40.7	46.0	54.1	61.3	66.7	67.7	67.1	61.8	56.7	49.5	40.3	(33)
(34)			MCD B	40.2	43.8	52.2	64.5	71.4	77.6	79.9	79.6	70.4	62.4	53.2	42.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.8	14.3	17.4	21.3	21.6	21.7	22.3	22.8	20.2	17.7	12.0	10.4	(35)
(36)			MCDBR	11.9	18.8	26.6	28.5	27.6	27.1	28.5	29.0	27.1	23.8	17.0	11.1	(36)
(37)			MCWBR	9.3	12.7	15.2	13.4	13.0	12.1	10.9	11.2	12.6	13.4	10.7	8.7	(37)
(38)		5% WB	MCDWR	10.8	16.6	22.7	26.0	24.7	24.0	25.1	26.0	23.3	20.9	14.1	10.5	(38)
(39)			MCWBR	8.9	11.7	13.9	12.8	12.4	11.5	10.5	11.0	11.4	12.4	9.4	8.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.310	0.335	0.376	0.426	0.424	0.424	0.436	0.433	0.403	0.374	0.348	0.311	(40)	
(41)		taud	2.329	2.289	2.247	2.166	2.214	2.252	2.221	2.243	2.294	2.350	2.361	2.378	(41)	
(42)		Ebn at Noon	235	256	263	260	266	266	261	255	251	238	218	219	(42)	
(43)		Edh at Noon	23	30	36	43	43	42	43	40	34	28	22	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	299	543	913	1341	1603	1738	1674	1510	1075	654	333	235	(44)	
(45)		RadStd	48	87	153	147	194	158	172	149	154	82	46	24	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+1.44	N/A	N/A	+2.59	+1.17	N/A	-236	-450	+284	+128	(46)
(47)	Regional (63 neighbors)	+1.03	N/A	N/A	+1.57	+0.85	+0.72	-227	-306	+155	+72	(47)

Nomenclature: See separate page