

PRIEVIDZA, Slovakia

WMO: 118670

Lat: 48.767N

Lon: 18.600E

Elev: 261

StdP: 98.23

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.0	-10.7	-17.2	0.9	-11.8	-14.4	1.1	-8.7	8.3	0.7	7.2	1.5	1.0	20	0.494

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.4	32.1	20.7	30.2	19.9	28.5	19.1	21.7	29.7	20.8	28.3	19.9	26.9	3.0	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	14.3	25.0	18.2	13.5	23.7	17.4	12.8	22.9	64.4	29.7	61.0	28.5	57.9	27.0	25.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4)	7.3	6.3	5.5	DB	-17.6	34.4	4.0	1.8	-20.4	35.7	-22.8	36.7	-25.0	37.8	-27.9	39.1
(5)				WB	-17.8	23.4	3.9	1.1	-20.6	24.2	-22.9	24.9	-25.1	25.5	-27.9	26.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.0	-1.3	0.6	4.8	10.8	15.0	18.3	20.1	19.9	15.1	10.3	5.6	0.0	(6)
(7)		DBStd	8.55	4.57	4.38	4.08	4.22	3.59	3.56	3.46	3.37	3.62	4.09	4.38	4.43	(7)
(8)		HDD10.0	1326	352	262	164	40	4	0	0	0	3	47	144	309	(8)
(9)		HDD18.3	3256	610	496	418	227	112	43	22	22	108	248	383	567	(9)
(10)		CDD10.0	1325	0	0	4	63	161	251	313	307	156	58	11	1	(10)
(11)		CDD18.3	215	0	0	0	1	11	44	77	71	12	1	0	0	(11)
(12)		CDH23.3	2478	0	0	0	29	156	501	859	789	138	6	0	0	(12)
(13)		CDH26.7	817	0	0	0	3	23	151	326	288	26	0	0	0	(13)
(14)	Wind	WSAvg	2.3	2.1	2.3	2.6	2.7	2.6	2.4	2.3	2.1	2.2	2.1	2.2	2.0	(14)
(15)	Precipitation	PrecAvg	768	54	49	51	51	72	82	93	73	65	61	63	56	(15)
(16)		PrecMax	1008	136	123	139	120	167	147	183	204	151	153	136	135	(16)
(17)		PrecMin	535	9	6	9	2	27	29	14	13	12	4	8	19	(17)
(18)		PrecStd	108	30	27	33	26	35	31	38	49	38	38	30	28	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.9	13.2	19.8	26.2	29.0	32.5	34.7	34.8	29.5	24.2	17.9	11.8	(19)
(20)		MCWB	7.3	8.2	10.9	15.2	18.0	21.4	21.3	21.1	18.8	16.5	12.6	8.4	(20)	
(21)		2%	DB	8.0	10.5	17.0	23.8	26.8	30.3	32.2	32.1	26.8	21.4	15.2	9.0	(21)
(22)		MCWB	6.3	6.9	9.4	13.9	17.5	20.5	20.5	20.6	17.6	15.1	11.2	7.0	(22)	
(23)		5%	DB	6.1	8.5	14.1	21.2	25.1	28.4	30.2	29.9	24.8	19.3	13.7	7.2	(23)
(24)		MCWB	4.8	5.9	8.4	12.5	16.5	19.4	19.8	19.8	16.9	14.3	10.5	5.7	(24)	
(25)		10%	DB	4.8	6.8	11.8	19.0	23.1	26.4	28.2	27.9	22.5	17.1	12.1	5.8	(25)
(26)		MCWB	3.4	4.6	7.3	11.5	15.5	18.5	19.2	18.8	15.9	13.4	9.6	4.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.2	9.0	11.7	16.1	19.6	22.9	22.7	22.8	20.0	17.3	13.2	9.0	(27)
(28)		MDCB	9.3	12.0	17.6	24.4	27.2	30.3	31.4	31.1	27.3	22.3	16.4	10.7	(28)	
(29)		2%	WB	6.4	7.5	10.2	14.6	18.3	21.3	21.6	21.5	18.7	15.9	12.0	7.3	(29)
(30)		MDCB	7.6	10.0	15.3	21.9	24.8	28.6	29.7	29.8	24.9	20.0	14.9	8.8	(30)	
(31)		5%	WB	4.8	6.1	9.0	13.4	17.3	20.2	20.7	20.5	17.6	14.8	10.9	5.9	(31)
(32)		MDCB	6.0	8.1	13.2	19.5	23.4	26.8	28.1	28.2	22.9	18.5	13.3	7.1	(32)	
(33)		10%	WB	3.5	4.8	7.8	12.3	16.3	19.3	19.8	19.5	16.6	13.7	9.7	4.6	(33)
(34)		MDCB	4.6	6.5	11.2	18.1	21.9	25.3	26.6	26.4	21.3	16.9	11.8	5.5	(34)	
(35)	Mean Daily Temperature Range	MDBR	6.6	7.9	9.7	11.8	12.0	12.0	12.4	12.7	11.2	9.8	6.7	5.8	(35)	
(36)		5% DB	MCDBR	6.6	10.5	14.8	15.8	15.3	15.1	15.9	16.1	15.0	13.2	9.4	6.2	(36)
(37)		MCWBR	5.2	7.1	8.5	7.5	7.2	6.7	6.1	6.2	7.0	7.5	6.0	4.9	(37)	
(38)		5% WB	MCDBR	6.0	9.2	12.6	14.4	13.7	13.3	13.9	14.5	12.9	11.6	7.8	5.8	(38)
(39)		MCWBR	4.9	6.5	7.7	7.1	6.9	6.4	5.8	6.1	6.3	6.9	5.2	4.8	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.310	0.335	0.376	0.426	0.424	0.424	0.436	0.433	0.403	0.374	0.348	0.311	(40)	
(41)		taud	2.329	2.289	2.247	2.166	2.214	2.252	2.221	2.243	2.294	2.350	2.361	2.378	(41)	
(42)		Ebn at Noon	741	806	828	820	839	839	822	805	791	751	686	691	(42)	
(43)		Edh at Noon	71	93	114	137	136	132	134	126	108	87	70	60	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.94	1.71	2.88	4.23	5.05	5.48	5.28	4.76	3.39	2.06	1.05	0.74	(44)	
(45)		RadStd	0.15	0.27	0.48	0.46	0.61	0.50	0.54	0.47	0.49	0.26	0.14	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)	
		+0.80	N/A	N/A	+1.44	+0.65	N/A	-131	-250	+158	+71		
(47)	Regional (63 neighbors)		+0.57	N/A	N/A	+0.87	+0.47	+0.40	-126	-170	+86	+40	(47)

Nomenclature: See separate page