

DUDINCE, Slovakia

WMO: 118800

Lat: 48.167N

Lon: 18.867E

Elev: 140

StdP: 99.65

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.7	-10.9	-17.1	0.9	-13.0	-13.9	1.1	-9.2	6.7	4.1	6.0	3.6	0.5	80	0.460

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.5	33.1	21.6	31.2	20.7	29.6	20.0	22.7	30.5	21.7	29.0	20.9	27.9	2.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.3	15.3	25.8	19.3	14.3	24.6	18.5	13.6	23.7	67.7	30.5	64.0	29.3	60.9	27.9	27.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
6.2	5.2	4.4	DB	-18.6	35.3	4.8	1.8	-22.0	36.6	-24.8	37.6	-27.5	38.6	-31.0	39.8	
			WB	-18.8	24.2	4.7	1.4	-22.2	25.2	-25.0	26.0	-27.7	26.8	-31.1	27.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.3	-1.4	0.7	5.2	11.0	15.6	19.0	20.9	20.8	15.8	10.5	5.4	-0.1
	DBStd	8.79	4.76	4.44	4.00	3.85	3.39	3.39	3.32	3.23	3.43	3.99	4.09	4.65
	HDD10.0	1304	352	260	153	33	2	0	0	0	1	44	144	314
	HDD18.3	3178	611	493	406	219	97	32	13	13	91	244	387	572
	CDD10.0	1428	0	0	6	64	176	271	337	334	174	59	7	0
	CDD18.3	261	0	0	0	1	12	53	92	89	14	0	0	0
	CDH23.3	3358	0	0	0	34	229	704	1136	1048	199	7	0	0
	CDH26.7	1224	0	0	0	3	43	238	471	423	46	0	0	0
Wind	WSAvg	1.6	1.5	1.6	1.9	1.9	1.8	1.7	1.8	1.5	1.5	1.4	1.6	1.5
Precipitation	PrecAvg	637	42	37	38	43	64	71	78	61	54	50	53	47
	PrecMax	1103	82	118	94	111	177	192	154	170	139	103	117	122
	PrecMin	419	2	2	0	4	16	12	10	5	1	1	7	9
	PrecStd	133	20	24	26	24	39	40	41	42	35	28	23	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.4	14.4	20.3	26.5	29.9	33.6	35.7	36.0	30.5	24.2	17.6	10.4
		MCWB	8.0	9.0	11.8	16.3	19.1	21.8	21.9	22.0	20.1	17.0	13.4	8.4
	2%	DB	8.1	11.5	17.6	24.0	27.9	31.3	33.2	33.1	27.8	21.9	14.8	8.5
		MCWB	6.3	7.9	10.5	14.7	18.4	21.1	21.6	21.6	18.7	15.9	11.5	6.8
	5%	DB	6.2	9.3	15.1	21.7	26.0	29.5	31.2	30.9	25.6	19.8	13.1	7.1
		MCWB	4.9	6.4	9.3	13.4	17.6	20.3	20.7	20.6	17.6	15.1	10.7	5.8
	10%	DB	4.6	7.2	12.7	19.6	24.0	27.5	29.4	28.9	23.5	17.4	11.5	5.7
		MCWB	3.5	5.2	8.1	12.4	16.6	19.4	20.0	19.8	16.7	13.7	9.7	4.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.5	9.8	12.7	17.0	20.4	23.4	23.8	24.0	21.0	18.0	14.0	8.8
		MCDB	9.9	13.4	18.1	25.3	27.2	30.9	31.4	31.9	28.4	22.4	16.8	10.1
	2%	WB	6.6	8.1	11.2	15.5	19.2	22.0	22.6	22.8	19.7	16.7	12.3	7.2
		MCDB	7.6	10.9	16.1	22.3	25.9	29.4	30.6	30.3	25.8	21.0	14.3	8.2
	5%	WB	5.1	6.7	10.0	14.2	18.2	21.0	21.6	21.6	18.6	15.5	11.0	6.0
		MCDB	6.1	8.7	14.0	20.3	24.6	27.6	29.1	28.8	24.0	19.1	12.6	6.9
	10%	WB	3.7	5.4	8.7	13.1	17.2	20.0	20.7	20.7	17.5	14.2	9.8	4.8
		MCDB	4.6	7.1	12.1	18.6	23.1	26.3	27.7	27.6	22.1	16.8	11.5	5.6
Mean Daily Temperature Range	5% DB	MDBR	6.7	8.7	11.0	13.0	13.2	13.5	13.6	12.2	10.6	7.1	5.8	
		MCDBR	7.3	11.5	15.6	17.1	16.7	16.3	16.6	16.8	16.1	14.0	9.9	6.6
		MCWBR	5.5	8.0	9.2	8.7	7.9	7.1	6.4	6.4	7.6	8.3	6.7	5.1
	5% WB	MCDBR	6.9	10.3	13.5	15.3	14.7	14.5	14.8	15.0	13.6	12.7	8.5	6.1
		MCWBR	5.5	7.4	8.5	8.1	7.4	6.8	6.2	6.5	6.8	7.8	6.0	4.9
Clear-Sky Solar Irradiance	taub	0.325	0.348	0.387	0.437	0.430	0.431	0.444	0.442	0.413	0.384	0.359	0.324	
	taud	2.340	2.299	2.238	2.130	2.197	2.235	2.200	2.218	2.263	2.318	2.340	2.368	
	Ebn at Noon	731	797	819	811	834	835	816	798	783	743	680	683	
	Edh at Noon	72	93	116	143	139	135	138	130	113	91	73	63	
All-Sky Solar Radiation	RadAvg	0.98	1.78	2.99	4.39	5.28	5.74	5.55	4.99	3.54	2.19	1.13	0.76	
	RadStd	0.14	0.28	0.48	0.45	0.60	0.47	0.49	0.49	0.47	0.25	0.14	0.08	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.74	N/A	N/A	+1.20	+0.68	N/A	-179	-243	+136	+69
(47)	Regional (56 neighbors)	+0.60	N/A	N/A	+0.88	+0.53	+0.46	-127	-181	+92	+43

Nomenclature: See separate page