

LIESEK, Slovakia

WMO: 119180

Lat: 49.367N

Lon: 19.683E

Elev: 2274

StdP: 13.53

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.5	5.3	-4.7	4.6	0.2	0.8	6.2	6.4	26.0	32.1	23.5	31.9	4.7	80	0.598

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.9	81.9	65.4	78.5	64.0	75.3	62.4	67.0	78.4	65.3	75.9	63.7	73.0	7.5	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.0	93.8	71.3	61.5	88.6	69.3	60.0	84.2	67.6	32.8	78.4	31.5	76.2	30.2	73.0	74.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.8	18.9	16.6	-7.5	87.3	7.0	2.2	-12.6	88.8	-16.6	90.1	-20.5	91.3	-25.6	92.9		
			-8.0	70.1	6.9	1.9	-13.0	71.5	-17.0	72.6	-20.8	73.6	-25.8	75.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.1	25.1	27.5	34.0	44.3	52.4	58.7	61.3	61.3	53.1	45.5	37.0	27.8
	DBStd	15.07	9.50	9.69	8.31	7.56	6.55	6.22	5.70	5.62	6.32	7.67	8.51	9.27
	HDD50	3458	771	630	498	196	50	6	1	1	40	181	396	688
	HDD65	7702	1236	1050	962	620	391	203	142	142	359	603	841	1153
	CDD50	1302	0	0	0	26	125	267	351	352	133	43	5	0
	CDD65	73	0	0	0	0	1	14	28	28	2	0	0	0
	CDH74	951	0	0	0	3	34	209	335	342	28	0	0	0
	CDH80	175	0	0	0	0	2	31	63	76	3	0	0	0
Wind	WSAvg	6.7	8.2	7.7	7.5	6.6	6.1	5.7	5.5	5.2	5.8	6.5	7.2	8.6
Precipitation	PrecAvg	36.6	1.9	1.9	2.3	2.4	4.0	4.6	5.5	3.8	3.5	2.6	2.2	1.7
	PrecMax	50.5	4.7	4.4	5.9	4.3	12.2	7.2	12.2	7.2	8.7	5.7	4.3	3.6
	PrecMin	28.2	0.4	0.6	0.6	0.2	1.5	2.1	1.5	0.8	0.7	0.4	0.0	0.7
	PrecStd	5.0	1.1	0.9	1.1	1.1	2.1	1.6	2.7	1.8	1.9	1.4	0.9	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.9	50.5	60.1	72.1	78.0	83.7	85.4	86.8	77.5	69.6	60.2	52.2
		MCWB	41.8	42.8	46.3	54.9	60.1	65.5	66.4	66.1	63.0	57.7	51.1	46.2
	2%	DB	42.9	46.2	54.8	67.3	73.6	79.6	81.5	81.6	72.7	65.1	56.3	45.9
		MCWB	40.1	40.8	44.7	52.2	58.8	64.4	65.7	65.3	60.4	55.4	49.2	42.1
	5%	DB	39.7	43.0	50.2	62.6	70.0	75.8	77.7	77.6	69.2	61.5	53.0	41.8
		MCWB	37.3	38.9	42.5	50.3	57.6	62.5	64.1	63.9	58.5	54.2	47.4	39.0
	10%	DB	37.0	39.6	45.9	58.4	65.9	72.0	74.0	74.0	65.2	57.4	48.9	38.7
		MCWB	35.0	36.4	40.6	48.3	55.6	60.9	62.6	62.4	56.8	51.9	45.4	36.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.0	44.1	48.2	55.7	63.4	68.4	69.1	68.8	64.3	59.2	52.1	46.3
		MCDB	45.1	48.5	56.9	69.2	73.6	79.6	79.7	80.3	74.3	66.6	58.4	51.0
	2%	WB	40.5	41.8	45.7	53.5	60.4	65.8	67.0	66.6	61.8	56.5	49.9	42.5
		MCDB	42.7	45.6	52.8	65.2	69.9	76.2	78.2	78.4	70.4	63.0	55.0	45.6
	5%	WB	37.5	39.1	43.3	51.5	58.5	63.7	65.3	64.9	59.6	54.5	47.9	39.1
		MCDB	39.4	42.4	49.3	60.2	67.5	73.2	75.6	75.5	66.6	60.5	52.2	41.3
	10%	WB	35.1	36.6	40.9	49.2	56.4	61.9	63.6	63.1	57.6	52.5	45.6	37.0
		MCDB	36.7	39.3	45.6	56.9	64.6	70.4	72.2	72.3	64.0	57.4	48.9	38.7
Mean Daily Temperature Range	5% DB	MDBR	10.8	13.1	15.1	18.9	19.2	18.9	18.9	20.4	17.4	15.4	11.7	10.2
		MCDBR	10.2	16.1	22.3	27.4	27.3	26.5	26.1	27.0	24.9	22.0	17.1	12.4
		MCWBR	8.1	11.1	13.6	14.5	14.0	13.0	12.2	12.6	13.4	13.2	11.2	9.1
	5% WB	MCDBR	9.5	13.8	19.9	24.1	24.0	23.5	23.8	24.5	21.7	20.4	15.3	11.7
		MCWBR	7.9	10.1	12.7	13.2	13.2	12.1	11.9	12.1	12.3	12.5	10.6	8.9
Clear-Sky Solar Irradiance	taub	0.294	0.321	0.371	0.430	0.426	0.428	0.441	0.435	0.401	0.363	0.331	0.292	
	taud	2.279	2.215	2.164	2.106	2.177	2.213	2.179	2.202	2.260	2.340	2.356	2.337	
	Ebn at Noon	237	257	262	258	265	265	259	254	250	240	221	222	
	Edh at Noon	23	31	39	46	45	43	44	41	35	27	22	19	
All-Sky Solar Radiation	RadAvg	286	522	874	1282	1534	1644	1593	1451	1022	625	318	224	
	RadStd	47	80	140	151	199	164	185	135	154	89	46	26	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	+1.03	N/A	N/A	+2.45	+1.21	+1.17	N/A	N/A	N/A
(47)	Regional (46 neighbors)	+1.03	N/A	N/A	+1.66	+0.85	+0.68	-234	-329	+157

Nomenclature: See separate page