

LIESEK, Slovakia

WMO: 119180

Lat: 49.367N

Lon: 19.683E

Elev: 693

StdP: 93.27

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -18.0	(c) -14.8	(d) -20.4	(e) 0.7	(f) -17.7	(g) -17.3	(h) 0.9	(i) -14.2	(j) 11.6	(k) 0.0	(l) 10.5	(m) -0.1	(n) 2.1	(o) 80	(p) 0.598

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	27.7	18.5	25.8	17.8	24.0	16.9	19.5	25.8	18.5	24.4	17.6	22.8	3.4	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.2	13.4	21.8	16.4	12.7	20.7	15.6	12.0	19.8	58.5	25.8	55.3	24.6	52.4	22.8	23.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.7	8.5	7.4	-22.0	30.7	3.9	1.2	-24.8	31.6	-27.0	32.3	-29.2	33.0	-32.0	33.8		
			-22.2	21.2	3.8	1.0	-25.0	21.9	-27.2	22.5	-29.4	23.1	-32.1	23.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.7	-3.8	-2.5	1.1	6.9	11.3	14.8	16.3	16.3	11.7	7.5	2.8	-2.3
	DBStd	8.37	5.28	5.38	4.62	4.20	3.64	3.45	3.16	3.12	3.51	4.26	4.73	5.15
	HDD10.0	1921	428	350	277	109	28	3	1	1	22	101	220	382
	HDD18.3	4279	687	583	534	344	217	113	79	79	199	335	467	641
	CDD10.0	723	0	0	0	14	69	148	195	196	74	24	3	0
	CDD18.3	41	0	0	0	0	1	8	16	16	1	0	0	0
	CDH23.3	528	0	0	0	2	19	116	186	190	16	0	0	0
	CDH26.7	97	0	0	0	0	1	17	35	42	2	0	0	0
(14) Wind	WSAvg	3.0	3.7	3.4	3.3	3.0	2.7	2.6	2.5	2.3	2.6	2.9	3.2	3.9
(15) Precipitation	PrecAvg	930	49	47	58	61	102	118	140	97	89	67	57	43
	PrecMax	1282	120	112	150	110	311	182	309	182	221	146	108	92
	PrecMin	716	11	14	14	6	37	54	38	20	18	10	1	17
	PrecStd	128	28	22	29	27	54	40	69	46	48	36	24	17
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.7	10.3	15.6	22.3	25.5	28.7	29.7	30.5	25.3	20.9	15.7	11.2
		MCWB	5.5	6.0	7.9	12.7	15.6	18.6	19.1	19.0	17.2	14.3	10.6	7.9
	2%	DB	6.1	7.9	12.6	19.6	23.1	26.5	27.5	27.5	22.6	18.4	13.5	7.7
		MCWB	4.5	4.9	7.0	11.2	14.9	18.0	18.7	18.5	15.8	13.0	9.6	5.6
	5%	DB	4.3	6.1	10.1	17.0	21.1	24.4	25.4	25.4	20.6	16.4	11.7	5.4
		MCWB	2.9	3.8	5.8	10.1	14.2	17.0	17.9	17.7	14.7	12.3	8.6	3.9
	10%	DB	2.8	4.2	7.7	14.7	18.8	22.2	23.3	23.3	18.5	14.1	9.4	3.7
		MCWB	1.7	2.5	4.8	9.1	13.1	16.1	17.0	16.9	13.8	11.1	7.5	2.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	6.7	9.0	13.2	17.4	20.2	20.6	20.5	18.0	15.1	11.2	7.9
		MCDB	7.3	9.2	13.9	20.7	23.1	26.5	26.5	26.8	23.5	19.2	14.7	10.5
	2%	WB	4.7	5.4	7.6	12.0	15.8	18.8	19.4	19.2	16.6	13.6	9.9	5.8
		MCDB	5.9	7.5	11.6	18.4	21.1	24.6	25.7	25.8	21.4	17.2	12.8	7.6
	5%	WB	3.0	3.9	6.3	10.8	14.7	17.6	18.5	18.3	15.3	12.5	8.8	4.0
		MCDB	4.1	5.8	9.6	15.7	19.7	22.9	24.2	24.2	19.2	15.9	11.2	5.2
	10%	WB	1.7	2.6	4.9	9.6	13.6	16.6	17.6	17.3	14.2	11.4	7.5	2.8
		MCDB	2.6	4.1	7.5	13.8	18.1	21.3	22.3	22.4	17.8	14.1	9.4	3.7
(35) Mean Daily Temperature Range	MDBR		6.0	7.3	8.4	10.5	10.7	10.5	10.5	11.3	9.7	8.5	6.5	5.6
	5% DB	MCDBR	5.6	9.0	12.4	15.2	15.2	14.7	14.5	15.0	13.8	12.2	9.5	6.9
		MCWBR	4.5	6.2	7.6	8.1	7.8	7.2	6.8	7.0	7.5	7.3	6.2	5.1
	5% WB	MCDBR	5.3	7.7	11.1	13.4	13.4	13.1	13.2	13.6	12.0	11.3	8.5	6.5
		MCWBR	4.4	5.6	7.1	7.3	7.3	6.7	6.6	6.7	6.9	7.0	5.9	4.9
(40) Clear-Sky Solar Irradiance	taub		0.294	0.321	0.371	0.430	0.426	0.428	0.441	0.435	0.401	0.363	0.331	0.292
	taud		2.279	2.215	2.164	2.106	2.177	2.213	2.179	2.202	2.260	2.340	2.356	2.337
	Ebn at Noon		748	810	826	812	834	834	815	800	788	756	698	700
	Edh at Noon		71	97	122	145	141	137	140	130	111	86	68	60
(44) All-Sky Solar Radiation	RadAvg		0.90	1.65	2.75	4.04	4.84	5.18	5.02	4.57	3.22	1.97	1.00	0.71
	RadStd		0.15	0.25	0.44	0.48	0.63	0.52	0.58	0.43	0.49	0.28	0.14	0.08

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.57	N/A	N/A	+1.36	+0.67	+0.65	N/A	N/A	N/A
(47) Regional (46 neighbors)		+0.57	N/A	N/A	+0.92	+0.47	+0.38	-130	-183	+87

Nomenclature: See separate page