

LOMNICKY STIT, Slovakia

WMO: 119300

Lat: 49.1951N

Lon: 20.2131E

Elev: 8645

StdP: 10.65

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-7.7	-4.3	-31.8	1.3	17.6	-25.6	1.8	15.1	55.9	6.9	47.7	10.2	22.8	320	1.015

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.5	55.8	48.3	53.4	46.9	51.1	45.2	50.3	53.9	48.5	51.8	46.8	50.0	6.7	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
48.7	70.4	51.8	46.9	65.7	50.2	45.1	61.3	48.6	23.7	53.9	22.5	52.0	21.4	50.1	56.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
43.8	37.1	31.7	-13.1	60.3	4.1	2.9	-16.1	62.4	-18.5	64.1	-20.8	65.7	-23.8	67.8
			-13.7	53.5	4.1	1.8	-16.6	54.8	-19.0	55.9	-21.3	56.9	-24.3	58.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	26.9	13.3	13.1	15.8	23.9	31.9	38.3	41.5	42.0	34.8	29.2	22.3	16.0	(6)
(7)		DBStd	13.20	8.74	8.71	8.49	7.88	6.98	7.29	6.63	6.39	6.99	9.10	9.53	9.33	(7)
(8)		HDD50	8440	1137	1033	1062	782	560	354	271	256	456	645	832	1052	(8)
(9)		HDD65	13897	1602	1453	1527	1232	1025	801	729	713	906	1110	1282	1517	(9)
(10)		CDD50	19	0	0	0	0	0	3	7	9	0	0	0	0	(10)
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	14.0	17.0	16.7	16.2	13.1	11.7	11.7	12.0	10.5	12.2	13.9	15.7	17.7	(14)
(15)	Precipitation	PrecAvg	49.3	2.8	2.7	3.1	3.5	5.3	5.9	7.1	5.2	4.3	3.5	3.3	2.6	(15)
(16)		PrecMax	64.2	7.4	6.7	7.1	6.9	12.6	9.6	15.7	9.2	8.3	6.2	5.1	6.5	(16)
(17)		PrecMin	36.9	0.6	0.6	0.4	0.6	2.1	2.8	2.5	1.9	1.1	0.6	0.0	0.9	(17)
(18)		PrecStd	6.7	1.7	1.3	1.6	1.5	2.2	1.8	3.1	2.2	2.0	1.6	1.3	1.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.0	33.1	34.1	42.3	50.3	58.0	59.4	59.3	51.8	49.7	45.0	37.6	(19)
(20)			MCWB	23.9	24.9	25.5	35.4	42.7	48.4	50.7	49.5	43.8	35.9	31.8	26.4	(20)
(21)		2%	DB	31.0	29.4	31.3	38.3	46.5	54.2	55.6	55.6	48.5	46.2	39.9	33.8	(21)
(22)			MCWB	24.1	23.5	25.3	33.5	40.5	47.2	48.5	48.1	41.2	34.1	29.6	24.3	(22)
(23)		5%	DB	27.9	27.0	29.2	35.5	43.8	51.3	53.1	53.1	46.0	42.8	36.1	30.4	(23)
(24)			MCWB	23.1	22.6	24.7	31.9	39.1	45.0	47.0	46.9	39.1	33.0	29.7	24.0	(24)
(25)		10%	DB	25.2	24.7	27.0	33.1	41.3	48.5	50.5	50.6	43.8	40.3	33.7	28.0	(25)
(26)			MCWB	22.2	21.8	23.8	30.4	38.1	43.3	45.8	45.3	38.1	33.4	28.6	23.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.6	28.0	30.3	38.2	45.1	51.6	52.9	52.6	47.1	40.5	36.5	30.1	(27)
(28)			MCDWB	29.9	29.1	31.3	40.5	48.9	56.1	56.5	56.4	49.8	43.0	39.7	31.5	(28)
(29)		2%	WB	26.0	25.9	28.1	35.0	42.3	48.5	50.5	50.2	44.1	38.5	33.9	27.9	(29)
(30)			MCDWB	27.6	27.8	29.1	36.9	44.6	52.4	53.8	53.7	46.4	40.9	35.4	29.8	(30)
(31)		5%	WB	24.3	23.9	26.2	32.7	40.4	46.4	48.6	48.4	42.2	37.0	31.7	26.3	(31)
(32)			MCDWB	26.5	25.8	27.6	34.5	42.5	50.3	51.7	51.6	44.3	39.5	33.3	28.5	(32)
(33)		10%	WB	22.5	22.1	24.3	30.9	38.5	44.2	46.7	46.6	40.2	35.5	30.0	24.5	(33)
(34)			MCDWB	25.2	24.0	26.1	32.5	40.7	47.2	49.6	49.6	42.1	38.2	32.5	26.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.3	8.6	9.0	8.7	8.3	9.1	9.0	8.5	7.6	7.6	7.7	8.1	(35)
(36)			MCDBR	8.8	9.4	9.1	8.7	9.8	11.8	11.2	10.3	9.0	8.1	7.0	8.4	(36)
(37)			MCWBR	7.4	8.1	8.3	8.6	9.4	12.0	10.4	10.7	10.6	7.6	5.8	6.9	(37)
(38)		5% WB	MCDBR	9.2	9.3	8.7	8.0	9.1	11.2	10.4	9.6	8.3	7.2	7.1	8.6	(38)
(39)			MCWBR	9.3	9.3	9.0	8.3	9.1	11.3	10.0	10.1	10.0	8.2	7.6	8.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.212	0.229	0.257	0.294	0.295	0.298	0.306	0.303	0.282	0.261	0.241	0.212	(40)	
(41)		taud	2.422	2.409	2.442	2.465	2.494	2.496	2.459	2.477	2.531	2.588	2.574	2.479	(41)	
(42)		Ebn at Noon	285	303	308	304	306	305	300	298	295	287	272	271	(42)	
(43)		Edh at Noon	19	25	29	32	32	33	33	31	26	21	16	16	(43)	
(44)	All-Sky Solar Radiation	RadAvg	290	529	899	1300	1568	1675	1623	1493	1053	643	329	222	(44)	
(45)		RadStd	42	79	127	146	197	148	180	128	150	91	44	25	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.95	N/A	N/A	+1.46	+1.31	+1.31	N/A	N/A	N/A	N/A
(47)	Regional (45 neighbors)	+1.03	N/A	N/A	+1.73	+0.94	+0.79	-232	-331	+160	+70

Nomenclature: See separate page