

TELGART, Slovakia

WMO: 119380

Lat: 48.850N

Lon: 20.183E

Elev: 906

StdP: 90.90

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.0	-12.8	-19.7	0.7	-12.6	-17.1	0.9	-10.5	14.5	-7.5	13.4	-6.9	5.1	80	0.664

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	25.7	18.1	24.1	17.2	22.6	16.3	18.8	24.2	17.9	22.8	17.0	21.5	4.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.8	13.4	21.4	16.0	12.7	20.4	15.2	12.0	19.5	57.4	24.2	54.3	22.9	51.4	21.6	22.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.1	10.5	9.3	DB	-18.0	27.8	2.4	1.6	-19.7	28.9	-21.1	29.9	-22.4	30.7	-24.2	31.9	(4)
(5)			WB	-18.4	20.2	2.4	1.0	-20.1	20.9	-21.5	21.4	-22.8	22.0	-24.6	22.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.1	-4.1	-2.6	0.6	6.3	10.6	14.1	15.7	15.7	11.0	6.7	2.0	-3.1	(6)	
	DBStd	8.12	4.25	4.47	4.33	3.97	3.51	3.44	3.11	3.19	3.55	4.29	4.35	4.21	(7)	
	HDD10.0	2041	438	353	291	120	36	6	1	1	31	119	239	407	(8)	
	HDD18.3	4482	696	587	549	360	239	131	91	93	220	361	489	666	(9)	
	CDD10.0	629	0	0	0	10	54	131	178	178	61	16	1	0	(10)	
	CDD18.3	27	0	0	0	0	0	4	10	12	1	0	0	0	(11)	
	CDH23.3	217	0	0	0	0	3	40	79	91	4	0	0	0	(12)	
	CDH26.7	18	0	0	0	0	0	2	7	9	0	0	0	0	(13)	
	WSAvg	4.1	4.4	4.8	4.6	4.2	4.1	3.7	3.5	3.5	3.8	4.0	4.2	4.3	(14)	
(15) Precipitation	PrecAvg	847	46	44	48	62	95	104	118	89	68	65	62	46	(15)	
	PrecMax	1220	120	139	113	163	219	180	204	193	133	127	130	124	(16)	
	PrecMin	556	6	11	11	7	35	39	30	24	15	4	0	9	(17)	
	PrecStd	130	27	27	29	33	43	33	50	45	34	36	31	26	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.1	9.3	14.3	20.3	23.6	26.6	27.7	27.7	23.6	19.3	13.2	6.7	(19)	
		MCWB	3.8	4.9	6.8	12.1	14.8	18.7	18.5	18.3	16.0	13.3	8.9	5.0	(20)	
	2%	DB	4.2	6.9	11.6	17.6	21.1	24.6	25.5	25.7	20.8	16.9	10.7	5.1	(21)	
		MCWB	2.9	3.5	5.9	10.3	14.0	17.6	18.0	18.2	14.6	12.4	8.1	4.1	(22)	
	5%	DB	2.9	4.7	9.0	15.2	19.4	22.7	23.8	23.9	18.9	14.7	9.1	3.7	(23)	
		MCWB	1.8	2.2	4.7	9.0	13.3	16.4	17.2	17.3	13.8	11.4	7.5	2.8	(24)	
	10%	DB	1.5	3.1	6.8	13.1	17.4	20.8	22.1	22.0	17.2	12.7	7.9	2.4	(25)	
		MCWB	0.6	1.5	3.7	7.9	12.3	15.4	16.4	16.4	12.9	10.4	6.8	1.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.8	6.0	8.1	12.7	16.1	19.7	19.6	20.2	16.8	14.4	10.0	5.7	(27)	
		MCDB	5.1	8.7	12.2	19.0	21.2	25.1	25.6	25.2	21.8	17.8	12.0	6.2	(28)	
	2%	WB	3.2	4.1	6.6	11.1	14.8	18.1	18.7	18.8	15.5	12.9	8.7	4.3	(29)	
		MCDB	3.8	5.9	10.2	16.2	19.8	23.3	24.1	24.1	19.6	15.4	9.9	4.7	(30)	
	5%	WB	1.9	3.0	5.3	9.8	13.7	17.0	17.8	17.9	14.4	11.8	7.8	3.0	(31)	
		MCDB	2.7	4.3	8.3	13.8	18.3	21.6	22.5	22.7	17.9	14.1	8.9	3.5	(32)	
	10%	WB	0.7	1.8	4.0	8.6	12.7	16.1	16.9	16.9	13.4	10.7	6.8	1.7	(33)	
		MCDB	1.4	2.7	6.3	12.2	16.9	19.9	21.1	21.3	16.4	12.7	7.8	2.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.0	6.9	8.0	9.2	9.4	9.8	9.9	9.9	8.8	7.8	5.9	5.7	(35)	
		MCDBR	6.2	8.9	11.7	12.7	12.3	12.2	12.0	12.0	11.1	10.3	7.7	6.5	(36)	
	5% WB	MCWBR	4.9	6.0	7.0	6.7	6.5	6.4	5.9	5.9	6.0	6.2	5.2	5.1	(37)	
		MCWBR	5.0	7.0	10.1	11.1	11.2	11.2	11.1	11.2	10.1	9.1	6.2	5.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.278	0.303	0.344	0.399	0.393	0.395	0.408	0.405	0.374	0.345	0.317	0.279	(40)	
		taud	2.327	2.279	2.252	2.200	2.275	2.299	2.262	2.279	2.339	2.401	2.410	2.380	(41)	
	Ebn at Noon		784	844	862	846	867	866	847	832	822	787	731	736	(42)	
		Edh at Noon	69	92	113	132	128	126	129	121	103	82	65	58	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.93	1.69	2.90	4.21	5.07	5.44	5.26	4.83	3.42	2.08	1.07	0.71	(44)	
	RadStd		0.13	0.26	0.42	0.45	0.60	0.45	0.55	0.42	0.47	0.28	0.14	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	+0.78	N/A	N/A	N/A	N/A
(47) Regional (49 neighbors)		+0.57	N/A	N/A	+0.93	+0.52	+0.47	-126	-181	+89	+40

Nomenclature: See separate page