

POP RAD-GANOVCE, Slovakia

WMO: 119520

Lat: 49.033N

Lon: 20.317E

Elev: 703

StdP: 93.16

Time Zone: 1.00 (EUC)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.5	-13.5	-19.6	0.7	-15.5	-16.5	1.0	-12.0	12.4	-1.3	11.2	0.0	2.6	40	0.583

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.1	28.8	19.1	26.8	18.3	25.2	17.5	19.9	26.7	19.1	25.6	18.3	24.1	4.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.7	13.8	22.8	16.9	13.1	21.8	16.1	12.5	20.8	60.3	26.7	57.5	25.9	54.7	24.0	22.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.9	9.2	7.8	-19.5	31.3	3.7	1.6	-22.1	32.5	-24.3	33.4	-26.4	34.3	-29.1	35.5		
(5)			-19.8	21.4	3.7	0.7	-22.4	21.9	-24.6	22.3	-26.6	22.7	-29.3	23.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.6	-3.6	-2.0	2.6	8.2	12.0	16.0	17.5	17.5	13.0	7.8	3.6	-2.0
	DBStd	8.52	4.79	5.46	4.69	4.18	3.52	3.32	3.10	3.48	3.53	4.07	4.42	4.40
	HDD10.0	1762	422	334	229	82	21	0	0	1	12	95	194	373
	HDD18.3	3992	681	568	486	303	197	85	53	58	163	326	441	631
	CDD10.0	891	0	0	1	28	83	181	232	234	102	27	3	0
	CDD18.3	79	0	0	0	0	0	16	27	33	3	0	0	0
	CDH23.3	846	0	0	0	6	14	176	255	360	34	0	0	0
	CDH26.7	182	0	0	0	0	1	32	51	94	4	0	0	0
Wind	WSAvg	3.2	3.3	3.3	3.8	3.5	3.4	3.0	2.8	2.6	2.9	3.0	3.1	3.2
Precipitation	PrecAvg	601	24	25	29	44	73	88	85	73	51	42	42	27
	PrecMax	997	77	85	87	118	157	213	220	186	119	188	135	85
	PrecMin	413	0	2	3	4	4	22	8	11	3	1	0	0
	PrecStd	116	16	17	17	25	33	36	46	38	29	37	28	17
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.4	10.6	17.4	24.3	25.0	29.5	30.5	31.6	26.4	21.1	14.6	9.0
		MCWB	5.6	5.2	8.4	13.1	15.3	19.4	19.8	19.0	17.1	13.7	10.4	6.2
	2%	DB	5.4	8.0	14.7	20.9	23.0	27.4	28.0	29.4	24.0	19.1	12.7	7.0
		MCWB	4.1	4.5	7.9	12.5	14.9	18.5	19.0	18.9	16.4	13.3	9.3	5.1
	5%	DB	4.0	6.2	12.0	18.5	21.3	25.3	26.1	27.0	22.1	17.0	11.1	5.4
		MCWB	2.6	3.6	6.5	10.8	13.9	17.6	18.3	18.5	15.6	12.4	8.6	3.9
	10%	DB	2.7	4.7	9.8	16.3	19.3	23.3	24.4	25.1	19.8	14.5	9.6	3.7
		MCWB	1.4	2.6	5.6	9.8	13.2	16.7	17.5	17.9	14.4	11.1	7.8	2.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.0	6.6	9.5	14.4	16.6	21.1	20.8	20.7	18.3	14.9	11.1	6.7
		MCDB	7.0	8.9	15.0	21.2	22.2	27.4	27.4	27.4	24.3	19.3	13.3	8.6
	2%	WB	4.5	5.0	8.2	12.8	15.5	19.5	19.8	19.8	17.1	13.7	10.0	5.4
		MCDB	5.2	7.3	13.3	20.2	21.0	25.8	26.2	26.9	22.6	18.0	11.9	6.9
	5%	WB	2.8	4.0	7.1	11.7	14.6	18.1	19.1	19.1	16.1	12.6	8.9	4.0
		MCDB	3.8	5.7	11.3	17.6	19.9	23.9	25.1	25.8	21.4	16.3	10.7	5.3
	10%	WB	1.5	2.8	5.8	10.4	13.7	17.2	18.2	18.2	15.0	11.5	7.8	2.6
		MCDB	2.5	4.5	9.6	15.2	18.6	22.2	23.3	24.4	18.9	14.6	9.7	3.6
Mean Daily Temperature Range	5% DB	MDBR	6.6	7.5	9.3	10.5	10.7	10.6	11.2	12.1	10.4	9.3	6.4	6.2
		MCDBR	6.2	9.1	13.5	14.6	14.2	14.1	14.0	14.8	13.7	13.0	8.5	7.1
		MCWBR	4.9	6.3	8.0	7.3	7.1	6.7	6.5	6.3	7.0	7.7	5.8	5.6
	5% WB	MCDBR	5.7	7.7	12.3	12.7	12.6	12.7	12.8	13.6	11.8	12.1	7.1	6.9
		MCWBR	4.8	5.6	7.4	6.7	6.7	6.4	6.2	6.3	6.1	7.4	5.4	5.6
Clear-Sky Solar Irradiance	taub	0.288	0.315	0.361	0.421	0.415	0.417	0.432	0.428	0.394	0.359	0.328	0.288	
	taud	2.285	2.227	2.194	2.138	2.222	2.252	2.214	2.232	2.292	2.362	2.376	2.344	
	Ebn at Noon	762	823	840	823	846	845	825	809	799	766	709	713	
	Edh at Noon	72	97	119	141	135	132	135	127	108	85	67	60	
All-Sky Solar Radiation	RadAvg	0.92	1.68	2.87	4.15	5.01	5.36	5.19	4.78	3.38	2.06	1.06	0.70	
	RadStd	0.13	0.26	0.40	0.45	0.61	0.45	0.56	0.40	0.47	0.29	0.14	0.08	

Historical Trends

		Heating		Cooling		Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
(47) Regional (45 neighbors)		+0.57	N/A	N/A	+0.95	+0.50	+0.45	-126	-180	+88

Nomenclature: See separate page