

KOSICE, Slovakia

WMO: 119680

Lat: 48.663N

Lon: 21.241E

Elev: 758

StdP: 14.30

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.5	14.3	2.2	6.3	13.5	6.8	8.0	18.1	31.6	25.8	28.9	26.2	7.9	10	0.526

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.0	88.0	69.4	85.0	68.2	82.2	66.9	71.5	83.6	69.9	81.5	68.3	78.9	7.4	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.6	104.2	77.2	65.9	98.3	75.7	64.4	93.0	73.6	35.7	83.7	34.2	81.6	33.0	79.2	78.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.5	21.8	18.8	5.4	92.4	4.6	3.0	2.1	94.5	-0.5	96.3	-3.1	97.9	-6.4	100.1		
(5)			4.6	74.2	4.5	1.8	1.4	75.5	-1.3	76.6	-3.8	77.6	-7.1	78.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.8	28.2	32.2	40.6	51.4	59.5	65.9	69.1	68.9	59.8	50.0	40.4	30.5		
	DBStd	16.00	7.37	7.28	7.39	7.05	6.45	6.01	5.71	5.56	6.42	7.10	7.32	7.47		
	HDD50	2538	676	499	299	65	5	0	0	0	3	91	296	604		
	HDD65	5976	1141	919	756	407	191	60	26	25	179	465	738	1069		
	CDD50	2470	0	0	8	109	301	478	592	586	298	91	7	0		
	CDD65	433	0	0	0	1	22	88	152	145	25	0	0	0		
	CDH74	3798	0	0	0	21	243	756	1341	1234	201	2	0	0		
	CDH80	1098	0	0	0	1	37	195	434	396	35	0	0	0		
	WSAvg	7.0	6.7	7.5	8.5	8.2	7.7	7.3	6.6	6.5	6.7	6.1	5.8	6.2		
	PrecAvg	24.1	0.9	1.0	1.1	1.8	2.7	3.3	3.4	2.9	2.0	1.8	1.9	1.3		
(15) Precipitation	PrecMax	33.5	3.2	2.7	3.0	4.0	5.2	7.2	6.4	6.7	6.2	8.0	4.4	3.3		
	PrecMin	16.5	0.1	0.0	0.0	0.4	1.1	0.9	0.9	0.3	0.2	0.1	0.2	0.2		
	PrecStd	4.2	0.7	0.7	0.7	0.9	1.2	1.5	1.4	1.6	1.2	1.6	1.2	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.7	53.5	64.8	76.8	84.2	89.2	92.9	92.8	84.2	73.0	61.7	48.1		
		MCWB	44.2	45.3	51.3	59.2	65.4	70.3	70.1	69.6	66.3	60.0	54.2	45.3		
	2%	DB	42.9	48.4	60.7	71.9	79.9	85.2	88.1	88.0	79.1	69.0	56.3	44.8		
		MCWB	41.4	43.2	48.6	56.3	63.7	68.7	69.3	69.3	63.5	59.0	51.2	42.6		
	5%	DB	40.3	45.0	56.6	68.0	76.6	82.1	84.8	84.4	75.5	65.1	53.4	42.6		
		MCWB	38.7	41.4	47.0	54.4	62.6	67.2	68.5	67.8	62.5	57.5	49.8	40.8		
	10%	DB	37.6	42.2	52.4	64.4	72.9	78.5	81.4	80.8	71.8	61.0	50.5	40.4		
		MCWB	36.2	39.4	44.8	52.7	60.7	65.5	66.9	66.7	60.9	55.2	47.8	39.1		
	0.4%	WB	45.1	47.3	52.9	60.8	67.4	72.7	73.5	74.0	67.5	62.7	55.2	45.7		
		MCDB	46.4	52.0	61.4	74.2	79.3	85.0	86.2	85.5	80.2	69.6	59.3	47.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	41.4	44.2	50.1	58.0	65.5	70.5	71.6	71.1	65.6	60.1	52.5	43.1		
		MCDB	42.3	47.1	58.3	69.2	77.1	82.3	84.0	82.7	76.3	66.7	55.6	44.1		
	5%	WB	38.7	41.9	48.1	55.7	63.6	68.5	69.9	69.3	63.7	58.0	50.3	40.9		
		MCDB	39.7	44.2	55.3	65.3	74.4	78.7	81.4	81.1	73.1	63.8	52.5	41.9		
	10%	WB	36.4	39.4	45.7	53.8	61.6	66.8	68.3	67.6	62.0	56.0	48.2	38.8		
		MCDB	37.4	41.6	51.4	62.6	71.0	76.1	78.3	78.8	69.9	60.6	50.4	39.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.8	11.2	15.6	18.2	18.7	18.7	19.0	19.5	17.4	15.5	11.0	7.6		
		MCDBR	10.4	15.6	22.4	24.8	24.6	23.7	24.5	24.7	23.3	21.2	15.8	9.3		
		MCWBR	8.4	11.0	13.2	12.6	11.9	10.7	9.7	9.7	10.7	12.4	10.9	7.5		
		MCDBR	9.0	14.3	20.4	21.7	22.4	21.2	21.5	22.0	20.1	18.9	13.4	8.3		
	5% WB	MCWBR	7.8	10.8	12.9	11.6	11.5	10.5	9.5	9.9	9.8	11.7	9.8	7.1		
(40) Clear-Sky Solar Irradiance	taub		0.314	0.340	0.379	0.436	0.425	0.427	0.445	0.441	0.405	0.376	0.351	0.315		
	taud		2.295	2.265	2.248	2.129	2.213	2.241	2.202	2.217	2.279	2.333	2.345	2.345		
	Ebn at Noon		232	253	262	257	266	266	258	253	250	237	216	216		
	Edh at Noon		23	30	36	45	43	42	43	41	35	28	23	20		
(44) All-Sky Solar Radiation	RadAvg		296	534	937	1354	1636	1754	1697	1568	1109	673	349	222		
	RadStd		38	86	129	139	187	129	170	128	144	92	45	26		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.40	N/A	N/A	+2.05	N/A	N/A	-243	-425	+227	+103
(47)	Regional (38 neighbors)	+1.12	N/A	N/A	+1.80	+1.03	+0.88	-229	-344	+175	+77

Nomenclature: See separate page