

STROPKOV TISINEC, Slovakia

WMO: 119760

Lat: 49.217N

Lon: 21.650E

Elev: 217

StdP: 98.75

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.2	-11.8	-18.3	0.8	-14.1	-15.2	1.0	-11.0	7.4	-3.9	6.5	-3.8	1.8	340	0.492

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.8	30.6	21.2	28.9	20.4	27.2	19.4	22.2	28.8	21.2	27.4	20.2	25.9	2.1	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.0	15.0	25.6	19.0	14.1	24.2	18.1	13.4	23.0	65.9	28.9	62.2	27.2	59.0	25.9	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.4	5.4	4.8	-19.3	32.8	3.6	1.7	-21.9	34.0	-24.0	35.0	-26.0	35.9	-28.7	37.2
			-19.5	23.8	3.6	1.1	-22.1	24.6	-24.2	25.2	-26.2	25.8	-28.8	26.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.0	-2.5	-0.7	3.7	9.8	14.3	17.6	19.5	19.2	14.2	9.2	4.4	-1.0
	DBStd	8.66	4.63	4.47	4.25	3.84	3.47	3.23	3.01	2.97	3.48	3.98	4.21	4.59
	HDD10.0	1522	387	299	198	49	6	0	0	0	4	64	173	341
	HDD18.3	3549	645	533	454	257	131	51	23	24	131	283	419	599
	CDD10.0	1167	0	0	2	43	139	229	293	285	131	40	4	0
	CDD18.3	152	0	0	0	0	6	30	58	51	7	0	0	0
	CDH23.3	1724	0	0	0	14	128	348	603	549	81	1	0	0
	CDH26.7	473	0	0	0	1	18	84	185	171	14	0	0	0
Wind	WSAvg	1.9	2.0	2.2	2.4	2.3	2.1	1.9	1.7	1.6	1.7	1.6	1.8	2.0
Precipitation	PrecAvg	717	38	40	34	50	80	84	110	72	66	58	45	40
	PrecMax	1050	99	83	75	112	220	135	220	197	145	140	85	78
	PrecMin	549	15	13	10	14	39	31	11	7	14	5	2	14
	PrecStd	102	19	18	17	22	36	29	55	41	31	35	20	17
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.0	11.1	18.4	25.4	28.9	31.3	32.6	33.5	28.7	22.2	16.0	9.3
		MCWB	6.7	7.1	10.5	15.4	18.9	21.4	21.8	21.5	19.6	15.5	11.9	7.5
	2%	DB	6.2	8.4	15.5	22.5	26.6	29.1	30.6	30.6	25.6	19.8	13.5	7.5
		MCWB	5.1	5.9	9.1	13.7	17.5	20.5	21.2	21.4	17.9	14.8	10.6	6.2
	5%	DB	4.5	6.6	13.0	20.0	24.6	27.1	28.9	28.4	23.3	17.5	11.9	5.8
		MCWB	3.4	4.6	7.8	12.4	16.7	19.5	20.5	20.2	16.9	13.6	9.8	4.9
	10%	DB	3.1	5.1	10.6	17.8	22.4	25.3	26.9	26.4	21.1	15.5	10.3	4.5
		MCWB	2.2	3.5	6.7	11.2	15.7	18.5	19.6	19.2	15.8	12.5	8.7	3.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.0	7.8	11.4	16.1	19.9	23.0	23.3	23.5	20.3	16.7	12.5	7.8
		MCDB	7.5	10.2	16.5	23.8	26.2	29.7	30.0	29.9	27.3	20.1	14.4	8.8
	2%	WB	5.4	6.2	9.7	14.4	18.5	21.4	22.1	22.1	18.8	15.3	11.1	6.3
		MCDB	6.1	7.8	14.2	20.9	24.6	27.5	29.0	28.4	24.1	18.7	13.0	7.3
	5%	WB	3.6	5.0	8.3	13.1	17.4	20.3	21.1	20.9	17.5	14.0	10.0	5.0
		MCDB	4.2	6.4	12.2	18.7	23.3	25.7	27.5	27.4	22.0	17.0	11.6	5.7
	10%	WB	2.3	3.7	7.1	11.9	16.2	19.2	20.2	19.9	16.4	12.8	8.8	3.8
		MCDB	3.0	5.0	10.4	16.9	21.3	24.0	25.8	25.3	20.2	15.3	10.2	4.5
Mean Daily Temperature Range	5% DB	MDBR	5.1	6.7	9.2	11.7	12.2	11.8	11.8	12.6	10.9	9.1	6.0	4.3
		MCDBR	4.9	9.0	14.2	17.0	16.7	15.3	15.4	15.9	14.8	12.5	8.7	5.1
		MCWBR	3.9	6.3	8.4	8.8	8.3	7.6	6.9	7.2	7.6	7.5	5.9	3.9
	5% WB	MCDBR	4.2	7.9	12.6	14.9	14.7	13.5	13.9	14.5	13.3	11.3	7.4	4.7
		MCWBR	3.6	5.8	7.9	8.0	7.7	7.1	6.6	7.0	7.1	7.0	5.3	3.9
Clear-Sky Solar Irradiance	taub	0.314	0.339	0.383	0.440	0.430	0.432	0.451	0.446	0.409	0.376	0.351	0.314	
	taud	2.259	2.219	2.216	2.115	2.199	2.228	2.189	2.205	2.268	2.331	2.333	2.319	
	Ebn at Noon	720	790	817	804	832	831	807	791	782	742	672	670	
	Edh at Noon	74	98	117	144	138	135	138	130	111	88	70	62	
All-Sky Solar Radiation	RadAvg	0.91	1.67	2.84	4.09	4.97	5.29	5.14	4.76	3.34	2.04	1.05	0.69	
	RadStd	0.13	0.25	0.37	0.45	0.62	0.45	0.56	0.40	0.47	0.29	0.14	0.08	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.73	N/A	N/A	+1.62	+0.93	+0.76	-169	-264	+138	+55
Regional (35 neighbors)		+0.58	N/A	N/A	+0.97	+0.55	+0.48	-125	-182	+89	+38

Nomenclature: See separate page