

MILHOSTOV, Slovakia

WMO: 119780

Lat: 48.667N

Lon: 21.733E

Elev: 106

StdP: 100.06

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.6	-10.0	-16.2	0.9	-11.5	-13.6	1.2	-9.3	11.9	-6.2	10.7	-3.2	3.7	350	0.511

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.4	31.9	21.7	30.1	21.1	28.3	20.1	22.7	29.7	21.8	28.4	20.9	26.9	2.8	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.4	15.3	26.3	19.5	14.4	25.0	18.7	13.7	24.0	67.5	29.8	64.0	28.4	60.8	27.1	26.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.2	8.9	7.8	-15.6	34.2	3.0	1.5	-17.8	35.3	-19.6	36.2	-21.3	37.0	-23.5	38.1		
(5)			-16.0	24.3	3.0	0.9	-18.2	24.9	-19.9	25.4	-21.6	25.9	-23.8	26.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.1	-1.9	-0.2	4.9	11.1	15.7	19.1	20.8	20.8	15.7	10.1	4.8	-0.5	(6)	
(7)		DBStd	8.94	4.24	4.20	4.16	3.75	3.40	3.19	3.11	2.92	3.53	3.86	3.94	4.25	(7)	
(8)		HDD10.0	1384	369	284	162	31	2	0	0	0	1	48	161	326	(8)	
(9)		HDD18.3	3267	628	518	416	217	96	29	12	10	94	256	407	584	(9)	
(10)		CDD10.0	1416	0	0	5	64	178	272	335	335	172	51	4	0	(10)	
(11)		CDD18.3	255	0	0	0	1	13	51	88	87	16	0	0	0	(11)	
(12)		CDH23.3	2453	0	0	0	20	172	484	832	802	141	2	0	0	(12)	
(13)		CDH26.7	776	0	0	0	2	29	136	297	282	31	0	0	0	(13)	
(14)	Wind	WSAvg	3.0	2.9	3.4	3.5	3.5	3.2	2.9	2.8	2.9	2.8	2.5	2.3	2.8	(14)	
(15)	Precipitation	PrecAvg	618	29	33	29	44	70	74	89	60	58	53	41	38	(15)	
(16)		PrecMax	1016	71	74	81	106	230	142	163	152	140	120	84	78	(16)	
(17)		PrecMin	476	8	7	5	5	36	29	12	7	7	4	3	6	(17)	
(18)		PrecStd	108	16	20	18	24	38	26	44	38	29	33	20	20	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.6	12.0	19.1	26.0	29.3	32.2	34.6	34.9	29.7	23.2	16.0	8.9	(19)	
(20)			MCWB	7.2	8.2	11.2	16.8	19.4	22.3	22.0	21.9	19.6	16.3	12.3	7.4	(20)	
(21)		2%	DB	6.2	9.1	16.2	22.7	27.2	30.2	31.8	32.0	26.9	21.0	13.8	7.1	(21)	
(22)			MCWB	5.3	6.7	10.0	14.2	18.5	21.5	21.7	21.5	18.3	15.5	11.3	6.1	(22)	
(23)		5%	DB	4.7	7.2	14.0	20.6	25.3	28.1	30.0	29.7	24.7	18.5	12.0	5.9	(23)	
(24)			MCWB	3.8	5.4	8.9	13.1	17.7	20.3	21.1	20.9	17.4	14.2	10.4	5.1	(24)	
(25)		10%	DB	3.3	5.5	11.7	18.5	23.1	26.2	28.0	27.7	22.4	16.2	10.4	4.8	(25)	
(26)			MCWB	2.5	3.9	7.7	12.1	16.8	19.4	20.3	19.8	16.4	13.2	9.0	4.0	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.6	8.7	12.2	17.1	20.5	23.7	23.7	24.1	20.2	17.6	13.3	7.7	(27)	
(28)			MCDWB	8.2	11.6	16.9	25.1	27.1	30.4	30.9	30.9	27.7	21.6	15.1	8.6	(28)	
(29)		2%	WB	5.4	7.0	10.7	15.3	19.3	22.3	22.6	22.6	19.1	16.0	11.8	6.3	(29)	
(30)			MCDWB	6.0	8.6	14.9	21.3	25.7	28.8	29.8	29.3	25.4	19.8	13.4	6.9	(30)	
(31)		5%	WB	3.9	5.6	9.4	14.0	18.3	21.2	21.7	21.5	18.1	14.7	10.5	5.2	(31)	
(32)			MCDWB	4.7	7.0	13.0	18.9	24.3	26.7	28.5	28.2	23.0	17.7	11.8	5.8	(32)	
(33)		10%	WB	2.6	4.1	8.0	12.7	17.2	20.1	20.8	20.5	17.1	13.5	9.2	4.1	(33)	
(34)			MCDWB	3.2	5.3	11.3	17.3	22.2	24.9	26.7	26.7	21.4	15.9	10.3	4.7	(34)	
(35)	Mean Daily Temperature Range			MDBR	4.5	6.0	8.9	11.0	11.2	11.1	11.4	11.7	10.3	8.9	6.1	4.2	(35)
(36)		5% DB	MCDBR	5.0	8.8	13.5	15.0	15.4	14.4	14.9	15.3	13.9	12.8	9.1	5.3	(36)	
(37)			MCWBR	4.1	6.4	8.0	7.8	7.7	7.0	6.0	6.3	6.3	7.6	6.5	4.4	(37)	
(38)		5% WB	MCDWB	4.3	8.4	11.9	13.0	13.9	12.9	13.3	13.8	12.1	11.2	7.9	4.8	(38)	
(39)			MCWBR	3.7	6.4	7.5	7.2	7.3	6.6	5.9	6.4	5.9	7.0	5.9	4.2	(39)	
(40)	Clear-Sky Solar Irradiance	taub		0.322	0.346	0.386	0.441	0.430	0.432	0.450	0.446	0.409	0.380	0.357	0.322	(40)	
(41)		taud		2.276	2.248	2.232	2.119	2.206	2.236	2.194	2.208	2.272	2.324	2.328	2.323	(41)	
(42)		Ebn at Noon		720	789	817	806	834	833	809	793	785	742	673	669	(42)	
(43)		Edh at Noon		75	97	116	144	137	134	138	130	111	90	72	64	(43)	
(44)	All-Sky Solar Radiation	RadAvg		0.93	1.69	2.92	4.25	5.15	5.54	5.36	4.96	3.49	2.12	1.10	0.69	(44)	
(45)		RadStd		0.13	0.27	0.41	0.44	0.59	0.41	0.53	0.42	0.47	0.30	0.15	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.69	N/A	N/A	+1.32	N/A	N/A	-139	-209	+121	+58
(47) Regional (38 neighbors)		+0.61	N/A	N/A	+0.98	+0.56	+0.50	-126	-190	+97	+40

Nomenclature: See separate page