

KAMENICA NAD CIROCHOU, Slovakia

WMO: 119930

Lat: **48.933N**Lon: **22.000E**Elev: **584**StdP: **14.39**Time Zone: **1.00 (EUC)**Period: **95-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.8	10.4	-1.5	5.2	6.0	4.1	6.9	13.0	15.9	28.5	14.0	30.3	1.9	70	0.477

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.6	88.5	69.8	85.2	68.4	82.2	66.9	71.9	84.2	70.1	82.0	68.5	79.5	5.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.8	104.3	77.8	66.1	98.2	75.8	64.5	92.9	73.8	36.0	84.4	34.4	81.9	33.0	79.9	79.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.2	12.2	10.8	DB	-3.0	92.7	7.7	3.2	-8.6	95.0	-13.1	96.8	-17.4	98.6	-23.0	100.9	(4)
(5)			WB	-3.5	74.4	7.7	2.3	-9.1	76.1	-13.6	77.4	-17.9	78.7	-23.5	80.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.0	28.5	31.6	39.5	50.1	58.0	64.6	67.7	67.4	58.2	49.3	40.8	31.2	(6)	
	DBStd	15.63	8.91	8.50	7.76	7.04	6.43	5.90	5.68	5.39	6.32	7.37	8.13	8.78	(7)	
	HDD50	2593	668	514	331	82	10	0	0	0	6	105	293	584	(8)	
	HDD65	6164	1133	934	790	447	229	78	37	36	219	486	727	1048	(9)	
	CDD50	2229	0	0	7	85	259	439	548	538	252	84	17	0	(10)	
	CDD65	326	0	0	0	1	14	67	120	109	15	0	0	0	(11)	
	CDH74	3866	0	0	0	30	298	810	1292	1246	188	2	0	0	(12)	
	CDH80	1160	0	0	0	2	50	218	438	417	35	0	0	0	(13)	
	WSAvg	4.1	4.0	4.2	4.9	4.7	4.4	4.1	3.8	3.5	3.5	3.6	4.0	4.2	(14)	
	PrecAvg	30.2	1.6	1.7	1.5	2.1	3.0	3.2	3.9	3.1	3.1	2.4	2.3	2.1	(15)	
(16) Precipitation	PrecMax	41.9	3.6	3.3	4.4	3.9	7.6	4.8	7.5	6.6	6.9	5.3	3.5	3.6	(16)	
	PrecMin	22.8	0.6	0.7	0.6	0.5	1.4	1.4	0.4	0.4	0.8	0.1	1.0	0.9	(17)	
	PrecStd	3.9	0.7	0.7	0.9	0.9	1.5	1.1	2.1	1.5	1.4	1.5	0.8	0.7	(18)	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.3	54.4	65.3	78.4	84.6	89.5	92.8	93.8	84.0	73.2	63.6	52.8	(19)	
		MCWB	45.7	46.0	50.7	59.6	64.4	70.0	70.5	68.8	67.3	60.5	54.0	46.8	(20)	
	2%	DB	46.0	49.7	60.5	72.8	81.0	85.7	88.5	88.3	79.0	69.3	59.4	49.3	(21)	
		MCWB	42.9	44.0	48.5	56.4	63.5	68.6	70.1	70.0	64.4	59.5	52.0	45.3	(22)	
	5%	DB	42.7	46.5	56.4	68.6	77.4	82.1	84.8	84.5	75.2	65.6	56.4	45.2	(23)	
		MCWB	40.0	42.0	46.8	54.5	62.0	66.9	68.7	68.5	62.8	57.6	50.7	42.0	(24)	
	10%	DB	39.8	43.5	52.8	64.8	73.2	78.8	81.5	81.0	71.3	62.0	53.5	42.0	(25)	
		MCWB	37.6	39.8	45.0	52.5	59.9	65.3	67.3	67.0	60.8	55.2	48.7	39.7	(26)	
	0.4%	WB	46.4	47.2	52.9	60.9	67.1	72.9	74.1	74.6	68.3	62.5	55.5	47.8	(27)	
		MCDB	48.5	52.9	61.5	74.6	79.4	85.7	85.9	85.7	81.5	69.7	60.4	51.3	(28)	
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	43.4	44.6	49.9	58.0	64.8	70.5	71.8	72.0	66.0	60.2	53.3	45.3	(29)	
		MCDB	45.7	49.1	58.1	70.2	77.9	82.2	84.5	83.6	76.2	67.5	58.5	48.9	(30)	
	5%	WB	40.2	42.4	47.6	55.8	63.0	68.5	70.1	69.9	63.9	58.1	51.2	42.4	(31)	
		MCDB	42.1	45.8	55.2	66.4	74.9	79.3	82.4	81.3	72.7	64.8	55.7	45.0	(32)	
	10%	WB	37.7	40.1	45.4	53.6	61.1	66.6	68.4	68.1	61.8	55.8	49.1	39.8	(33)	
		MCDB	39.7	43.3	52.1	63.0	71.4	76.5	78.9	79.4	69.8	61.4	53.2	41.9	(34)	
(36) Mean Daily Temperature Range	5% DB	MDBR	10.5	13.3	17.0	21.4	22.7	21.9	21.6	23.2	20.4	17.5	12.4	9.0	(35)	
		MCDBR	10.0	16.7	24.4	29.6	30.6	27.8	28.0	29.2	27.0	23.8	17.0	10.9	(36)	
		MCWBR	7.6	11.6	14.4	15.2	14.7	12.9	11.8	12.7	13.8	14.4	11.1	8.2	(37)	
	5% WB	MCDBR	8.8	15.0	21.3	26.3	27.5	24.5	25.2	26.5	24.3	21.0	14.4	10.1	(38)	
		MCWBR	7.1	11.0	13.3	13.9	13.8	12.1	11.3	12.6	12.9	13.2	9.8	8.1	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.320	0.345	0.389	0.445	0.433	0.435	0.455	0.450	0.412	0.381	0.357	0.320	(40)	
	taud		2.241	2.202	2.195	2.098	2.188	2.220	2.177	2.190	2.256	2.312	2.311	2.299	(41)	
	Ebn at Noon		226	249	257	254	263	263	255	250	247	234	212	211	(42)	
	Edh at Noon		24	32	38	47	44	43	44	42	36	29	23	20	(43)	
(44) All-Sky Solar Radiation	RadAvg		289	531	904	1324	1609	1728	1677	1552	1085	665	343	217	(44)	
	RadStd		45	83	124	143	192	133	171	136	153	98	47	29	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+1.71	N/A	+1.55	N/A	N/A	+160	+70
(47) Regional (36 neighbors)		+1.08	N/A	N/A	+1.76	+0.95	+0.88	-229	-346	+169	+68

Nomenclature: See separate page