

LEBA, Poland

WMO: 121200

Lat: 54.7536N

Lon: 17.5347E

Elev: 19

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.5	16.2	5.7	7.4	13.2	10.3	9.3	17.5	40.6	42.7	36.1	41.8	5.3	180	0.650

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.9	80.3	67.0	76.1	65.6	72.8	64.5	69.3	76.4	67.5	73.2	65.8	71.1	10.7	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.0	99.3	72.7	65.3	93.5	70.8	63.7	88.3	69.0	33.5	76.6	31.9	73.2	30.6	71.3	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 31.2	26.9	23.2	DB	5.7	87.4	7.6	3.2	0.2	89.7	-4.2	91.5	-8.5	93.3	-14.0	95.6	(4)
(5)			WB	5.0	73.3	7.4	2.8	-0.3	75.3	-4.7	76.9	-8.9	78.5	-14.3	80.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.0	31.6	32.6	36.7	44.2	51.7	58.3	62.9	63.1	57.0	48.8	40.9	34.7	(6)	
	DBStd	12.82	7.75	7.28	6.16	7.03	6.84	5.30	4.83	4.52	4.84	5.72	5.87	7.33	(7)	
	HDD50	2581	569	487	413	205	57	2	0	0	5	92	276	475	(8)	
	HDD65	6675	1034	907	877	625	418	214	101	92	242	501	724	940	(9)	
	CDD50	1472	0	0	1	31	110	251	399	406	216	56	2	0	(10)	
	CDD65	89	0	0	0	1	5	13	35	32	3	0	0	0	(11)	
	CDH74	583	0	0	0	13	57	113	209	171	20	0	0	0	(12)	
	CDH80	124	0	0	0	1	7	30	49	35	2	0	0	0	(13)	
(14) Wind	WSAvg	10.5	11.8	11.9	11.2	10.1	9.8	10.4	9.7	9.1	9.4	10.2	10.4	11.8	(14)	
(15) Precipitation	PrecAvg	26.7	1.7	1.3	1.5	1.2	1.9	2.2	3.1	3.1	3.1	2.9	2.4	2.3	(15)	
	PrecMax	35.8	5.2	2.4	4.0	2.8	4.8	4.6	8.9	7.7	7.8	8.0	5.7	4.2	(16)	
	PrecMin	16.6	0.1	0.2	0.5	0.2	0.3	0.5	0.1	0.1	0.5	0.7	0.3	0.7	(17)	
	PrecStd	5.0	1.0	0.5	0.8	0.6	1.3	1.2	2.0	1.7	1.7	1.7	1.3	0.8	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.4	50.3	57.8	75.2	80.7	84.7	85.8	84.7	76.9	67.1	55.5	50.4	(19)	
		MCWB	45.3	45.6	47.7	57.7	63.8	68.8	70.3	71.2	64.3	58.5	52.3	47.4	(20)	
	2%	DB	44.8	46.1	51.4	66.2	73.3	76.6	79.6	78.5	71.6	62.0	52.5	47.3	(21)	
		MCWB	42.9	42.9	45.7	53.4	61.5	65.0	68.2	66.8	62.2	57.3	49.9	45.3	(22)	
	5%	DB	42.7	43.4	47.6	60.3	67.6	71.1	75.1	74.5	68.0	59.3	50.3	45.4	(23)	
		MCWB	41.1	41.1	43.7	50.8	58.6	62.6	66.5	65.8	61.3	55.5	48.1	43.6	(24)	
	10%	DB	40.8	41.5	44.8	55.2	63.0	67.5	71.8	71.8	65.0	57.0	48.6	43.7	(25)	
		MCWB	39.3	39.7	41.7	48.3	56.2	60.8	65.1	65.1	59.8	54.2	46.7	42.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.3	46.6	50.1	59.3	65.6	70.0	72.6	72.2	67.1	60.2	53.1	48.5	(27)	
		MCDB	47.6	49.1	54.9	73.0	76.4	81.8	81.0	80.9	73.1	63.9	54.8	49.9	(28)	
	2%	WB	43.2	43.3	46.6	54.7	62.5	66.2	69.8	69.1	63.8	57.8	50.3	45.8	(29)	
		MCDB	44.5	45.4	49.9	64.2	71.8	74.0	77.1	75.0	68.8	60.9	51.9	47.0	(30)	
	5%	WB	41.2	41.5	44.0	51.6	59.6	63.6	67.8	67.3	62.1	56.1	48.5	43.8	(31)	
		MCDB	42.6	43.1	47.1	58.6	66.2	69.9	73.4	72.4	66.3	58.8	50.0	45.1	(32)	
	10%	WB	39.5	39.8	42.0	49.0	56.7	61.4	66.0	65.8	60.4	54.5	46.9	42.1	(33)	
		MCDB	40.6	41.3	44.4	54.3	62.1	66.6	70.7	70.7	64.5	56.9	48.4	43.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.0	8.2	10.1	13.5	14.1	13.2	12.9	14.0	12.7	10.6	7.5	6.7	(35)	
		MCDBR	7.1	9.9	15.1	22.7	22.5	21.5	19.7	19.4	18.0	13.8	8.9	6.9	(36)	
	5% WB	MCWBR	6.4	7.6	10.3	12.7	12.3	12.1	10.8	10.9	10.6	9.4	7.1	6.3	(37)	
		MCWBR	6.8	9.0	13.3	19.8	20.0	19.0	16.6	16.7	15.0	12.7	8.4	6.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.315	0.341	0.365	0.406	0.400	0.395	0.422	0.417	0.379	0.362	0.345	0.312	(40)	
		taud	2.287	2.291	2.280	2.232	2.316	2.364	2.308	2.323	2.405	2.410	2.321	2.280	(41)	
	Ebn at Noon		195	232	254	259	268	271	260	253	248	223	181	168	(42)	
		Edh at Noon	18	26	32	39	38	36	38	35	29	23	18	15	(43)	
(44) All-Sky Solar Radiation	RadAvg		142	348	759	1342	1764	1881	1693	1399	990	492	192	102	(44)	
	RadStd		19	50	75	152	185	131	181	130	107	74	28	10	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-270	+110	N/A
Regional (29 neighbors)		+0.68	N/A	N/A	N/A	N/A	N/A	N/A	-227	+106	N/A

Nomenclature: See separate page