

DARLOWO, Poland

WMO: 121240

Lat: 54.4054N

Lon: 16.3516E

Elev: 5

StdP: 101.26

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.3	-9.5	-15.3	1.0	-11.3	-12.5	1.3	-8.6	12.5	4.6	11.5	4.1	2.8	100	0.593

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.9	27.9	19.6	25.8	18.8	23.9	18.3	20.9	25.5	20.0	23.9	19.1	22.6	4.4	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.5	14.2	22.6	18.6	13.4	21.6	17.7	12.7	20.8	60.6	25.7	57.1	23.9	54.3	22.7	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.3	9.1	8.1	DB	-16.8	31.7	5.1	1.8	-20.4	33.0	-23.4	34.0	-26.3	35.0	-29.9	36.3	(4)
(5)			WB	-16.6	23.0	5.0	1.1	-20.2	23.8	-23.1	24.4	-25.9	25.0	-29.5	25.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.7	-0.3	0.3	2.9	7.4	11.6	15.2	17.7	17.8	14.3	9.5	5.5	2.3	(6)	
	DBStd	7.26	4.85	4.12	3.71	3.65	3.88	3.08	2.64	2.55	2.64	3.17	2.97	4.21	(7)	
	HDD10.0	1361	321	271	222	97	24	1	0	0	2	49	136	240	(8)	
	HDD18.3	3577	579	504	480	329	213	105	44	42	124	274	384	498	(9)	
	CDD10.0	892	0	0	1	18	74	156	239	241	129	32	2	0	(10)	
	CDD18.3	66	0	0	0	0	4	10	24	24	2	0	0	0	(11)	
	CDH23.3	520	0	0	0	2	57	93	188	161	19	0	0	0	(12)	
	CDH26.7	116	0	0	0	0	11	20	48	35	2	0	0	0	(13)	
(14) Wind	WSAvg	4.0	4.7	4.3	4.0	3.9	3.5	3.6	3.5	3.4	3.8	4.1	4.4	4.9	(14)	
(15) Precipitation	PrecAvg	716	51	36	44	35	58	71	80	88	77	63	59	55	(15)	
	PrecMax	1001	145	64	98	79	101	222	167	199	184	158	105	102	(16)	
	PrecMin	577	3	2	8	10	17	0	14	12	24	15	5	15	(17)	
	PrecStd	105	31	17	24	18	20	44	42	42	36	37	26	23	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.3	10.3	16.0	22.4	28.2	29.3	30.9	30.4	25.7	19.6	13.5	11.2	(19)	
		MCWB	8.5	6.8	9.0	13.8	18.5	19.5	21.4	20.8	17.9	14.8	11.0	9.5	(20)	
	2%	DB	8.1	7.7	12.3	19.1	24.8	26.0	27.9	27.0	23.0	17.2	11.7	9.6	(21)	
		MCWB	6.8	5.7	8.3	11.7	17.1	18.2	20.2	19.5	17.2	14.2	10.1	8.1	(22)	
	5%	DB	6.8	6.3	9.7	16.5	21.4	23.4	25.3	24.9	20.8	15.5	10.7	8.1	(23)	
		MCWB	5.9	4.8	7.3	10.7	15.4	17.4	19.2	19.1	16.4	13.2	9.4	6.8	(24)	
	10%	DB	5.5	5.1	7.6	13.9	18.5	20.6	23.3	22.9	18.8	14.2	9.7	7.1	(25)	
		MCWB	4.6	4.0	5.7	9.3	13.9	16.2	18.7	18.4	15.8	12.5	8.6	6.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.0	7.7	10.9	14.7	19.9	21.0	22.5	22.1	20.0	15.9	11.4	10.1	(27)	
		MCDB	10.5	9.3	12.9	20.2	26.8	26.8	28.0	27.3	24.2	17.9	12.6	10.8	(28)	
	2%	WB	7.0	6.1	8.8	12.5	17.6	19.2	21.2	20.7	18.1	14.6	10.4	8.4	(29)	
		MCDB	7.8	7.5	11.7	17.8	23.6	24.3	25.8	24.8	20.5	16.6	11.3	9.4	(30)	
	5%	WB	5.9	4.9	7.3	11.0	16.0	17.9	20.1	19.8	17.1	13.6	9.6	7.0	(31)	
		MCDB	6.7	6.0	9.6	15.5	20.1	22.2	23.9	23.3	19.7	15.3	10.5	7.7	(32)	
	10%	WB	4.7	4.1	5.9	9.7	14.3	16.8	19.1	19.0	16.1	12.6	8.7	6.2	(33)	
		MCDB	5.4	5.0	7.4	13.4	17.8	19.9	22.4	22.1	18.7	14.0	9.6	7.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.3	5.0	6.2	8.6	8.6	8.1	7.9	8.1	7.7	6.4	4.5	4.0	(35)	
		MCDBR	3.9	6.5	9.9	13.8	13.9	13.3	12.8	12.7	11.8	8.6	5.5	4.3	(36)	
	5% WB	MCWBR	3.7	5.0	6.6	7.9	7.5	7.1	6.6	6.7	6.8	6.1	4.4	3.7	(37)	
		MCDWR	3.8	5.4	9.2	12.4	12.7	11.1	10.7	10.2	9.4	7.8	5.0	4.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.316	0.341	0.367	0.405	0.402	0.396	0.421	0.419	0.380	0.363	0.343	0.312	(40)	
		taud	2.303	2.309	2.286	2.248	2.316	2.363	2.313	2.323	2.407	2.407	2.339	2.298	(41)	
	Ebn at Noon		624	738	801	818	844	852	821	798	784	706	583	543	(42)	
		Edh at Noon	58	80	102	121	119	115	119	111	90	73	57	48	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.47	1.12	2.36	4.15	5.38	5.70	5.18	4.30	3.09	1.57	0.61	0.34	(44)	
	RadStd		0.06	0.16	0.24	0.48	0.60	0.42	0.58	0.40	0.33	0.23	0.09	0.03	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (35 neighbors)		+0.38	N/A	N/A	N/A	N/A	N/A	N/A	-130	+59	N/A	

Nomenclature: See separate page