

LEBORK, Poland

WMO: 121250

Lat: 54.5531N

Lon: 17.7569E

Elev: 134

StdP: 14.62

Time Zone: 1.00 (EUC)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.6	14.3	2.9	6.4	11.1	8.3	8.4	15.8	27.9	43.4	24.6	43.1	4.4	120	0.563

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.3	83.1	67.0	79.9	65.9	76.8	64.5	69.8	78.0	67.9	76.2	66.2	73.7	8.7	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.0	99.7	73.4	65.1	93.3	71.3	63.3	87.6	69.7	33.9	78.0	32.3	76.2	31.0	73.8	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.3	18.4	16.0	DB	1.3	89.6	9.3	4.0	-5.4	92.5	-10.9	94.8	-16.1	97.0	-22.9	99.9	(4)
(5)			WB	0.4	73.5	9.1	2.6	-6.1	75.4	-11.5	76.9	-16.6	78.3	-23.2	80.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.7	30.6	31.9	37.1	46.3	53.8	60.0	64.3	63.8	57.4	48.8	41.7	35.8		
	DBStd	13.56	8.99	8.35	7.95	6.98	7.46	5.79	5.31	5.06	5.29	6.32	5.71	7.22		
	HDD50	2505	601	507	403	155	41	1	0	0	6	98	253	440		
	HDD65	6453	1066	927	864	562	357	173	79	86	234	501	699	905		
	CDD50	1670	0	0	3	43	159	300	445	427	228	62	3	0		
	CDD65	144	0	0	0	0	10	22	58	48	6	0	0	0		
	CDH74	1320	0	0	0	13	115	271	514	357	50	0	0	0		
	CDH80	273	0	0	0	1	15	63	117	71	6	0	0	0		
(14) Wind	WSAvg	7.5	8.3	8.2	8.4	7.8	7.3	7.3	6.6	6.3	6.5	7.0	7.5	8.4		
(15) Precipitation	PrecAvg	27.1	1.8	1.4	1.5	1.2	2.2	2.5	3.2	3.0	3.0	2.6	2.4	2.2		
	PrecMax	35.2	5.4	2.4	3.8	2.9	4.7	5.4	8.3	5.7	7.4	6.7	5.1	5.0		
	PrecMin	20.0	0.2	0.2	0.4	0.1	0.5	0.0	0.6	0.5	0.6	0.6	0.3	0.8		
	PrecStd	3.9	1.1	0.6	0.9	0.7	1.1	1.3	1.7	1.3	1.6	1.5	1.3	1.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.6	50.9	61.9	75.9	82.1	86.5	88.1	86.6	79.8	69.1	56.7	52.7		
		MCWB	48.0	45.2	50.3	59.2	63.5	67.9	69.3	70.1	64.6	58.5	53.1	49.8		
	2%	DB	46.6	47.4	56.1	68.7	77.3	80.8	83.2	81.4	74.3	64.9	53.6	49.4		
		MCWB	44.5	43.6	47.0	54.5	63.1	65.7	67.6	66.9	62.3	57.6	50.4	47.0		
	5%	DB	44.1	44.4	52.0	64.4	73.0	76.8	79.9	77.8	70.4	61.4	51.5	47.2		
		MCWB	42.2	41.6	45.8	52.0	60.5	63.9	66.4	65.9	60.7	56.1	49.1	45.1		
	10%	DB	41.9	42.2	47.7	59.7	68.5	72.5	76.2	74.4	67.1	58.4	49.5	44.9		
		MCWB	40.1	39.8	43.7	49.6	57.7	61.9	64.9	64.5	59.6	54.5	47.4	43.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.5	46.9	52.3	60.0	67.7	71.6	72.6	71.8	67.4	61.0	54.0	50.5		
		MCDB	51.0	49.5	59.3	73.1	76.5	83.3	82.4	80.4	76.1	65.9	55.7	52.1		
	2%	WB	44.8	44.0	48.6	55.4	64.5	67.5	70.2	69.1	64.0	58.7	51.0	47.6		
		MCDB	46.5	46.6	53.7	66.0	74.9	77.4	78.4	77.0	70.3	63.1	52.9	49.0		
	5%	WB	42.4	41.8	46.2	52.8	61.9	65.1	68.3	67.2	62.2	56.6	49.3	45.2		
		MCDB	43.9	44.2	50.9	62.3	71.1	74.3	76.4	74.7	68.0	60.6	51.2	46.7		
	10%	WB	40.2	39.9	43.8	50.5	58.9	62.8	66.6	65.5	60.5	54.8	47.5	43.2		
		MCDB	41.8	42.1	47.3	58.0	66.7	70.7	73.3	72.5	66.1	58.1	49.3	44.8		
(35) Mean Daily Temperature Range	MDBR		7.7	9.1	12.6	18.7	19.4	18.3	17.3	16.9	15.7	12.5	8.0	6.9		
	5% DB	MCDBR	7.1	11.3	19.4	26.8	25.5	26.0	24.1	22.5	21.6	17.1	9.6	7.8		
		MCWBR	6.6	8.5	12.0	14.7	13.1	12.6	10.6	10.7	11.3	10.8	7.4	7.1		
	5% WB	MCDBR	7.2	10.9	16.5	24.2	22.3	22.8	20.5	19.7	18.3	15.1	9.3	7.8		
		MCWBR	6.9	8.7	11.1	14.0	12.3	12.4	10.3	10.5	10.5	10.1	7.6	7.5		
(40) Clear-Sky Solar Irradiance	taub		0.312	0.339	0.366	0.409	0.402	0.397	0.425	0.420	0.379	0.361	0.344	0.309		
	taud		2.265	2.267	2.262	2.208	2.289	2.335	2.277	2.296	2.385	2.403	2.315	2.269		
	Ebn at Noon		197	233	254	258	267	270	259	252	248	224	182	170		
	Edh at Noon		19	26	33	40	39	37	39	36	29	23	18	15		
(44) All-Sky Solar Radiation	RadAvg		146	351	748	1320	1722	1822	1644	1374	979	494	191	106		
	RadStd		19	50	77	154	183	137	181	131	105	74	27	11		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (27 neighbors)	+0.70	N/A	N/A	N/A	N/A	N/A	N/A	-234	+121	N/A	

Nomenclature: See separate page