

LEBORK, Poland

WMO: 121250

Lat: 54.5531N

Lon: 17.7569E

Elev: 41

StdP: 100.83

Time Zone: 1.00 (EUC)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.0	-9.8	-16.2	0.9	-11.6	-13.2	1.2	-9.0	12.5	6.3	11.0	6.2	2.0	120	0.563

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	28.4	19.4	26.6	18.8	24.9	18.0	21.0	25.6	20.0	24.5	19.0	23.2	3.9	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.4	14.2	23.0	18.4	13.3	21.8	17.4	12.5	21.0	60.9	25.5	57.4	24.5	54.1	23.2	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.5	8.2	7.1	-17.0	32.0	5.2	2.2	-20.8	33.6	-23.8	34.9	-26.7	36.1	-30.5	37.7		
			-17.5	23.1	5.1	1.4	-21.2	24.1	-24.1	24.9	-27.0	25.7	-30.7	26.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.7	-0.8	-0.1	2.8	7.9	12.1	15.5	18.0	17.7	14.1	9.4	5.4	2.1
	DBStd	7.53	5.00	4.64	4.41	3.88	4.15	3.21	2.95	2.81	2.94	3.51	3.17	4.01
	HDD10.0	1392	334	282	224	86	23	1	0	0	3	54	141	244
	HDD18.3	3585	592	515	480	312	198	96	44	48	130	278	388	503
	CDD10.0	928	0	0	2	24	88	167	247	237	127	34	2	0
	CDD18.3	80	0	0	0	0	6	12	32	27	3	0	0	0
	CDH23.3	733	0	0	0	7	64	151	286	198	28	0	0	0
	CDH26.7	152	0	0	0	1	8	35	65	39	3	0	0	0
(14) Wind	WSAvg	3.3	3.7	3.7	3.7	3.5	3.3	3.3	3.0	2.8	2.9	3.1	3.4	3.7
(15) Precipitation	PrecAvg	688	45	35	39	31	57	64	82	77	75	66	60	56
	PrecMax	893	136	62	96	74	120	138	210	146	188	171	130	128
	PrecMin	507	4	5	9	3	12	1	16	12	15	15	7	21
	PrecStd	100	28	15	22	17	29	32	42	33	40	39	32	25
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.9	10.5	16.6	24.4	27.8	30.3	31.2	30.3	26.6	20.6	13.7	11.5
		MCWB	8.9	7.4	10.2	15.1	17.5	20.0	20.7	21.2	18.1	14.7	11.7	9.9
	2%	DB	8.1	8.6	13.4	20.4	25.2	27.1	28.5	27.4	23.5	18.3	12.0	9.7
		MCWB	7.0	6.4	8.3	12.5	17.3	18.7	19.8	19.4	16.8	14.2	10.2	8.4
	5%	DB	6.7	6.9	11.1	18.0	22.8	24.9	26.6	25.4	21.3	16.3	10.8	8.4
		MCWB	5.6	5.3	7.7	11.1	15.8	17.7	19.1	18.8	16.0	13.4	9.5	7.3
	10%	DB	5.5	5.7	8.7	15.4	20.3	22.5	24.6	23.5	19.5	14.7	9.7	7.2
		MCWB	4.5	4.3	6.5	9.8	14.3	16.6	18.3	18.1	15.3	12.5	8.5	6.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	8.3	11.3	15.6	19.8	22.0	22.5	22.1	19.6	16.1	12.2	10.3
		MCDB	10.6	9.7	15.1	22.9	24.7	28.5	28.0	26.9	24.5	18.8	13.2	11.1
	2%	WB	7.1	6.7	9.2	13.0	18.0	19.7	21.2	20.6	17.8	14.8	10.6	8.7
		MCDB	8.0	8.1	12.0	18.9	23.8	25.2	25.8	25.0	21.3	17.3	11.6	9.4
	5%	WB	5.8	5.5	7.9	11.6	16.6	18.4	20.2	19.5	16.8	13.7	9.6	7.3
		MCDB	6.6	6.8	10.5	16.8	21.7	23.5	24.6	23.7	20.0	15.9	10.7	8.2
	10%	WB	4.6	4.4	6.6	10.3	15.0	17.1	19.2	18.6	15.9	12.7	8.6	6.2
		MCDB	5.4	5.6	8.5	14.4	19.3	21.5	23.0	22.5	19.0	14.5	9.6	7.1
(35) Mean Daily Temperature Range	5% DB	MDBR	4.3	5.0	7.0	10.4	10.8	10.2	9.6	9.4	8.7	7.0	4.4	3.8
		MCDBR	4.0	6.3	10.8	14.9	14.2	14.4	13.4	12.5	12.0	9.5	5.4	4.3
		MCWBR	3.7	4.7	6.7	8.2	7.3	7.0	5.9	5.9	6.3	6.0	4.1	3.9
	5% WB	MCDWR	4.0	6.0	9.2	13.4	12.4	12.7	11.4	10.9	10.1	8.4	5.2	4.3
		MCWBR	3.8	4.8	6.2	7.8	6.8	6.9	5.7	5.8	5.8	5.6	4.2	4.1
(40) Clear-Sky Solar Irradiance	taub		0.312	0.339	0.366	0.409	0.402	0.397	0.425	0.420	0.379	0.361	0.344	0.309
	taud		2.265	2.267	2.262	2.208	2.289	2.335	2.277	2.296	2.385	2.403	2.315	2.269
	Ebn at Noon		620	733	800	812	843	851	816	795	783	706	575	537
	Edh at Noon		59	83	104	125	122	118	123	114	92	73	57	48
(44) All-Sky Solar Radiation	RadAvg		0.46	1.11	2.36	4.16	5.43	5.74	5.18	4.33	3.09	1.56	0.60	0.33
	RadStd		0.06	0.16	0.24	0.48	0.58	0.43	0.57	0.41	0.33	0.23	0.09	0.03

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)	+0.39	N/A	N/A	N/A	N/A	N/A	N/A	-130	+67	N/A

Nomenclature: See separate page