

GDANSK NOWY PORT, Poland

WMO: 121400

Lat: 54.3997N

Lon: 18.6978E

Elev: 3

StdP: 101.29

Time Zone: 1.00 (EUC)

Period: 01-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.4	-10.1	-15.9	0.9	-13.0	-13.2	1.2	-9.9	17.2	1.4	14.1	2.8	4.1	200	0.621

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.5	26.0	19.5	24.1	18.6	22.7	18.4	20.8	23.6	20.0	22.5	19.3	21.8	5.2	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.8	14.5	22.4	19.0	13.8	21.7	18.2	13.1	21.2	60.2	23.8	57.5	22.6	54.9	21.9	23.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
12.5	10.7	9.2	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-15.8	30.3	4.4	1.9	-19.0	31.7	-21.6	32.8	-24.0	33.9	-27.3	35.3
			-16.2	22.2	4.1	0.8	-19.2	22.8	-21.6	23.2	-23.9	23.7	-26.8	24.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.9	-0.4	-0.2	3.3	7.3	12.2	15.8	18.8	18.7	15.2	9.6	5.3	1.1	(6)
(7)		DBStd	7.70	5.32	4.62	3.71	3.02	3.19	2.65	2.47	2.19	2.37	3.23	2.90	4.38	(7)
(8)		HDD10.0	1384	323	285	208	92	12	0	0	0	47	142	276		(8)
(9)		HDD18.3	3510	581	518	465	331	191	84	23	23	98	271	391	534	(9)
(10)		CDD10.0	999	0	0	1	11	82	174	273	268	156	34	1	0	(10)
(11)		CDD18.3	84	0	0	0	0	2	8	38	33	3	0	0	0	(11)
(12)		CDH23.3	252	0	0	0	0	17	27	118	71	19	0	0	0	(12)
(13)		CDH26.7	41	0	0	0	0	1	3	25	10	2	0	0	0	(13)
(14)	Wind	WSAvg	4.5	5.0	5.1	4.9	4.6	4.1	4.3	4.0	4.2	4.3	4.5	4.7	4.8	(14)
(15)	Precipitation	PrecAvg	569	32	26	30	30	53	59	76	65	59	52	48	39	(15)
(16)		PrecMax	726	76	47	53	76	91	137	169	134	124	118	104	68	(16)
(17)		PrecMin	388	5	3	6	1	15	10	15	10	16	13	16	14	(17)
(18)		PrecStd	80	16	10	13	18	23	32	35	33	31	29	21	15	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.4	10.7	15.0	20.4	26.1	26.5	29.7	27.8	25.9	19.4	12.4	11.2	(19)
(20)		MCWB	8.5	8.6	9.6	12.2	18.2	18.9	20.1	19.3	17.6	15.0	10.2	9.3		(20)
(21)		2%	DB	8.7	9.3	11.6	16.1	21.8	23.5	26.2	25.2	22.5	17.1	11.5	8.4	(21)
(22)		MCWB	6.6	7.6	8.0	10.4	15.7	16.7	20.4	19.2	16.4	13.7	9.6	6.8		(22)
(23)		5%	DB	7.3	7.2	10.0	13.4	19.2	21.4	24.2	23.4	20.7	15.5	10.5	7.4	(23)
(24)		MCWB	5.6	5.5	7.1	9.5	15.2	16.6	19.3	18.8	15.9	13.0	8.7	6.0		(24)
(25)		10%	DB	6.2	5.7	8.3	11.7	17.2	20.0	22.7	22.4	19.4	14.2	9.5	6.3	(25)
(26)		MCWB	4.6	4.1	6.1	8.6	13.8	15.9	18.9	18.6	15.7	12.0	8.0	5.1		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.0	9.3	10.6	12.6	19.0	19.7	22.5	21.8	19.2	16.0	10.9	9.4	(27)
(28)		MCDWB	11.4	10.3	12.9	17.6	23.0	23.5	26.5	24.5	22.0	18.5	11.9	10.9		(28)
(29)		2%	WB	6.9	7.7	8.6	11.0	17.2	18.4	21.2	20.7	18.0	14.1	9.8	7.1	(29)
(30)		MCDWB	8.4	9.4	11.1	15.0	21.4	21.8	24.6	23.0	21.0	16.2	11.2	8.1		(30)
(31)		5%	WB	5.7	5.7	7.3	10.1	15.5	17.5	20.3	20.0	16.9	13.2	8.9	6.1	(31)
(32)		MCDWB	7.1	7.1	9.5	12.8	18.8	20.6	23.1	22.1	19.8	15.2	10.2	7.2		(32)
(33)		10%	WB	4.6	4.2	6.1	9.1	13.9	16.6	19.5	19.3	16.0	12.3	8.1	5.1	(33)
(34)		MCDWB	6.0	5.5	8.1	11.4	16.7	19.3	22.1	21.6	18.9	14.0	9.2	6.2		(34)
(35)	Mean Daily Temperature Range	MDBR	4.1	4.2	4.9	5.5	6.0	5.6	5.5	5.7	6.3	5.3	3.8	3.7	(35)	
(36)		5% DB	MCDBR	4.4	4.8	7.8	9.8	10.8	8.9	8.7	8.1	9.7	7.2	4.5	4.0	(36)
(37)		MCWBR	3.8	4.0	5.0	5.7	5.8	4.7	4.3	4.2	5.1	4.5	3.5	3.5	(37)	
(38)		5% WB	MCDBR	4.3	5.0	7.2	7.9	9.6	7.6	6.5	5.9	7.7	6.6	4.3	4.0	(38)
(39)		MCWBR	3.9	4.3	5.1	5.1	5.6	4.6	4.1	3.7	4.8	4.5	3.6	3.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.311	0.340	0.367	0.411	0.401	0.398	0.430	0.421	0.380	0.362	0.346	0.310	(40)	
(41)		taud	2.283	2.290	2.285	2.215	2.311	2.353	2.282	2.310	2.402	2.430	2.331	2.290	(41)	
(42)		Ebn at Noon	628	737	802	811	844	851	812	795	785	710	579	544	(42)	
(43)		Edh at Noon	59	81	102	125	119	116	123	113	91	71	57	48	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.48	1.15	2.39	4.18	5.41	5.66	5.09	4.37	3.10	1.58	0.60	0.35	(44)	
(45)		RadStd	0.06	0.17	0.28	0.51	0.53	0.47	0.57	0.42	0.34	0.24	0.08	0.04	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (24 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-134	+67	N/A

Nomenclature: See separate page