

GDANSK LECHA WALESY, Poland

WMO: 121500

Lat: 54.3805N

Lon: 18.4719E

Elev: 454

StdP: 14.46

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.0	10.5	1.1	5.9	6.3	6.5	7.8	12.1	31.9	40.3	27.9	39.6	5.0	120	0.605

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.3	81.0	66.4	78.5	65.1	75.1	63.9	69.0	77.7	67.1	75.1	65.3	72.8	9.8	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.1	97.9	73.0	64.3	91.8	71.1	62.5	86.0	69.2	33.4	77.5	32.0	74.6	30.6	71.9	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.3	20.7	18.1	DB	-2.5	88.2	8.8	3.6	-8.8	90.8	-14.0	92.9	-19.0	95.0	-25.4	97.6	(4)
(5)			WB	-2.9	73.0	8.8	1.9	-9.2	74.4	-14.3	75.5	-19.2	76.6	-25.6	78.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.2	29.0	30.3	35.8	44.9	52.9	59.2	63.6	63.3	55.9	47.2	38.7	32.2	(6)	
	DBStd	14.12	9.22	8.85	7.48	7.25	6.92	5.54	5.11	4.84	5.28	6.34	6.61	8.48	(7)	
	HDD50	2907	650	552	441	187	45	1	0	0	10	129	340	552	(8)	
	HDD65	6978	1115	972	904	604	380	189	90	91	277	550	789	1017	(9)	
	CDD50	1510	0	0	1	32	135	278	421	412	186	44	1	0	(10)	
	CDD65	109	0	0	0	0	5	16	46	38	4	0	0	0	(11)	
	CDH74	909	0	0	0	9	61	160	371	275	33	0	0	0	(12)	
	CDH80	181	0	0	0	0	5	35	92	44	5	0	0	0	(13)	
(14) Wind	WSAvg	8.3	9.4	9.2	9.4	8.4	8.0	8.3	7.6	7.1	7.4	8.0	8.3	8.9	(14)	
(15) Precipitation	PrecAvg	21.7	1.2	0.9	0.9	1.2	1.7	2.3	2.8	2.8	1.9	2.0	2.4	1.5	(15)	
	PrecMax	30.4	2.8	2.1	1.5	3.0	3.8	4.7	8.0	6.1	3.7	6.5	4.3	3.1	(16)	
	PrecMin	12.9	0.2	0.0	0.2	0.2	0.6	0.2	0.6	0.6	0.5	0.4	1.0	0.1	(17)	
	PrecStd	4.5	0.7	0.5	0.4	0.8	1.0	1.2	1.7	1.7	0.9	1.4	0.9	0.7	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.5	49.8	59.3	74.8	80.4	84.7	87.8	84.5	78.7	67.7	55.3	50.1	(19)	
		MCWB	46.0	45.7	48.4	57.9	63.9	68.8	69.6	67.7	64.4	59.0	52.3	48.3	(20)	
	2%	DB	44.6	46.4	53.7	67.6	74.9	78.6	82.2	80.4	72.0	62.7	51.7	46.8	(21)	
		MCWB	43.0	43.1	45.2	54.6	61.9	65.0	67.5	66.1	61.6	56.5	48.8	45.3	(22)	
	5%	DB	42.4	43.1	49.8	62.3	70.1	73.8	78.0	77.0	68.2	59.2	49.7	44.7	(23)	
		MCWB	40.8	41.0	44.3	51.4	59.2	62.4	65.9	64.9	59.9	54.7	47.7	43.3	(24)	
	10%	DB	39.5	41.0	46.2	57.5	66.2	70.1	73.9	73.6	65.8	56.9	46.8	42.6	(25)	
		MCWB	38.3	38.9	42.4	48.7	56.2	60.3	64.0	63.4	58.4	53.3	45.5	41.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.4	46.3	50.7	59.9	65.6	70.2	72.1	71.1	66.7	60.4	52.7	48.9	(27)	
		MCDB	48.1	48.3	55.6	71.9	75.3	80.0	82.4	79.8	75.2	64.9	54.8	49.5	(28)	
	2%	WB	42.8	43.1	47.3	55.3	62.9	66.9	69.4	68.4	63.3	57.6	49.5	45.7	(29)	
		MCDB	43.9	45.0	51.7	63.9	73.1	76.2	78.2	76.2	69.7	61.3	50.8	46.6	(30)	
	5%	WB	40.2	41.0	44.4	52.3	60.2	63.9	67.4	66.7	61.1	55.3	47.5	43.1	(31)	
		MCDB	41.4	42.7	47.4	60.3	68.0	71.8	75.2	74.0	66.4	59.2	48.8	44.0	(32)	
	10%	WB	38.2	38.6	42.2	50.0	57.6	61.6	65.5	64.9	59.4	53.3	45.5	40.8	(33)	
		MCDB	39.3	40.4	45.2	55.7	65.1	68.9	72.8	71.7	64.5	56.7	46.8	41.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.0	9.5	12.1	17.0	18.0	17.1	16.3	16.9	14.6	11.9	7.9	7.3	(35)	
		MCDBR	7.8	10.5	18.2	25.2	24.2	23.6	23.4	22.2	20.3	16.2	9.4	7.6	(36)	
	5% WB	MCWBR	7.1	8.3	11.7	13.9	12.9	12.2	11.1	10.9	11.5	10.8	7.8	7.3	(37)	
		MCDWR	7.5	10.1	15.1	21.9	21.5	20.9	20.0	19.2	17.9	14.6	8.9	7.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.305	0.334	0.361	0.404	0.395	0.391	0.421	0.413	0.373	0.356	0.339	0.304	(40)	
		taud	2.282	2.292	2.291	2.226	2.317	2.357	2.288	2.314	2.407	2.434	2.335	2.289	(41)	
	Ebn at Noon		202	236	257	259	270	272	260	255	251	228	187	176	(42)	
		Edh at Noon	18	26	32	39	38	36	39	36	29	23	18	15	(43)	
(44) All-Sky Solar Radiation	RadAvg		153	366	759	1326	1715	1794	1614	1385	984	501	190	111	(44)	
	RadStd		20	56	89	162	170	150	182	134	108	77	24	14	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.70	N/A	N/A	N/A	N/A	N/A	-227	-272	+126	N/A
Regional (26 neighbors)		+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-241	+121	N/A

Nomenclature: See separate page