

ELBLAG-MILEJEWO, Poland

WMO: 121600

Lat: 54.2232N

Lon: 19.5435E

Elev: 607

StdP: 14.38

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.4	10.9	0.0	5.6	7.2	5.3	7.4	12.1	25.1	34.6	22.4	34.0	5.6	90	0.562

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	82.6	68.0	79.2	66.1	76.2	64.6	70.1	79.4	68.1	75.7	66.4	73.7	8.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.0	101.5	73.8	65.3	95.5	72.5	63.5	89.6	70.5	34.4	79.5	32.8	75.8	31.4	73.6	78.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.4	17.9	15.8	-0.4	89.1	9.0	2.9	-6.9	91.1	-12.1	92.8	-17.1	94.5	-23.7	96.6		
(5)			-1.2	73.6	8.6	1.8	-7.4	74.9	-12.4	76.0	-17.3	77.0	-23.5	78.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.1	28.1	30.8	36.7	46.9	54.8	60.5	64.7	64.6	57.1	47.8	39.8	32.7		
	DBStd	14.63	9.50	8.57	7.56	7.76	7.58	6.10	5.88	5.49	5.68	6.46	6.16	8.17		
	HDD50	2786	679	537	415	148	34	1	0	0	7	121	307	537		
	HDD65	6709	1144	957	878	545	331	162	79	76	245	534	756	1002		
	CDD50	1735	0	0	2	55	181	317	455	452	220	52	1	0		
	CDD65	184	0	0	0	2	14	28	69	63	8	0	0	0		
	CDH74	1169	0	0	0	21	94	200	445	365	44	0	0	0		
	CDH80	232	0	0	0	2	7	39	107	71	6	0	0	0		
	WSAvg	7.9	8.6	8.5	8.5	8.0	7.4	7.0	6.9	6.8	7.0	8.0	8.5	9.3		
	PrecAvg	26.4	1.7	1.4	1.5	1.4	2.2	2.6	3.3	3.0	2.7	2.5	2.2	2.0		
	PrecMax	32.8	3.7	2.7	2.8	3.3	3.7	5.1	6.4	5.9	7.2	5.6	4.3	3.1		
(15) Precipitation	PrecMin	18.9	0.5	0.2	0.4	0.1	0.9	0.4	0.6	0.5	0.9	0.5	0.6	0.8		
	PrecStd	3.1	0.7	0.6	0.7	0.7	0.7	1.1	1.4	1.3	1.5	1.4	1.0	0.7		
	DB	48.4	48.9	59.9	76.9	80.8	85.6	88.2	86.7	79.8	67.3	54.9	50.1			
	MCWB	45.7	45.6	48.2	60.0	64.8	69.8	70.2	70.2	64.9	58.7	51.5	48.4			
	2% DB	44.1	46.0	54.2	69.6	76.7	79.2	82.7	81.3	73.5	63.0	52.0	46.8			
(23) Mean Coincident Wet Bulb Temperatures	MCWB	42.0	42.8	46.5	56.1	62.8	65.8	68.8	67.1	62.4	56.8	49.2	45.1			
	5% DB	41.8	43.4	50.4	64.1	72.4	75.5	78.9	77.8	69.6	59.8	50.0	44.7			
	MCWB	40.1	40.7	44.6	52.6	60.2	63.6	67.2	65.5	60.5	55.2	47.8	43.1			
	10% DB	39.2	40.9	46.9	59.7	68.0	71.8	75.3	74.8	66.2	57.2	47.9	42.6			
	MCWB	37.8	38.6	42.5	50.0	57.9	62.0	65.4	64.6	58.8	53.4	45.8	41.2			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	45.9	46.8	51.2	61.8	67.0	71.3	72.8	71.8	66.5	60.4	52.8	48.5			
	MCDB	47.8	48.6	56.3	76.0	77.4	81.9	82.5	82.2	75.7	65.3	53.9	49.7			
	2% WB	42.6	43.4	47.8	57.1	64.0	67.7	70.4	69.5	64.0	57.7	49.8	45.5			
	MCDB	43.8	45.6	52.5	66.5	74.1	75.9	79.7	77.9	71.1	61.4	51.3	46.6			
	5% WB	40.1	41.0	45.2	53.6	61.6	65.2	68.6	67.6	61.8	55.9	47.9	43.3			
(31) Mean Daily Temperature Range	MCDB	41.5	43.2	49.5	62.6	70.8	73.2	76.4	74.7	67.1	59.4	49.8	44.5			
	10% WB	37.9	38.7	42.8	51.1	59.0	62.9	66.7	65.8	59.8	53.8	46.1	41.2			
	MCDB	39.2	40.7	46.2	58.2	66.6	70.0	73.4	72.5	65.2	56.6	47.7	42.5			
	5% DB	7.1	8.5	11.2	15.5	16.3	15.7	14.4	15.1	13.5	11.0	7.1	6.8			
	MCDBR	7.3	9.6	16.3	21.9	21.0	21.0	19.3	19.5	18.1	14.2	9.0	7.8			
(36) Clear-Sky Solar Irradiance	MCWBR	6.6	7.7	10.6	11.9	10.9	11.1	9.4	9.0	9.6	9.5	7.1	7.2			
	5% WB	7.2	8.9	14.3	20.1	19.1	18.8	17.4	17.2	16.2	13.1	8.6	7.7			
	MCDBR	6.5	7.8	10.2	11.8	10.6	11.1	9.5	8.9	9.6	9.4	7.3	7.3			
	taub	0.300	0.329	0.357	0.400	0.390	0.388	0.420	0.409	0.369	0.351	0.336	0.298			
	taud	2.278	2.297	2.300	2.233	2.321	2.356	2.286	2.318	2.412	2.447	2.336	2.287			
(42) All-Sky Solar Radiation	Ebn at Noon	205	239	258	261	272	273	261	256	253	231	189	180			
	Edh at Noon	19	26	32	39	37	37	39	36	29	22	18	15			
	RadAvg	161	377	769	1325	1707	1783	1609	1386	987	508	193	116			
(45)	RadStd	23	57	95	164	168	152	183	134	111	78	25	15			

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (24 neighbors)	+0.74	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-252	+126	N/A

Nomenclature: See separate page