

ELBLAG-MILEJEWO, Poland

WMO: 121600

Lat: 54.2232N

Lon: 19.5435E

Elev: 185

StdP: 99.12

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.8	-11.7	-17.8	0.8	-13.8	-14.8	1.1	-11.0	11.2	1.5	10.0	1.1	2.5	90	0.562

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.0	28.1	20.0	26.2	18.9	24.6	18.1	21.1	26.3	20.1	24.3	19.1	23.2	3.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.4	14.5	23.2	18.5	13.6	22.5	17.5	12.8	21.4	62.1	26.4	58.3	24.3	55.1	23.1	25.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.1	8.0	7.1	-18.0	31.7	5.0	1.6	-21.6	32.9	-24.5	33.8	-27.3	34.7	-30.9	35.9
			-18.4	23.1	4.8	1.0	-21.9	23.8	-24.7	24.4	-27.4	25.0	-30.8	25.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.4	-2.2	-0.7	2.6	8.3	12.6	15.8	18.2	18.1	13.9	8.8	4.3	0.4	(6)
(7)		DBStd	8.13	5.28	4.76	4.20	4.31	4.21	3.39	3.27	3.05	3.15	3.59	3.42	4.54	(7)
(8)		HDD10.0	1548	377	298	231	82	19	1	0	0	4	67	171	298	(8)
(9)		HDD18.3	3727	636	532	488	303	184	90	44	42	136	297	420	557	(9)
(10)		CDD10.0	964	0	0	1	31	101	176	253	251	122	29	1	0	(10)
(11)		CDD18.3	102	0	0	0	1	8	16	38	35	4	0	0	0	(11)
(12)		CDH23.3	649	0	0	0	12	52	111	247	203	24	0	0	0	(12)
(13)		CDH26.7	129	0	0	0	1	4	22	59	39	3	0	0	0	(13)
(14)	Wind	WSAvg	3.5	3.8	3.8	3.8	3.6	3.3	3.1	3.1	3.1	3.1	3.6	3.8	4.2	(14)
(15)	Precipitation	PrecAvg	671	43	36	37	36	56	65	83	76	68	64	56	50	(15)
(16)		PrecMax	832	94	68	71	85	95	129	162	149	182	141	108	79	(16)
(17)		PrecMin	481	12	6	11	2	22	11	14	12	23	13	15	21	(17)
(18)		PrecStd	80	19	14	17	19	19	29	36	34	39	36	25	17	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.1	9.4	15.5	24.9	27.1	29.8	31.2	30.4	26.6	19.6	12.7	10.1	(19)
(20)			MCWB	7.6	7.6	9.0	15.5	18.2	21.0	21.2	21.2	18.3	14.8	10.9	9.1	(20)
(21)		2%	DB	6.7	7.8	12.3	20.9	24.8	26.2	28.2	27.4	23.0	17.2	11.1	8.2	(21)
(22)			MCWB	5.6	6.0	8.0	13.4	17.1	18.8	20.4	19.5	16.9	13.8	9.6	7.3	(22)
(23)		5%	DB	5.5	6.4	10.2	17.8	22.5	24.1	26.1	25.5	20.9	15.5	10.0	7.0	(23)
(24)			MCWB	4.5	4.8	7.0	11.4	15.7	17.6	19.6	18.6	15.8	12.9	8.8	6.2	(24)
(25)		10%	DB	4.0	5.0	8.3	15.4	20.0	22.1	24.1	23.8	19.0	14.0	8.9	5.9	(25)
(26)			MCWB	3.2	3.7	5.8	10.0	14.4	16.7	18.5	18.1	14.9	11.9	7.6	5.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.7	8.2	10.7	16.6	19.4	21.8	22.7	22.1	19.2	15.8	11.5	9.2	(27)
(28)			MCDWB	8.8	9.2	13.5	24.4	25.2	27.7	28.0	27.9	24.3	18.5	12.1	9.8	(28)
(29)		2%	WB	5.9	6.3	8.8	14.0	17.8	19.9	21.4	20.8	17.8	14.3	9.9	7.5	(29)
(30)			MCDWB	6.6	7.6	11.4	19.2	23.4	24.4	26.5	25.5	21.7	16.4	10.7	8.1	(30)
(31)		5%	WB	4.5	5.0	7.3	12.0	16.4	18.4	20.3	19.8	16.6	13.3	8.8	6.3	(31)
(32)			MCDWB	5.3	6.2	9.7	17.0	21.5	22.9	24.7	23.7	19.5	15.2	9.9	6.9	(32)
(33)		10%	WB	3.3	3.7	6.0	10.6	15.0	17.2	19.3	18.8	15.4	12.1	7.8	5.1	(33)
(34)			MCDWB	4.0	4.8	7.9	14.6	19.2	21.1	23.0	22.5	18.4	13.7	8.7	5.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.0	4.7	6.2	8.6	9.1	8.7	8.0	8.4	7.5	6.1	4.0	3.8	(35)
(36)			MCDBR	4.1	5.3	9.0	12.2	11.7	11.7	10.7	10.8	10.1	7.9	5.0	4.3	(36)
(37)			MCWBR	3.6	4.3	5.9	6.6	6.1	6.2	5.2	5.0	5.3	5.3	4.0	4.0	(37)
(38)		5% WB	MCDWR	4.0	5.0	7.9	11.2	10.6	10.5	9.7	9.6	9.0	7.3	4.8	4.3	(38)
(39)	MCWBR		3.6	4.3	5.7	6.6	5.9	6.1	5.3	5.0	5.3	5.2	4.0	4.1	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.300	0.329	0.357	0.400	0.390	0.388	0.420	0.409	0.369	0.351	0.336	0.298	(40)	
(41)		taud	2.278	2.297	2.300	2.233	2.321	2.356	2.286	2.318	2.412	2.447	2.336	2.287	(41)	
(42)		Ebn at Noon	646	753	814	823	856	860	822	807	798	727	596	566	(42)	
(43)		Edh at Noon	59	81	100	122	118	116	122	112	90	70	57	48	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.51	1.19	2.42	4.18	5.38	5.62	5.07	4.37	3.11	1.60	0.61	0.36	(44)	
(45)		RadStd	0.07	0.18	0.30	0.52	0.53	0.48	0.58	0.42	0.35	0.25	0.08	0.05	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (24 neighbors)	+0.41	N/A	N/A	N/A	N/A	N/A	-140	+70	N/A	N/A

Nomenclature: See separate page