

KETRZYN, Poland

WMO: 121850

Lat: 54.0672N

Lon: 21.3668E

Elev: 110

StdP: 100.01

Time Zone: 1.00 (EUC)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.7	-13.5	-19.4	0.7	-16.0	-16.6	0.9	-12.7	11.7	-0.4	10.5	-0.2	2.1	100	0.569

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	28.7	20.6	26.9	19.3	25.4	18.5	21.8	26.9	20.7	25.1	19.5	23.7	4.7	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.1	15.0	24.6	19.0	14.0	23.1	18.0	13.1	21.6	64.3	26.8	60.1	25.1	56.1	23.8	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.2	8.2	7.3	DB	-19.8	32.0	4.1	1.7	-22.7	33.2	-25.1	34.1	-27.4	35.1	-30.4	36.3	(4)
(5)			WB	-20.1	23.8	3.9	1.1	-23.0	24.6	-25.3	25.2	-27.5	25.8	-30.3	26.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.3	-2.8	-2.1	2.1	8.3	13.1	16.1	18.6	18.1	14.0	8.6	4.1	0.5	(6)
(7)		DBStd	8.52	5.77	5.41	4.69	4.10	4.14	3.43	3.15	2.97	3.11	3.57	3.55	4.56	(7)
(8)		HDD10.0	1623	397	338	244	78	16	1	0	0	4	71	178	296	(8)
(9)		HDD18.3	3776	654	572	502	300	169	84	36	41	133	302	428	554	(9)
(10)		CDD10.0	998	0	0	1	29	112	183	267	252	126	27	1	0	(10)
(11)		CDD18.3	108	0	0	0	1	8	17	44	35	4	0	0	0	(11)
(12)		CDH23.3	876	0	0	0	11	72	158	354	251	29	0	0	0	(12)
(13)		CDH26.7	178	0	0	0	1	6	28	87	53	3	0	0	0	(13)
(14)	Wind	WSAvg	3.6	4.2	3.8	3.7	3.4	3.2	3.2	3.0	3.0	3.2	3.7	4.2	4.3	(14)
(15)	Precipitation	PrecAvg	624	37	32	37	36	55	73	83	77	55	51	50	38	(15)
(16)		PrecMax	854	86	59	93	93	119	144	171	197	128	143	103	71	(16)
(17)		PrecMin	460	10	9	7	3	30	18	22	14	23	2	16	10	(17)
(18)		PrecStd	81	18	13	20	21	19	29	35	37	28	34	21	15	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.2	8.9	15.6	25.0	27.5	29.9	31.6	30.7	26.5	19.8	12.6	10.1	(19)
(20)			MCWB	7.6	7.2	9.9	16.0	18.6	21.6	21.6	22.0	19.0	14.9	10.9	8.9	(20)
(21)		2%	DB	6.8	6.7	12.8	21.1	25.6	27.0	29.1	28.1	23.6	17.3	10.8	8.5	(21)
(22)			MCWB	5.9	5.0	8.2	13.2	17.8	19.2	20.8	20.6	17.2	13.8	9.6	7.3	(22)
(23)		5%	DB	5.5	5.2	10.3	18.3	23.3	25.1	27.0	26.0	21.6	15.5	9.7	7.0	(23)
(24)			MCWB	4.6	4.0	7.1	11.2	16.0	18.1	19.5	19.2	16.0	12.8	8.6	6.1	(24)
(25)		10%	DB	4.1	3.9	8.3	15.9	21.0	23.2	25.1	24.2	19.7	13.8	8.7	5.8	(25)
(26)			MCWB	3.4	2.9	5.8	9.8	15.0	17.1	18.6	18.2	15.2	12.0	7.7	5.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.8	7.0	11.3	16.2	20.3	22.7	23.2	23.0	19.9	16.1	11.3	9.1	(27)
(28)			MCD B	8.8	8.6	14.3	24.1	25.6	28.5	29.1	28.8	24.8	18.9	12.1	10.0	(28)
(29)		2%	WB	6.1	5.2	8.9	13.6	18.3	20.6	22.0	21.4	18.0	14.3	9.9	7.6	(29)
(30)			MCD B	6.8	6.4	11.6	19.5	23.6	25.2	27.2	26.0	22.3	16.4	10.6	8.3	(30)
(31)		5%	WB	4.7	4.1	7.4	11.9	17.0	19.1	20.9	20.2	16.7	13.2	8.8	6.2	(31)
(32)			MCD B	5.4	5.2	9.7	17.3	22.3	23.1	25.4	24.4	20.1	14.9	9.5	6.8	(32)
(33)		10%	WB	3.4	3.0	6.1	10.5	15.6	17.8	19.7	19.1	15.7	12.2	7.9	5.1	(33)
(34)			MCD B	4.1	3.9	8.1	14.8	20.0	22.0	23.7	22.9	18.9	13.7	8.6	5.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.3	4.8	6.8	9.8	10.3	9.9	9.6	9.4	8.4	6.5	3.9	3.6	(35)
(36)			MCDBR	4.2	5.4	9.9	13.9	13.0	12.8	12.1	11.8	11.6	8.8	5.2	4.3	(36)
(37)			MCWBR	3.9	4.4	6.4	7.4	6.4	6.4	5.0	5.5	5.8	5.6	4.3	4.0	(37)
(38)		5% WB	MCD BR	4.1	5.3	8.9	12.5	11.6	11.3	10.7	10.6	9.9	7.8	4.7	4.2	(38)
(39)			MCWBR	3.9	4.5	6.2	7.2	6.4	6.5	5.3	5.4	5.5	5.3	4.1	4.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.300	0.331	0.366	0.408	0.397	0.395	0.428	0.420	0.378	0.357	0.342	0.299	(40)	
(41)		taud	2.218	2.220	2.238	2.200	2.290	2.323	2.251	2.274	2.366	2.409	2.300	2.248	(41)	
(42)		Ebn at Noon	640	745	803	815	849	854	814	797	786	718	586	562	(42)	
(43)		Edh at Noon	62	87	107	127	122	120	126	117	94	73	59	50	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.59	1.31	2.54	4.12	5.32	5.53	5.10	4.36	3.10	1.60	0.61	0.40	(44)	
(45)		RadStd	0.10	0.22	0.40	0.54	0.51	0.48	0.57	0.42	0.39	0.27	0.07	0.04	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (21 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	-141	+70	N/A

Nomenclature: See separate page