

SWINOUJSCIE, Poland

WMO: 122000

Lat: 53.9233N

Lon: 14.2422E

Elev: 16

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.5	18.6	7.8	8.2	14.6	13.3	10.8	20.5	30.8	36.9	27.2	34.8	5.7	110	0.545

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.1	80.8	66.8	77.1	66.1	74.1	65.0	69.7	77.0	68.0	74.2	66.4	72.1	6.8	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.2	100.2	73.1	65.6	94.5	71.3	64.1	89.8	69.8	33.7	77.2	32.3	74.1	31.1	72.2	80.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.2	20.9	17.2	DB	9.5	90.3	7.5	4.6	4.1	93.6	-0.3	96.3	-4.5	98.9	-9.9	102.2	(4)
(5)			WB	8.9	73.0	7.4	2.4	3.6	74.7	-0.8	76.1	-4.9	77.4	-10.3	79.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.5	32.7	34.4	38.7	46.3	54.0	60.5	64.8	65.0	58.4	49.9	41.3	35.3		
	DBStd	13.03	7.78	7.27	6.56	6.63	5.93	5.12	4.81	4.74	4.97	5.72	5.80	7.41		
	HDD50	2294	535	437	353	149	24	0	0	0	2	74	265	455		
	HDD65	6163	1000	857	815	562	347	155	63	59	204	469	712	920		
	CDD50	1753	0	0	3	38	147	314	458	465	255	70	3	0		
	CDD65	148	0	0	0	1	5	19	56	59	8	0	0	0		
	CDH74	731	0	0	0	13	52	139	255	243	29	0	0	0		
	CDH80	162	0	0	0	2	10	40	54	54	2	0	0	0		
	WSAvg	7.3	7.4	7.4	7.9	8.1	7.6	7.3	7.3	6.4	7.0	6.9	6.7	7.2		
	PrecAvg	23.1	1.7	1.3	1.5	1.3	2.0	2.4	2.8	2.5	2.1	1.8	1.8	1.8		
(15) Precipitation	PrecMax	28.7	3.1	2.8	3.1	3.6	4.2	4.8	9.9	6.5	4.3	3.6	4.0	3.8		
	PrecMin	18.5	0.0	0.2	0.4	0.1	0.6	0.7	0.1	0.9	0.9	0.7	0.1	0.4		
	PrecStd	3.1	0.9	0.6	0.7	0.7	0.9	1.0	1.9	1.1	0.9	0.7	0.8	0.8		
	PrecStd	3.1	0.9	0.6	0.7	0.7	0.9	1.0	1.9	1.1	0.9	0.7	0.8	0.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.1	52.9	60.8	75.4	80.4	85.8	86.4	86.6	78.1	67.7	57.2	52.7		
		MCWB	47.5	48.3	50.6	57.8	63.4	67.9	68.9	70.4	64.1	59.7	54.3	50.6		
	2%	DB	47.7	49.4	54.3	66.1	72.3	77.5	79.9	79.6	73.0	63.2	53.7	49.7		
		MCWB	45.4	46.1	48.1	54.3	60.1	65.0	67.9	67.2	62.9	57.9	51.0	47.8		
	5%	DB	45.0	47.0	50.8	60.2	67.3	72.6	76.3	76.0	69.5	60.2	51.2	47.1		
		MCWB	43.0	44.0	46.1	52.1	58.6	63.1	67.1	66.1	61.5	56.3	48.9	45.0		
	10%	DB	42.7	44.5	47.9	56.1	63.6	69.3	73.3	73.3	66.5	57.9	49.1	44.6		
		MCWB	40.9	42.0	44.0	49.8	56.8	61.7	65.6	65.1	60.2	54.9	47.3	42.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.7	49.5	52.3	59.9	65.5	69.5	72.1	72.7	67.3	61.6	55.0	51.3		
		MCDB	50.4	51.6	57.6	72.4	77.0	80.1	79.9	81.2	72.9	65.5	56.7	52.2		
	2%	WB	45.6	46.9	49.1	55.9	62.1	66.6	70.1	69.6	64.5	58.8	51.4	48.0		
		MCDB	47.2	49.0	53.3	63.5	69.5	74.6	77.1	76.4	69.8	61.7	53.0	49.3		
	5%	WB	43.3	44.4	46.6	52.9	59.8	64.6	68.3	67.8	62.7	56.9	49.3	45.3		
		MCDB	44.8	46.5	50.1	58.7	65.9	70.8	74.4	73.4	67.4	59.5	50.9	46.8		
	10%	WB	41.1	41.9	44.4	50.5	57.7	62.7	66.6	66.3	61.1	55.2	47.4	43.0		
		MCDB	42.6	44.3	47.4	55.6	62.9	68.4	72.1	71.5	65.9	57.6	48.9	44.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.8	8.1	10.5	12.5	13.4	13.7	13.1	13.9	12.2	10.0	7.0	6.3		
		MCDBR	7.9	10.9	15.8	20.4	21.1	20.6	18.7	18.8	17.1	13.0	8.6	7.7		
		MCWBR	7.3	8.2	10.3	10.8	10.8	10.3	9.0	9.4	8.8	8.5	6.9	7.1		
		MCDBR	7.8	9.9	14.6	18.0	18.7	18.1	15.9	15.7	14.9	12.1	8.3	7.8		
	5% WB	MCWBR	7.4	8.4	10.3	10.4	10.5	10.2	8.7	9.4	8.7	8.4	7.1	7.4		
(40) Clear-Sky Solar Irradiance	taub		0.319	0.343	0.373	0.408	0.406	0.401	0.423	0.420	0.385	0.365	0.343	0.314		
	taud		2.329	2.326	2.275	2.245	2.310	2.351	2.302	2.318	2.392	2.398	2.366	2.321		
	Ebn at Noon		201	236	253	259	267	269	260	253	248	225	190	178		
	Edh at Noon		18	25	33	39	38	37	38	36	29	23	18	16		
(44) All-Sky Solar Radiation	RadAvg		167	373	766	1323	1676	1775	1638	1367	990	511	209	117		
	RadStd		19	56	80	168	193	134	204	113	103	73	28	11		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.68	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (44 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-268	N/A	N/A

Nomenclature: See separate page