

SZCZECIN, Poland

WMO: 122050

Lat: 53.3953N

Lon: 14.6228E

Elev: 22

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.4	16.0	5.1	7.1	12.1	10.9	9.6	17.9	24.7	40.3	22.5	40.1	5.4	90	0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.9	85.0	68.4	81.4	66.8	78.2	65.4	70.7	81.2	68.8	78.0	67.0	75.2	8.8	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.2	100.0	75.2	65.5	94.3	72.8	63.9	89.1	71.0	34.5	81.3	32.9	77.9	31.5	75.2	83.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4) 20.6	18.3	16.3		4.8	92.0	7.9	3.5	-0.9	94.6	-5.6	96.6	-10.0	98.6	-15.8	101.2	
(5)			DB	4.2	74.6	7.8	2.7	-1.4	76.6	-6.0	78.2	-10.4	79.7	-16.0	81.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.7	32.2	34.1	39.1	48.1	55.7	61.3	65.5	65.0	57.6	49.1	40.7	34.9
	DBStd	13.64	8.78	8.13	7.19	7.25	6.67	5.84	5.60	5.38	5.36	6.27	6.52	8.28
	HDD50	2326	550	445	342	119	18	1	0	0	5	93	284	469
	HDD65	6139	1015	864	802	507	298	141	62	68	228	491	730	933
	CDD50	1857	0	0	5	63	196	341	482	464	234	66	5	1
	CDD65	195	0	0	0	1	10	31	79	67	7	0	0	0
	CDH74	1807	0	0	0	21	122	327	740	531	66	0	0	0
	CDH80	465	0	0	0	2	17	85	221	133	7	0	0	0
Wind	WSAvg	7.9	9.3	9.0	8.6	8.3	7.5	7.2	6.8	6.6	7.1	7.7	8.4	9.1
Precipitation	PrecAvg	22.0	1.5	1.3	1.5	1.2	2.2	2.4	2.8	2.5	2.0	1.6	1.5	1.7
	PrecMax	29.0	3.0	2.9	2.8	3.4	3.8	5.0	7.6	6.7	4.6	4.3	4.1	3.1
	PrecMin	15.3	0.0	0.2	0.4	0.2	0.6	0.6	0.7	0.9	0.6	0.4	0.0	0.3
	PrecStd	3.1	0.8	0.6	0.7	0.7	0.9	1.2	1.6	1.2	0.9	0.9	0.7	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.1	54.7	63.3	77.3	82.4	87.6	91.2	89.2	80.7	69.5	58.4	53.7
		MCWB	48.2	48.6	51.6	60.1	65.9	69.4	71.4	70.7	66.1	61.1	54.5	50.8
	2%	DB	48.7	50.5	58.0	70.2	77.5	82.0	85.6	83.2	75.4	65.1	54.9	50.5
		MCWB	45.8	46.5	48.7	56.5	63.0	66.8	69.0	67.7	63.0	58.7	51.7	48.0
	5%	DB	46.0	48.1	53.3	66.0	73.1	77.3	81.7	79.7	71.5	61.5	52.1	48.0
		MCWB	43.8	44.7	47.4	53.8	60.3	64.9	67.6	66.4	61.7	56.7	49.3	45.6
	10%	DB	43.2	45.5	49.8	61.8	69.1	73.5	77.8	76.1	67.7	58.7	49.9	45.2
		MCWB	41.3	42.4	45.0	52.2	58.5	62.7	66.0	65.2	60.1	55.1	47.8	43.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.1	50.2	53.3	61.5	67.8	72.5	73.8	72.6	68.2	62.6	55.5	51.8
		MCDB	51.4	52.6	60.2	74.5	78.1	84.3	85.4	83.2	76.2	67.8	57.8	53.3
	2%	WB	46.3	47.5	50.4	58.1	64.5	68.8	71.0	70.0	64.7	59.4	52.0	48.5
		MCDB	48.3	49.8	55.7	67.8	74.4	78.4	82.0	79.6	72.2	63.3	54.4	50.3
	5%	WB	43.7	45.0	47.7	55.3	62.0	66.3	69.0	68.2	62.7	57.3	49.7	45.9
		MCDB	45.4	47.8	52.4	64.0	70.4	74.9	78.7	76.2	69.0	60.8	51.7	47.6
	10%	WB	41.5	42.3	45.5	52.8	59.5	63.9	67.1	66.5	61.0	55.4	47.7	43.4
		MCDB	43.1	45.2	49.4	60.2	67.1	71.6	75.5	73.6	66.6	58.5	49.5	45.0
Mean Daily Temperature Range	5% DB	MDBR	8.3	10.4	13.9	18.3	18.9	18.0	17.9	18.1	16.2	13.4	9.0	7.7
		MCDBR	9.1	12.3	20.4	26.0	25.5	24.8	25.3	24.2	23.2	17.3	11.2	9.3
		MCWBR	7.8	9.4	13.0	14.1	13.2	12.9	12.0	11.3	12.4	11.6	8.8	8.2
	5% WB	MCDBR	8.8	11.6	17.8	23.8	22.3	23.2	22.5	20.8	20.0	15.7	10.9	9.0
		MCWBR	7.9	9.6	12.2	13.6	12.5	13.1	11.6	11.2	11.6	11.1	9.0	8.3
Clear-Sky Solar Irradiance	taub	0.316	0.341	0.376	0.413	0.410	0.407	0.429	0.424	0.386	0.365	0.343	0.312	
	taud	2.310	2.302	2.250	2.207	2.259	2.296	2.250	2.273	2.357	2.379	2.362	2.314	
	Ebn at Noon	205	238	253	258	266	268	259	252	248	226	193	183	
	Edh at Noon	19	26	34	40	40	39	40	37	30	24	18	16	
All-Sky Solar Radiation	RadAvg	185	397	771	1311	1625	1713	1593	1362	993	523	218	130	
	RadStd	19	56	97	184	193	140	208	123	112	75	31	11	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	+0.67	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (37 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-275	+115	N/A

Nomenclature: See separate page