

SZCZECIN, Poland

WMO: 122050

Lat: 53.3953N

Lon: 14.6228E

Elev: 7

StdP: 101.24

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -12.0	(c) -8.9	(d) -15.0	(e) 1.0	(f) -11.0	(g) -11.7	(h) 1.4	(i) -7.8	(j) 11.0	(k) 4.6	(l) 10.1	(m) 4.5	(n) 2.4	(o) 90	(p) 0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 9.9	(c) 29.4	(d) 20.2	(e) 27.4	(f) 19.3	(g) 25.7	(h) 18.6	(i) 21.5	(j) 27.3	(k) 20.4	(l) 25.5	(m) 19.5	(n) 24.0	(o) 3.9	(p) 120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.5	14.3	24.0	18.6	13.5	22.7	17.7	12.7	21.7	62.5	27.4	58.7	25.5	55.4	24.0	28.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.2	8.2	7.3	-15.1	33.3	4.4	2.0	-18.3	34.8	-20.9	35.9	-23.3	37.0	-26.5	38.4
			-15.4	23.7	4.3	1.5	-18.6	24.8	-21.1	25.7	-23.5	26.5	-26.7	27.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.3	0.1	1.2	4.0	9.0	13.2	16.3	18.6	18.3	14.2	9.5	4.8	1.6
	DBStd	7.58	4.88	4.52	3.99	4.03	3.70	3.25	3.11	2.99	2.98	3.49	3.62	4.60
	HDD10.0	1292	306	247	190	66	10	1	0	0	3	52	158	261
	HDD18.3	3411	564	480	446	282	166	78	34	38	127	273	406	518
	CDD10.0	1032	0	0	3	35	109	189	268	258	130	37	3	1
	CDD18.3	108	0	0	0	1	6	17	44	37	4	0	0	0
	CDH23.3	1004	0	0	0	12	68	182	411	295	37	0	0	0
	CDH26.7	258	0	0	0	1	9	47	123	74	4	0	0	0
Wind	WSAvg	3.6	4.2	4.0	3.9	3.7	3.3	3.2	3.0	2.9	3.2	3.4	3.8	4.1
Precipitation	PrecAvg	558	38	32	37	31	55	60	72	63	50	40	39	42
	PrecMax	736	77	74	72	86	97	126	192	169	117	109	103	80
	PrecMin	389	1	4	9	4	16	14	19	22	14	11	1	8
	PrecStd	78	20	15	17	17	23	30	40	30	23	22	19	17
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	12.6	17.4	25.2	28.0	30.9	32.9	31.8	27.1	20.8	14.7	12.1
		MCWB	9.0	9.2	10.9	15.6	18.8	20.8	21.9	21.5	18.9	16.2	12.5	10.4
	2%	DB	9.3	10.3	14.4	21.2	25.3	27.8	29.8	28.5	24.1	18.4	12.7	10.3
		MCWB	7.7	8.1	9.3	13.6	17.2	19.4	20.5	19.8	17.2	14.8	10.9	8.9
	5%	DB	7.8	8.9	11.8	18.9	22.9	25.2	27.6	26.5	22.0	16.4	11.2	8.9
		MCWB	6.5	7.0	8.5	12.1	15.7	18.3	19.8	19.1	16.5	13.7	9.6	7.6
	10%	DB	6.2	7.5	9.9	16.5	20.6	23.0	25.5	24.5	19.8	14.8	9.9	7.3
		MCWB	5.2	5.8	7.2	11.2	14.7	17.1	18.9	18.4	15.6	12.8	8.8	6.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	10.1	11.8	16.4	19.9	22.5	23.2	22.6	20.1	17.0	13.1	11.0
		MCDB	10.8	11.4	15.7	23.6	25.6	29.1	29.7	28.5	24.5	19.9	14.3	11.8
	2%	WB	8.0	8.6	10.2	14.5	18.1	20.4	21.7	21.1	18.1	15.2	11.1	9.2
		MCDB	9.0	9.9	13.2	19.9	23.6	25.8	27.8	26.4	22.4	17.4	12.5	10.2
	5%	WB	6.5	7.2	8.7	13.0	16.7	19.1	20.6	20.1	17.1	14.1	9.9	7.7
		MCDB	7.4	8.8	11.3	17.8	21.3	23.8	25.9	24.6	20.6	16.0	10.9	8.7
	10%	WB	5.3	5.7	7.5	11.6	15.3	17.7	19.5	19.2	16.1	13.0	8.7	6.3
		MCDB	6.2	7.3	9.6	15.7	19.5	22.0	24.2	23.1	19.2	14.7	9.7	7.2
Mean Daily Temperature Range	5% DB	MDBR	4.6	5.8	7.7	10.2	10.5	10.0	9.9	10.0	9.0	7.4	5.0	4.3
		MCDBR	5.1	6.9	11.4	14.4	14.2	13.8	14.0	13.4	12.9	9.6	6.2	5.2
		MCWBR	4.3	5.2	7.2	7.8	7.3	7.2	6.6	6.3	6.9	6.4	4.9	4.5
	5% WB	MCDBR	4.9	6.4	9.9	13.2	12.4	12.9	12.5	11.5	11.1	8.7	6.1	5.0
		MCWBR	4.4	5.4	6.8	7.6	7.0	7.3	6.5	6.2	6.4	6.2	5.0	4.6
Clear-Sky Solar Irradiance	taub	0.316	0.341	0.376	0.413	0.410	0.407	0.429	0.424	0.386	0.365	0.343	0.312	
	taud	2.310	2.302	2.250	2.207	2.259	2.296	2.250	2.273	2.357	2.379	2.362	2.314	
	Ebn at Noon	647	749	797	814	838	844	816	795	782	713	610	576	
	Edh at Noon	60	83	107	127	127	123	127	118	96	77	58	51	
All-Sky Solar Radiation	RadAvg	0.58	1.25	2.43	4.13	5.12	5.40	5.02	4.29	3.13	1.65	0.69	0.41	
	RadStd	0.06	0.18	0.30	0.58	0.61	0.44	0.66	0.39	0.35	0.23	0.10	0.04	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.37	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (37 neighbors)		+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-153	+64	N/A

Nomenclature: See separate page