

SZCZECINEK, Poland

WMO: 122150

Lat: 53.715N

Lon: 16.747E

Elev: 466

StdP: 14.45

Time Zone: 1.00 (EUC)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.5	12.2	0.9	5.9	6.3	7.0	8.0	13.9	20.0	33.7	18.5	33.7	4.6	80	0.543

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.7	84.2	66.5	80.9	65.1	77.8	63.9	68.9	79.6	67.2	77.0	65.6	74.5	7.8	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.5	95.9	72.8	63.7	89.8	70.9	62.1	84.8	69.6	33.3	80.0	31.9	77.1	30.6	74.4	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
16.7	15.0	13.6	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-1.6	88.6	6.7	4.0	-6.4	91.5	-10.3	93.8	-14.1	96.1	-19.0	99.0
			-0.8	71.9	7.8	2.3	-6.4	73.6	-10.9	74.9	-15.3	76.2	-20.9	77.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.2	28.6	31.6	37.2	46.6	54.8	60.0	64.1	63.8	56.6	48.2	39.5	33.9
	DBStd	14.06	9.31	8.68	8.06	6.79	7.08	5.93	5.18	5.37	5.32	6.40	5.87	7.68
	HDD50	2684	665	516	398	142	30	1	0	0	7	109	317	499
	HDD65	6654	1130	935	861	551	325	173	82	89	258	520	766	964
	CDD50	1647	0	0	2	41	179	302	436	427	205	54	1	0
	CDD65	143	0	0	0	0	9	24	53	51	6	0	0	0
	CDH74	1601	0	0	0	3	125	314	549	541	69	0	0	0
	CDH80	370	0	0	0	0	16	75	123	146	10	0	0	0
(14) Wind	WSAvg	6.7	7.8	7.6	7.3	6.9	6.3	5.9	5.6	5.6	5.8	6.5	7.3	7.7
(15) Precipitation	PrecAvg	27.6	2.0	1.5	1.9	1.7	2.8	3.1	3.3	3.1	2.4	1.9	2.0	2.0
	PrecMax	50.9	7.0	2.9	3.9	4.6	8.8	13.8	6.1	7.9	5.7	3.8	3.8	3.8
	PrecMin	17.6	0.2	0.3	0.4	0.2	0.9	0.9	0.3	0.4	0.7	0.6	0.1	0.4
	PrecStd	9.1	1.6	0.7	1.0	1.2	1.9	2.4	1.5	1.8	1.1	1.0	0.9	1.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.8	51.1	61.7	73.3	82.2	88.0	87.3	89.6	80.8	68.3	55.4	51.8
		MCWB	45.9	47.2	50.0	56.5	63.7	68.7	67.9	68.8	65.1	58.8	53.7	49.4
	2%	DB	45.4	47.9	56.3	68.1	77.4	81.0	83.9	84.0	74.8	64.1	51.9	48.3
		MCWB	43.4	44.2	46.7	54.0	62.7	64.8	66.6	66.5	61.0	57.2	49.3	46.8
	5%	DB	42.8	44.7	51.8	64.0	73.5	77.2	80.6	80.0	70.3	60.7	49.8	45.9
		MCWB	41.3	41.8	45.7	51.5	59.7	64.0	65.3	64.9	59.6	55.3	47.8	44.0
	10%	DB	40.0	42.1	48.2	59.8	69.4	73.2	77.0	76.0	66.5	57.8	47.8	43.5
		MCWB	38.7	39.7	43.4	49.7	57.5	61.6	64.2	63.4	58.1	54.3	46.1	41.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.6	48.6	52.1	59.1	67.1	70.6	71.1	71.1	67.0	60.5	54.3	50.0
		MCDB	48.4	50.5	59.1	70.4	77.9	82.4	81.8	83.0	78.1	66.2	55.1	51.1
	2%	WB	43.8	44.9	48.4	55.7	63.9	67.0	68.8	68.8	63.3	58.3	50.1	47.3
		MCDB	45.4	47.3	53.1	65.5	74.4	77.3	79.2	79.6	71.6	62.2	51.6	48.5
	5%	WB	41.4	42.2	46.1	53.0	61.6	64.7	67.3	66.8	61.1	56.4	48.2	44.5
		MCDB	42.9	44.2	51.0	61.0	70.4	74.7	76.4	76.6	67.5	60.1	49.7	45.8
	10%	WB	38.8	39.8	43.7	50.6	59.1	62.6	65.7	64.8	59.3	54.3	46.3	42.2
		MCDB	40.0	42.0	47.8	58.3	67.6	71.2	73.9	73.6	65.0	57.5	47.9	43.6
(35) Mean Daily Temperature Range	5% DB	MDBR	7.5	9.9	14.0	18.6	20.0	19.5	18.7	19.6	16.3	13.1	7.7	7.0
		MCDBR	8.3	11.8	20.5	26.1	26.0	26.2	25.9	26.1	23.3	17.7	9.8	8.6
		MCWBR	7.4	8.9	12.9	14.3	13.2	12.9	11.2	11.4	11.7	11.2	8.6	7.7
	5% WB	MCDBR	8.3	10.3	17.6	22.3	22.4	23.5	21.2	22.7	19.9	16.2	9.7	8.5
		MCWBR	7.6	8.7	11.8	13.0	12.0	12.6	10.8	11.3	11.1	11.0	8.7	8.0
(40) Clear-Sky Solar Irradiance	taub		0.305	0.332	0.363	0.403	0.401	0.396	0.420	0.417	0.374	0.358	0.337	0.302
	taud		2.290	2.292	2.273	2.229	2.286	2.325	2.273	2.287	2.388	2.413	2.354	2.301
	Ebn at Noon		207	240	257	261	269	271	261	254	252	229	193	183
	Edh at Noon		19	26	33	39	39	38	39	37	30	23	18	16
(44) All-Sky Solar Radiation	RadAvg		179	396	779	1310	1645	1728	1595	1366	991	522	205	124
	RadStd		28	56	105	172	183	142	200	134	115	78	29	13

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-254	+119	N/A

Nomenclature: See separate page