

PILA, Poland

WMO: 122300

Lat: 53.1304N

Lon: 16.7472E

Elev: 240

StdP: 14.57

Time Zone: 1.00 (EUC)

Period: 94-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.2	10.2	0.5	5.7	4.7	6.2	7.6	11.4	16.7	41.6	14.8	37.8	2.8	60	0.520

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.1	85.3	66.4	81.9	65.2	78.9	63.9	69.1	80.2	67.5	77.5	65.9	74.7	7.0	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.7	95.8	72.1	64.1	90.4	71.1	62.5	85.2	69.8	33.3	80.2	32.1	77.5	30.8	74.4	75.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.2	12.5	11.4	DB	-2.3	90.7	7.3	3.3	-7.6	93.1	-11.8	95.1	-16.0	96.9	-21.3	99.4	(4)
(5)			WB	-2.2	71.9	7.6	1.6	-7.6	73.1	-12.1	74.0	-16.3	74.9	-21.8	76.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.1	28.4	31.7	37.3	47.2	55.4	61.1	65.6	64.2	55.9	47.4	39.2	31.3
	DBStd	14.75	9.83	8.70	7.44	7.41	7.07	6.08	6.03	5.55	5.57	6.78	6.17	8.96
	HDD50	2792	671	513	397	138	26	1	0	0	11	129	327	579
	HDD65	6709	1136	933	860	536	306	147	68	84	277	544	775	1043
	CDD50	1748	0	0	2	53	195	335	483	440	188	50	2	0
	CDD65	191	0	0	0	1	10	31	86	59	4	0	0	0
	CDH74	2004	0	0	0	31	150	378	884	500	61	0	0	0
	CDH80	491	0	0	0	3	21	89	274	97	7	0	0	0
Wind	WSAvg	5.3	5.7	5.8	6.0	5.5	5.4	5.5	5.3	4.7	4.6	4.7	5.1	5.4
Precipitation	PrecAvg	23.7	1.8	1.4	1.7	1.3	2.3	2.5	3.0	2.8	2.0	1.5	1.6	1.9
	PrecMax	30.9	3.9	3.3	3.7	3.4	5.3	5.0	6.1	5.9	5.2	4.4	4.2	3.8
	PrecMin	15.2	0.1	0.3	0.4	0.2	0.9	0.9	0.8	0.4	0.4	0.5	0.1	0.4
	PrecStd	4.0	1.0	0.7	0.9	0.7	1.1	1.1	1.4	1.3	0.9	0.9	0.8	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.7	52.6	62.4	78.1	82.8	87.7	90.5	87.4	80.6	68.7	55.9	52.1
		MCWB	47.0	48.0	50.2	58.9	64.4	69.8	68.7	67.7	63.7	60.8	53.2	50.2
	2%	DB	46.4	48.5	57.1	71.4	78.4	82.3	86.6	82.6	74.8	64.7	52.7	47.6
		MCWB	44.4	45.3	47.3	55.5	62.1	64.4	66.8	66.1	61.6	58.1	50.2	45.7
	5%	DB	43.5	45.6	52.4	65.7	74.1	78.3	82.8	79.6	70.8	61.0	50.1	44.6
		MCWB	41.7	43.0	46.6	52.5	60.2	63.3	65.9	64.9	60.3	56.3	47.8	42.9
	10%	DB	41.1	43.0	48.6	61.5	70.1	74.2	79.1	76.3	67.1	58.1	48.1	42.2
		MCWB	39.4	40.3	44.1	50.7	57.6	61.4	64.6	63.7	58.5	54.3	46.2	40.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.8	49.0	52.1	60.1	66.7	70.2	71.3	70.2	66.1	62.3	53.9	50.8
		MCDB	50.0	51.2	58.2	75.1	78.9	82.2	84.1	80.9	75.5	67.6	55.2	52.0
	2%	WB	44.5	46.0	49.5	57.1	63.8	67.3	69.3	68.5	63.6	59.1	50.5	45.7
		MCDB	46.2	48.1	54.6	68.8	74.7	77.8	81.3	78.1	71.9	63.0	52.3	47.2
	5%	WB	42.1	43.3	46.7	54.1	61.6	64.8	67.9	66.9	61.6	56.6	48.2	43.1
		MCDB	43.5	45.4	51.2	62.9	71.6	74.9	79.0	75.2	68.1	60.0	49.6	44.4
	10%	WB	39.4	40.6	44.4	51.8	59.3	62.9	66.3	65.4	59.8	54.7	46.3	41.0
		MCDB	40.9	42.7	48.5	59.6	67.8	71.3	75.3	73.0	65.5	57.8	47.9	42.1
Mean Daily Temperature Range	5% DB	MDBR	8.4	10.4	14.3	19.4	19.9	19.0	18.1	18.7	16.9	14.5	8.9	7.8
		MCDBR	9.1	12.6	22.1	27.1	26.3	25.6	24.9	24.1	24.6	18.2	11.1	9.0
		MCWBR	8.2	10.0	13.9	13.6	12.5	11.4	8.8	10.2	12.7	12.2	9.2	7.6
	5% WB	MCDBR	9.0	11.7	18.5	23.3	22.7	22.1	20.7	19.7	21.0	16.5	10.8	8.4
		MCWBR	8.4	9.9	12.7	12.6	11.7	11.1	8.8	9.8	11.9	11.7	9.4	7.6
Clear-Sky Solar Irradiance	taub	0.310	0.338	0.372	0.412	0.409	0.404	0.430	0.426	0.383	0.364	0.342	0.307	
	taud	2.295	2.296	2.255	2.203	2.263	2.302	2.246	2.264	2.362	2.391	2.355	2.313	
	Ebn at Noon	209	240	255	259	266	269	259	252	250	228	195	187	
	Edh at Noon	20	27	34	40	40	39	41	38	30	24	19	16	
All-Sky Solar Radiation	RadAvg	196	414	790	1314	1625	1703	1582	1376	1000	538	220	137	
	RadStd	30	63	110	174	182	146	201	133	121	79	31	15	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)	+0.74	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-270	+117	N/A

Nomenclature: See separate page