

GORZOW WIELKOPOLSKI, Poland

WMO: 123000

Lat: 52.7411N

Lon: 15.2772E

Elev: 73

StdP: 100.46

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.5	-9.5	-15.4	1.0	-11.9	-12.3	1.3	-8.4	8.1	4.9	7.3	4.3	2.5	110	0.501

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.3	30.1	19.5	28.2	18.8	26.4	18.2	20.9	27.5	19.9	25.9	19.1	24.5	2.7	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	13.7	23.0	17.9	12.9	22.1	17.0	12.3	21.2	60.6	27.4	57.3	25.9	54.4	24.6	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.6	5.8	5.2	DB	-14.8	33.6	4.3	2.0	-17.9	35.0	-20.4	36.1	-22.8	37.2	-25.9	38.7	(4)
(5)			WB	-15.1	22.8	4.2	0.9	-18.1	23.5	-20.6	24.0	-22.9	24.5	-26.0	25.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.5	-0.5	0.9	4.1	9.6	13.9	17.1	19.3	19.0	14.5	9.5	4.4	1.0	(6)
(7)		DBStd	8.03	5.01	4.55	4.02	4.28	3.79	3.46	3.32	3.10	3.21	3.69	3.67	4.51	(7)
(8)		HDD10.0	1337	325	254	185	58	8	0	0	0	2	56	169	279	(8)
(9)		HDD18.3	3393	583	488	441	264	146	63	27	29	122	275	417	537	(9)
(10)		CDD10.0	1137	0	0	3	46	128	214	289	279	137	39	2	0	(10)
(11)		CDD18.3	150	0	0	0	1	8	27	58	49	6	0	0	0	(11)
(12)		CDH23.3	1309	0	0	0	16	84	250	518	388	53	1	0	0	(12)
(13)		CDH26.7	361	0	0	0	2	13	69	164	104	8	0	0	0	(13)
(14)	Wind	WSAvg	2.6	2.9	2.9	3.0	2.8	2.6	2.5	2.4	2.3	2.4	2.4	2.6	2.8	(14)
(15)	Precipitation	PrecAvg	555	40	34	39	30	54	57	76	61	46	37	41	42	(15)
(16)		PrecMax	715	82	87	86	85	110	132	183	149	114	102	111	99	(16)
(17)		PrecMin	386	1	2	9	1	11	3	19	21	5	8	2	8	(17)
(18)		PrecStd	85	22	18	20	18	28	32	43	26	23	20	21	19	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.1	12.6	17.6	25.6	28.5	31.7	33.2	32.5	27.8	21.6	14.3	11.8	(19)
(20)			MCWB	8.7	9.1	11.3	15.6	18.0	20.9	20.6	20.4	18.7	16.2	11.9	10.1	(20)
(21)		2%	DB	9.0	10.3	14.6	22.0	25.9	28.6	30.4	29.3	24.7	18.7	12.4	9.6	(21)
(22)			MCWB	7.6	7.9	9.2	13.7	16.9	18.8	19.4	19.6	16.9	14.6	10.5	8.3	(22)
(23)		5%	DB	7.3	8.6	12.0	19.4	23.3	26.3	28.4	27.2	22.5	16.7	10.7	8.2	(23)
(24)			MCWB	6.0	6.6	8.5	12.2	15.6	17.8	19.0	18.6	16.3	13.6	9.3	7.0	(24)
(25)		10%	DB	5.8	7.1	10.1	17.0	21.2	23.9	26.3	25.3	20.2	14.9	9.5	6.8	(25)
(26)			MCWB	4.8	5.4	7.2	11.2	14.6	16.8	18.5	18.0	15.3	12.7	8.4	5.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.3	10.0	11.9	16.3	19.4	21.9	22.0	22.1	19.9	16.8	12.8	10.4	(27)
(28)			MCDWB	10.4	11.3	16.4	24.4	26.0	29.1	30.2	28.6	25.9	20.3	13.8	11.4	(28)
(29)		2%	WB	7.7	8.3	10.2	14.5	17.8	20.0	20.9	20.7	18.1	15.1	10.7	8.5	(29)
(30)			MCDWB	8.8	9.8	13.2	20.3	23.8	26.6	27.6	26.9	22.7	17.6	12.0	9.4	(30)
(31)		5%	WB	6.1	6.9	8.8	13.0	16.6	18.8	20.0	19.7	16.9	13.9	9.5	7.1	(31)
(32)			MCDWB	7.1	8.4	11.5	18.1	21.8	24.3	26.1	25.0	20.9	16.1	10.6	8.0	(32)
(33)		10%	WB	4.8	5.5	7.5	11.7	15.4	17.6	19.1	18.8	15.9	12.9	8.4	5.8	(33)
(34)			MCDWB	5.8	7.0	9.8	16.1	20.1	22.6	24.6	23.7	19.5	14.7	9.4	6.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.3	5.4	7.0	9.4	9.7	9.4	9.3	9.5	8.4	7.0	4.7	4.0	(35)
(36)			MCDBR	5.3	7.2	10.6	13.0	13.3	13.2	12.9	12.8	12.0	9.4	6.2	5.1	(36)
(37)			MCWBR	4.4	5.3	6.5	6.5	6.2	5.8	4.8	5.2	5.5	5.7	4.7	4.2	(37)
(38)		5% WB	MCDWB	5.3	6.7	9.5	11.5	11.9	11.9	10.8	10.9	10.4	8.6	5.9	5.0	(38)
(39)			MCWBR	4.6	5.3	6.3	6.1	6.0	6.0	4.7	5.1	5.4	5.6	4.7	4.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.315	0.341	0.376	0.416	0.412	0.409	0.431	0.427	0.385	0.365	0.343	0.310	(40)	
(41)		taud	2.323	2.313	2.250	2.198	2.256	2.291	2.243	2.264	2.358	2.383	2.373	2.339	(41)	
(42)		Ebn at Noon	664	759	802	814	839	844	816	796	788	722	625	600	(42)	
(43)		Edh at Noon	61	83	108	129	128	124	129	119	97	77	59	51	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.63	1.32	2.43	4.07	5.00	5.29	4.95	4.28	3.12	1.69	0.74	0.45	(44)	
(45)		RadStd	0.08	0.22	0.32	0.56	0.59	0.43	0.62	0.40	0.38	0.23	0.11	0.04	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (36 neighbors)	+0.38	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+61	N/A

Nomenclature: See separate page