

SLUBICE, Poland

WMO: 123100

Lat: 52.348N

Lon: 14.593E

Elev: 24

StdP: 101.04

Time Zone: 1.00 (EUC)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.6	-9.1	-15.3	1.0	-11.1	-12.2	1.3	-6.7	9.3	6.3	8.4	5.3	1.8	110	0.513

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	30.9	19.6	29.0	19.0	27.2	18.5	21.2	27.5	20.2	26.3	19.4	25.1	3.1	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.0	23.1	18.2	13.2	22.0	17.4	12.5	21.4	61.3	27.4	58.1	26.2	55.3	25.1	24.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.6	6.7	6.0	-15.9	34.3	4.7	2.0	-19.3	35.8	-22.0	37.0	-24.7	38.2	-28.1	39.6		
(5)			-16.0	23.1	4.5	0.9	-19.3	23.7	-21.9	24.2	-24.5	24.7	-27.8	25.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.8	0.0	0.8	4.5	9.8	14.0	17.5	19.5	19.0	14.7	9.8	5.3	2.4
	DBStd	7.89	5.34	4.63	4.40	4.09	3.91	3.45	3.07	3.00	3.15	3.90	3.67	4.28
	HDD10.0	1240	311	258	176	52	9	0	0	2	53	145	236	
	HDD18.3	3262	569	491	429	255	145	55	23	28	118	265	391	493
	CDD10.0	1172	0	1	4	47	131	226	294	278	141	46	4	1
	CDD18.3	154	0	0	0	1	9	31	59	47	7	0	0	0
	CDH23.3	1653	0	0	0	14	136	367	608	436	91	2	0	0
	CDH26.7	497	0	0	0	2	32	107	200	137	19	0	0	0
(14) Wind	WSAvg	2.9	3.3	3.1	3.3	3.0	2.8	2.8	2.5	2.5	2.5	2.7	2.9	3.4
(15) Precipitation	PrecAvg	510	33	26	25	33	57	56	57	54	41	43	45	40
	PrecMax	675	95	55	49	63	139	111	133	101	88	106	73	105
	PrecMin	372	9	3	8	6	19	7	5	4	4	3	15	2
	PrecStd	95	20	16	13	16	28	33	37	33	21	31	19	27
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.2	13.5	19.0	25.2	29.9	32.5	33.5	33.5	29.1	22.7	15.0	12.6
		MCWB	9.2	9.1	11.5	14.7	18.0	20.4	20.5	20.1	18.7	15.7	12.2	9.9
	2%	DB	10.0	10.6	15.7	22.2	27.2	29.5	30.8	30.4	26.1	19.9	13.0	10.6
		MCWB	8.4	7.6	9.9	13.5	17.3	19.1	19.6	19.8	17.3	14.6	10.8	8.8
	5%	DB	8.3	8.8	13.4	20.2	24.3	27.4	29.0	27.6	23.5	17.7	11.7	9.3
		MCWB	6.6	6.2	8.8	12.1	15.8	18.3	19.3	19.0	16.6	14.0	9.9	7.6
	10%	DB	6.8	7.3	11.3	18.1	21.9	25.1	26.9	25.5	21.1	15.8	10.6	8.0
		MCWB	5.4	5.2	7.6	11.5	14.5	17.5	18.7	18.3	15.5	13.0	9.1	6.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.1	10.2	12.5	16.0	19.6	22.0	22.4	22.4	20.0	16.9	12.8	10.6
		MCDB	11.4	12.0	17.2	23.6	26.6	29.0	28.9	28.9	26.7	21.0	14.5	11.9
	2%	WB	8.4	8.2	10.7	14.3	18.2	20.4	21.2	20.8	18.3	15.4	11.3	9.0
		MCDB	9.8	9.8	14.8	20.4	24.7	26.7	27.6	26.9	24.2	18.7	12.6	10.2
	5%	WB	6.8	6.5	9.3	13.2	16.9	19.1	20.3	19.9	17.2	14.3	10.2	7.8
		MCDB	8.1	8.5	12.4	19.0	22.6	25.4	26.4	25.7	21.8	17.2	11.5	9.2
	10%	WB	5.5	5.2	8.0	11.9	15.7	18.1	19.5	19.0	16.2	13.2	9.2	6.5
		MCDB	6.7	7.2	11.1	16.8	20.8	23.5	25.1	24.0	20.4	15.5	10.5	7.8
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	6.2	8.4	11.0	11.0	11.0	10.6	10.7	10.1	8.0	5.3	4.5
		MCDBR	5.4	8.7	13.2	15.1	15.2	15.2	15.0	14.8	14.6	11.0	6.5	5.4
	5% WB	MCWBR	4.3	5.9	8.0	7.6	6.7	6.5	5.7	6.2	7.0	6.6	4.8	4.3
		MCDWR	5.3	7.5	11.3	13.2	13.1	13.3	12.5	12.4	12.7	9.8	6.3	5.2
(40) Clear-Sky Solar Irradiance	taub		0.324	0.351	0.390	0.420	0.417	0.414	0.435	0.429	0.389	0.375	0.351	0.318
		taud	2.313	2.290	2.205	2.194	2.250	2.286	2.238	2.268	2.353	2.350	2.353	2.331
	Ebn at Noon		658	749	787	811	835	841	813	795	786	712	619	597
		Edh at Noon	63	86	114	130	129	125	129	119	98	81	62	53
(44) All-Sky Solar Radiation	RadAvg		0.67	1.35	2.43	4.05	4.95	5.25	4.93	4.29	3.11	1.72	0.77	0.48
	RadStd		0.09	0.24	0.32	0.56	0.58	0.42	0.61	0.40	0.40	0.23	0.12	0.05

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (38 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page