

POZNAN KRZESINY, Poland

WMO: 123260

Lat: 52.332N

Lon: 16.966E

Elev: 81

StdP: 100.36

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.1	-10.9	-17.0	0.9	-12.9	-14.0	1.1	-9.5	11.6	4.5	10.4	4.0	2.4	100	0.558

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.2	31.0	19.7	28.9	18.9	27.1	18.2	21.2	28.1	20.3	26.4	19.4	24.9	4.0	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	14.0	23.2	18.2	13.2	22.3	17.4	12.5	21.7	61.6	28.4	58.5	26.4	55.6	24.9	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.4	7.5	DB	-16.6	34.0	4.7	1.8	-20.0	35.3	-22.8	36.3	-25.4	37.3	-28.9	38.7	(4)
(5)			WB	-17.0	22.7	4.2	1.1	-20.0	23.5	-22.5	24.1	-24.8	24.7	-27.9	25.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.4	-1.2	0.1	3.9	9.6	13.9	17.7	19.7	19.3	14.5	9.2	4.7	1.3
	DBStd	8.31	5.43	4.97	4.56	3.99	3.84	3.23	3.15	2.90	3.18	3.85	3.44	4.50
	HDD10.0	1376	348	278	192	54	9	0	0	0	2	62	160	271
	HDD18.3	3406	606	511	447	261	147	50	21	23	121	282	408	529
	CDD10.0	1173	0	0	4	43	129	230	301	289	138	38	1	0
	CDD18.3	163	0	0	0	1	8	30	64	54	7	0	0	0
	CDH23.3	1643	0	0	0	17	117	322	618	489	79	1	0	0
	CDH26.7	478	0	0	0	3	22	87	209	140	17	0	0	0
Wind	WSAvg	3.6	4.0	3.9	4.0	3.8	3.5	3.4	3.4	3.2	3.3	3.4	3.5	3.9
Precipitation	PrecAvg	546	36	30	39	31	53	61	84	58	43	35	35	39
	PrecMax	721	75	64	82	79	107	115	187	147	110	94	99	99
	PrecMin	362	4	6	9	7	11	6	14	10	7	6	1	7
	PrecStd	85	19	14	19	18	25	31	46	29	24	23	18	20
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.5	12.6	18.2	25.4	29.0	32.1	33.2	33.2	29.0	22.3	14.7	11.8
		MCWB	8.9	9.0	11.5	15.0	18.4	20.8	20.6	21.4	19.1	16.1	11.8	9.3
	2%	DB	8.9	10.0	15.0	22.3	26.7	29.1	31.3	30.1	25.4	19.3	12.5	9.7
		MCWB	7.0	7.2	9.4	13.6	17.3	19.2	19.5	19.7	17.4	14.5	10.5	8.1
	5%	DB	7.2	8.2	12.8	19.7	24.0	26.9	29.1	28.0	23.3	17.2	11.0	8.4
		MCWB	5.7	5.7	8.7	12.3	16.0	17.6	18.8	19.1	16.2	13.7	9.2	7.0
	10%	DB	5.7	6.5	10.8	17.5	21.7	24.8	26.9	26.1	21.0	15.2	9.8	6.9
		MCWB	4.4	4.6	7.4	11.0	14.6	16.6	18.4	18.2	15.2	12.6	8.5	5.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	9.7	12.1	16.1	19.7	22.2	22.2	22.3	19.9	16.7	12.2	9.7
		MCDB	11.1	11.6	16.8	23.5	26.1	29.2	29.4	29.9	27.2	20.8	14.0	10.8
	2%	WB	7.2	7.6	10.3	14.5	18.2	20.4	21.1	21.1	18.3	15.1	10.7	8.3
		MCDB	8.8	9.7	13.8	20.7	24.5	27.3	27.7	27.8	23.8	18.4	12.0	9.4
	5%	WB	5.8	5.9	9.0	13.0	16.9	19.0	20.2	20.2	17.0	14.0	9.7	7.0
		MCDB	7.1	7.8	12.2	18.7	22.6	24.7	26.4	25.6	21.5	16.8	10.8	8.2
	10%	WB	4.4	4.6	7.8	11.6	15.5	17.9	19.3	19.2	15.9	12.8	8.5	5.8
		MCDB	5.6	6.4	10.5	16.7	20.5	22.2	24.9	23.7	19.8	15.2	9.6	6.9
Mean Daily Temperature Range	5% DB	MDBR	4.7	5.9	8.0	10.8	10.7	10.6	10.2	10.7	9.8	8.0	5.4	4.6
		MCDBR	5.3	7.9	12.0	14.9	14.7	14.5	14.4	14.4	14.0	11.5	7.6	5.3
		MCWBR	4.3	5.8	7.5	8.0	6.9	6.2	5.1	6.1	6.8	7.1	5.8	4.4
	5% WB	MCDBR	5.2	7.8	10.9	13.7	13.1	12.2	12.1	11.8	12.0	10.3	7.5	5.1
		MCWBR	4.4	6.0	7.0	7.5	6.7	6.2	5.3	5.6	6.4	6.8	6.1	4.4
Clear-Sky Solar Irradiance	taub	0.316	0.343	0.378	0.421	0.416	0.412	0.438	0.431	0.390	0.368	0.345	0.311	
	taud	2.300	2.292	2.233	2.167	2.231	2.272	2.215	2.242	2.330	2.362	2.349	2.323	
	Ebn at Noon	667	759	801	810	835	842	810	793	784	721	627	606	
	Edh at Noon	64	86	110	133	131	127	133	123	100	80	62	53	
All-Sky Solar Radiation	RadAvg	0.68	1.36	2.51	4.16	5.11	5.36	5.00	4.41	3.19	1.75	0.78	0.49	
	RadStd	0.10	0.23	0.33	0.54	0.58	0.48	0.61	0.40	0.40	0.24	0.11	0.06	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (29 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+59	N/A

Nomenclature: See separate page