

POZNAN LAWICA, Poland

WMO: 123300

Lat: 52.4167N

Lon: 16.8347E

Elev: 289

StdP: 14.54

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 7.8	(c) 13.5	(d) 2.8	(e) 6.4	(f) 9.2	(g) 8.2	(h) 8.5	(i) 15.5	(j) 27.6	(k) 40.9	(l) 24.2	(m) 39.2	(n) 6.1	(o) 80	(p) 0.557

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 18.4	(c) 87.4	(d) 67.1	(e) 83.9	(f) 65.9	(g) 80.6	(h) 64.6	(i) 69.7	(j) 82.2	(k) 68.1	(l) 79.5	(m) 66.6	(n) 76.7	(o) 8.4	(p) 150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.0	96.9	72.8	64.4	91.4	71.7	62.8	86.4	70.7	33.8	82.1	32.5	79.8	31.3	76.6	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 21.7	(b) 18.9	(c) 16.7	(e) 2.9	(f) 93.2	(g) 7.7	(h) 3.2	(i) -2.7	(j) 95.5	(k) -7.2	(l) 97.4	(m) -11.6	(n) 99.2	(o) -17.2	(p) 101.5		
(4) 21.7	(5) 18.9	(6) 16.7	(7) 2.9	(8) 93.2	(9) 7.7	(10) 3.2	(11) -2.7	(12) 95.5	(13) -7.2	(14) 97.4	(15) -11.6	(16) 99.2	(17) -17.2	(18) 101.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.8	30.6	32.9	38.8	48.9	57.1	63.0	67.0	66.3	57.9	48.7	40.0	33.5
	DBStd	14.82	9.31	8.76	7.61	7.75	7.18	6.52	6.02	5.66	6.02	7.07	6.85	8.38
	HDD50	2494	601	480	353	111	16	0	0	0	6	110	304	513
	HDD65	6200	1066	900	813	485	262	114	47	53	227	504	751	978
	CDD50	2057	0	0	5	78	236	390	528	505	241	71	3	0
	CDD65	288	0	0	0	2	17	54	110	93	12	0	0	0
	CDH74	2863	0	0	0	37	212	572	1078	838	125	1	0	0
	CDH80	829	0	0	0	5	37	168	364	232	23	0	0	0
	WSAvg	8.0	8.9	8.8	8.9	8.3	7.7	7.7	7.3	6.8	7.1	7.4	8.0	8.7
	PrecAvg	21.5	1.4	1.2	1.5	1.2	2.1	2.4	3.3	2.3	1.7	1.4	1.4	1.5
(15) Precipitation	PrecMax	28.4	3.0	2.5	3.2	3.1	4.2	4.5	7.4	5.8	4.3	3.7	3.9	3.9
	PrecMin	14.3	0.2	0.2	0.4	0.3	0.4	0.2	0.6	0.4	0.3	0.2	0.0	0.3
	PrecStd	3.3	0.7	0.6	0.7	0.7	1.0	1.2	1.8	1.1	0.9	0.9	0.7	0.8
	PrecStd	3.3	0.7	0.6	0.7	0.7	1.0	1.2	1.8	1.1	0.9	0.9	0.7	0.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.0	54.1	63.9	78.9	84.2	90.8	91.8	90.7	83.3	71.6	58.3	53.3
		MCWB	47.8	47.6	51.4	59.4	64.6	69.4	69.0	68.6	65.1	60.6	53.4	49.9
	2%	DB	47.9	50.2	58.6	72.6	80.0	84.6	88.0	85.8	77.3	66.7	55.0	49.4
		MCWB	45.2	45.8	48.5	56.7	62.3	66.1	67.5	66.9	62.6	58.2	50.8	46.7
	5%	DB	44.9	47.4	54.0	67.4	75.4	80.5	84.1	82.1	73.4	62.9	52.0	46.7
		MCWB	42.3	43.6	47.1	54.0	60.5	64.2	66.3	65.7	61.0	56.7	48.9	44.5
	10%	DB	42.4	44.6	50.3	62.9	71.4	76.6	80.3	78.7	69.4	59.2	49.8	44.1
		MCWB	40.3	41.6	44.8	51.8	58.4	62.2	65.4	64.4	59.4	54.7	47.3	42.2
	0.4%	WB	48.6	49.6	53.6	60.7	67.2	71.6	71.6	71.0	66.9	62.1	54.7	50.5
		MCDB	50.5	52.4	62.5	75.3	79.6	84.6	84.7	83.3	78.6	69.1	57.5	52.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	45.2	46.6	50.3	58.0	64.3	68.1	69.8	69.2	64.5	59.4	51.7	47.2
		MCDB	47.4	49.5	56.0	70.3	75.3	80.7	82.2	81.0	73.9	64.9	53.9	49.1
	5%	WB	42.5	43.9	47.8	55.2	62.0	65.7	68.3	67.6	62.4	57.3	49.4	44.6
		MCDB	44.5	46.7	53.2	64.9	72.0	76.1	79.9	77.9	70.5	61.9	51.6	46.5
	10%	WB	40.2	41.5	45.3	53.0	59.9	63.8	66.7	66.1	60.5	55.2	47.3	42.2
		MCDB	41.9	44.4	49.8	61.0	69.1	73.0	76.9	75.1	67.4	59.0	49.5	43.8
(35) Mean Daily Temperature Range	5% DB	MDBR	8.4	10.6	14.0	18.4	19.1	18.9	18.4	19.2	16.8	13.9	9.4	7.8
		MCDBR	9.8	13.5	20.6	25.0	25.2	24.9	25.0	24.8	23.6	18.8	12.8	9.5
		MCWBR	8.2	10.0	12.9	12.5	11.2	10.4	8.8	9.7	11.0	11.3	9.7	8.1
	5% WB	MCDBR	9.8	12.8	18.7	22.4	21.7	21.3	21.3	21.2	20.0	16.8	12.1	9.2
		MCWBR	8.4	10.1	12.7	11.8	11.0	10.5	8.7	9.4	10.6	10.8	10.0	8.1
(40) Clear-Sky Solar Irradiance	taub		0.315	0.342	0.377	0.420	0.415	0.411	0.436	0.430	0.388	0.367	0.344	0.310
	taud		2.303	2.296	2.238	2.174	2.237	2.277	2.221	2.246	2.336	2.367	2.352	2.324
	Ebn at Noon		212	241	254	257	266	267	257	252	249	229	199	192
	Edh at Noon		20	27	35	42	41	40	42	39	31	25	19	17
	RadAvg		213	428	793	1318	1619	1698	1582	1395	1009	554	243	153
(45) All-Sky Solar Radiation	RadStd		32	73	104	171	183	151	194	127	126	77	35	18

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.03	N/A	N/A	N/A	N/A	N/A	N/A	-331	+193	+68
(47) Regional (28 neighbors)		+0.77	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+119	N/A

Nomenclature: See separate page